

December 22, 1999

Mr. Robert P. Powers, Senior Vice President
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNIT 1 - ISSUANCE OF AMENDMENT
RE: STEAM GENERATOR TUBE REPAIR CRITERIA AND SLEEVING
METHODOLOGIES (TAC NO. MA6389)

Dear Mr. Powers:

The U.S. Nuclear Regulatory Commission has issued the enclosed Amendment No. 238 to Facility Operating License No. DPR-58 for the Donald C. Cook Nuclear Plant, Unit 1. The amendment consists of changes to the Technical Specifications (TSs) in response to your application dated August 17, 1999.

The amendment removes the voltage-based repair criteria, F* repair criteria, and sleeving methodologies from the Unit 1 TSs and clarifies the Bases sections accordingly.

A copy of our related safety evaluation is also enclosed. The Notice of Issuance will be included in the Commission's next biweekly *Federal Register* notice.

Sincerely,
Original signed by:

John F. Stang, Senior Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-315

Enclosures: 1. Amendment No. 238 to DPR-58
2. Safety Evaluation

cc w/encls: See next page

ARC FILE CENTER COPY

DISTRIBUTION

File Center WBeckner
PUBLIC GHill(2)
PDIII-1 Reading RScholl(e-mail SE)
OGC AVegel, RIII
ACRS

TO RECEIVE A COPY OF THIS DOCUMENT, INDICATE "C" IN THE BOX

*PREVIOUSLY CONCURRED

OFFICE	PDIII-1/PM	C	PDIII-1/PM	C	PDIII-1/LA	C	EMCB/SC*	SPSB/SC*	OGC <i>NLO with represent</i>	PDIII-1/SC	C
NAME	CLyon	<input checked="" type="checkbox"/>	JStang	<input checked="" type="checkbox"/>	<i>R. Daily</i>	<input checked="" type="checkbox"/>	ESullivan	MReinhart	<i>R Weismay</i>	CCraig	<input checked="" type="checkbox"/>
DATE	12/1/99		12/1/99		12/10/99		10/22/99	11/09/99	Dec 16 1999	12/22/99	

DOCUMENT NAME: G:\PDIII-1\DCCOOK\AMDA6389.wpd

OFFICIAL RECORD COPY

DFOI

PDR ADDCK 05000315

December 22, 1999

Mr. Robert P. Powers, Senior Vice President
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNIT 1 - ISSUANCE OF AMENDMENT
RE: STEAM GENERATOR TUBE REPAIR CRITERIA AND SLEEVING
METHODOLOGIES (TAC NO. MA6389)

Dear Mr. Powers:

The U.S. Nuclear Regulatory Commission has issued the enclosed Amendment No. 238 to Facility Operating License No. DPR-58 for the Donald C. Cook Nuclear Plant, Unit 1. The amendment consists of changes to the Technical Specifications (TSs) in response to your application dated August 17, 1999.

The amendment removes the voltage-based repair criteria, F* repair criteria, and sleeving methodologies from the Unit 1 TSs and clarifies the Bases sections accordingly.

A copy of our related safety evaluation is also enclosed. The Notice of Issuance will be included in the Commission's next biweekly *Federal Register* notice.

Sincerely,
Original signed by:

John F. Stang, Senior Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-315

Enclosures: 1. Amendment No. 238 to DPR-58
2. Safety Evaluation

cc w/encls: See next page

DISTRIBUTION

File Center WBeckner
PUBLIC GHill(2)
PDIII-1 Reading RScholl(e-mail SE)
OGC AVegel, RIII
ACRS

TO RECEIVE A COPY OF THIS DOCUMENT, INDICATE "C" IN THE BOX

*PREVIOUSLY CONCURRED

OFFICE	PDIII-1/PM	C	PDIII-1/PM	C	PDIII-1/LA	C	EMCB/SC*	SPSB/SC*	OGC	PDIII-1/SC	C
NAME	CLyon		JStang		RBeatty		ESullivan	MReinhart	RWeismay	CCraig	
DATE	12/1/99		12/12/99		12/10/99		10/22/99	11/09/99	Dec 16 1999	12/22/99	

DOCUMENT NAME: G:\PDIII-1\DCCOOK\AMDA6389.wpd
OFFICIAL RECORD COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

December 22, 1999

Mr. Robert P. Powers, Senior Vice President
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNIT 1 - ISSUANCE OF AMENDMENT
RE: STEAM GENERATOR TUBE REPAIR CRITERIA AND SLEEVING
METHODOLOGIES (TAC NO. MA6389)

Dear Mr. Powers:

The U.S. Nuclear Regulatory Commission has issued the enclosed Amendment No. 238 to Facility Operating License No. DPR-58 for the Donald C. Cook Nuclear Plant, Unit 1. The amendment consists of changes to the Technical Specifications (TSs) in response to your application dated August 17, 1999.

The amendment removes the voltage-based repair criteria, F* repair criteria, and sleeving methodologies from the Unit 1 TSs and clarifies the Bases sections accordingly.

A copy of our related safety evaluation is also enclosed. The Notice of Issuance will be included in the Commission's next biweekly *Federal Register* notice.

Sincerely,

A handwritten signature in black ink, appearing to read "John F. Stang".

John F. Stang, Senior Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-315

Enclosures: 1. Amendment No. 238 to DPR-58
2. Safety Evaluation

cc w/encls: See next page

Donald C. Cook Nuclear Plant, Units 1 and 2

cc:

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Attorney General
Department of Attorney General
525 West Ottawa Street
Lansing, MI 48913

Township Supervisor
Lake Township Hall
P.O. Box 818
Bridgman, MI 49106

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
7700 Red Arrow Highway
Stevensville, MI 49127

David W. Jenkins, Esquire
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

Mayor, City of Bridgman
P.O. Box 366
Bridgman, MI 49106

Special Assistant to the Governor
Room 1 - State Capitol
Lansing, MI 48909

Drinking Water and Radiological
Protection Division
Michigan Department of
Environmental Quality
3423 N. Martin Luther King Jr Blvd
P.O. Box 30630, CPH Mailroom
Lansing, MI 48909-8130

Robert C. Godley
Director, Regulatory Affairs
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

David A. Lochbaum
Union of Concerned Scientists
1616 P Street NW, Suite 310
Washington, DC 20036-1495

A. Christopher Bakken, Site Vice President
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

Michael W. Rencheck
Vice President, Nuclear Engineering
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107