Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381-2000

Richard T. Purcell Site Vice President, Watts Bar Nuclear Plant

APR 1 0 2000

TVA-WBN-TS-99-013

10 CFR 50.90

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D. C. 20555

Gentlemen:

In the Matter of Tennessee Valley Authority Docket No. 50-390

## WATTS BAR NUCLEAR PLANT (WBN) - UNIT 1 - TECHNICAL SPECIFICATION (TS) CHANGE NO. WBN-TS-99-013 - ALTERNATE STEAM GENERATOR TUBESHEET REGION PLUGGING CRITERION (F\*)

)

In accordance with the provisions of 10 CFR 50.4 and 50.90, TVA is submitting a request for an amendment to WBN's license NPF-90 to change the TSs for Unit 1. The proposed change requests approval to use the alternate tube plugging criteria F-Star (F\*) repair limit of 1.06 inch as provided in Westinghouse Electric Coporation's WCAP-13084, "Tubesheet Region Tube Alternate Plugging (F\*) Criterion for the Tennessee Valley Authority Watts Bar Units 1 and 2 Nuclear Power Plant Steam Generators."

TVA has determined that there are no significant hazards considerations associated with the proposed change and that the change is exempt from environmental review pursuant to the provisions of 10 CFR 51.22(c)(9). The WBN Plant Operations Review Committee and the WBN Nuclear Safety Review Board have reviewed this proposed change and determined that operation of WBN Unit 1 in accordance with the proposed change will not endanger the health and safety of the public. Additionally, in accordance with 10 CFR 50.91(b)(1), TVA is sending a copy of this letter and enclosures to the Tennessee State Department of Public Health.

MATERIALS TRANSMITTED HEREWITH CONTAINS 2.790 INFORMATION U.S. Nuclear Regulatory Commission Page 2 APR 1 0 2000

Enclosure 1 to this letter provides the description and evaluation of the proposed change. This includes TVA's determination that the proposed change does not involve a significant hazards consideration, and is exempt from environmental review. Enclosure 2 contains copies of the appropriate TS pages from Unit 1 marked-up to show the proposed change. Enclosure 3 forwards the revised TS pages for Unit 1 which incorporate the proposed change.

Enclosure 4 contains a copy of WCAP-13084, "Tubesheet Region Tube Alternate Plugging (F\*) Criteria for the Tennessee Valley Authority Watts Bar Nuclear Station Units 1 and 2 Steam Generators," (Proprietary) and a copy of WCAP-13085, "Tubesheet Region Tube Alternate Plugging (F\*) Criteria for the Tennessee Valley Authority Watts Bar Nuclear Station Units 1 and 2 Steam Generators," (Non-Proprietary).

Enclosure 5 contains Westinghouse authorization letter, CAW-00-1393, accompanying affidavit, Proprietary Information Notice, and Copyright Notice.

As WCAP-13084 contains information proprietary to Westinghouse Electric Corporation, it is supported by an affidavit signed by Westinghouse, the owner of the information. The affidavit sets forth the basis on which the information may be withheld from public disclosure by the Commission and addresses with specificity the considerations listed in paragraph (b)(4) of 10 CFR Section 2.790 of the Commission's regulations.

Accordingly, it is respectfully requested that the information which is proprietary to Westinghouse be withheld from public disclosure in accordance with 10 CFR Section 2.790 of the commission's regulations. Correspondence with respect to the copyright or proprietary aspects of the WCAP or the supporting Westinghouse affidavit should reference CAW-00-1393, and should be addressed to H. A. Sepp, Manager Regulatory and Licensing Engineering, Westinghouse Electric Corporation, P. O. Box 355, Pittsburg, Pennsylvania 15230-0355.

Enclosure 6 identifies a commitment to revise the Updated Final Safety Analysis Report to include a reference to this letter for implementing the F\* criteria. U.S. Nuclear Regulatory Commission Page 3

APR 1 0 2000

TVA requests approval for the use of this F\* alternate repair criteria before the upcoming September 2000 Cycle 3 outage to prevent, if appropriate, unnecessary plugging of steam generator tubes within the tubesheet region. TVA is prepared to meet with the Staff as necessary to facilitate the Staff's review. If you have any questions about this change, please contact P. L. Pace at (423) 365-1824.

Sincerely,

ArR. T. Purcell

Enclosures cc: See page 4

Subscribed and sworn to	o before me
on this 10th day of (	Geril 2000.
$\bigcap$ = $\varphi$	
O. Clannette A:	sno
Notary/Public	
. ()	$\alpha$
My Commission Expires	Xune 27,2001
	77
	()
	$\vee$

U.S. Nuclear Regulatory Commission Page 4

APR 1 0 2000

cc (Enclosures): NRC Resident Inspector Watts Bar Nuclear Plant 1260 Nuclear Plant Road Spring City, Tennessee 37381

> Mr. Robert E. Martin, Senior Project Manager U.S. Nuclear Regulatory Commission One White Flint North 11555 Rockville Pike Rockville, Maryland 20852

U.S. Nuclear Regulatory Commission Region II Atlanta Federal Center 61 Forsyth St., SW, Suite 23T85 Atlanta, Georgia 30303

Mr. Michael H. Mobley, Director Division of Radiological Health 3<sup>rd</sup> Floor L & C Annex Nashville, Tennessee 37423

#### ENCLOSURE 5

.

WATTS BAR NUCLEAR PLANT UNIT 1

PROPRIETARY INFORMATION NOTICE COPYRIGHT NOTICE AFFIDAVIT CAW-00-1393 Transmitted herewith are proprietary and/or non-proprietary versions of documents furnished to the NRC in connection with requests for generic and/or plant-specific review and approval.

In order to conform to the requirements of 10 CFR 2.790 of the Commission's regulations concerning the protection of proprietary information so submitted to the NRC, the information which is proprietary in the proprietary versions is contained within brackets, and where the proprietary information has been deleted in the non-proprietary versions, only the brackets remain (the information that was contained within the brackets in the proprietary versions having been deleted). The justification for claiming the information so designated as proprietary is indicated in both versions by means of lower case letters (a) through (g) contained within parentheses located as a superscript immediately following the brackets enclosing each item of information being identified as proprietary or in the margin opposite such information. These lower case letters refer to the types of information Westinghouse customarily holds in confidence identified in Sections (4)(ii)(a) through (4)(ii)(g) of the affidavit accompanying this transmittal pursuant to 10 CFR 2.790(b)(1).

## **Copyright Notice**

The reports transmitted herewith each bear a Westinghouse copyright notice. The NRC is permitted to make the number of copies of the information contained in these reports which are necessary for its internal use in connection with generic and plant-specific reviews and approvals as well as the issuance, denial, amendment, transfer, renewal, modification, suspension, revocation, or violation of a license, permit, order, or regulation subject to the requirements of 10 CFR 2.790 regarding restrictions on public disclosure to the extent such information has been identified as proprietary by Westinghouse, copyright protection notwithstanding. With respect to the non-proprietary versions of these reports, the NRC is permitted to make the number of copies beyond those necessary for its internal use which are necessary in order to have one copy available for public viewing in the appropriate docket files in the public document room in Washington, DC and in local public document rooms as may be required by NRC regulations if the number of copies submitted is insufficient for this purpose. The NRC is not authorized to make copies for the personal use of members of the public who make use of the NRC public document rooms. Copies made by the NRC must include the copyright notice in all instances and the proprietary notice if the original was identified as proprietary.

#### AFFIDAVIT

#### COMMONWEALTH OF PENNSYLVANIA:

SS

#### COUNTY OF ALLEGHENY:

Before me, the undersigned authority, personally appeared H. A. Sepp, who, being by me duly sworn according to law, deposes and says that he is authorized to execute this Affidavit on behalf of Westinghouse Electric Company LLC ("Westinghouse"), and that the averments of fact set forth in this Affidavit are true and correct to the best of his knowledge, information, and belief:

H. A. Sepp, Manager Regulatory and Licensing Engineering

Sworn to and subscribed

before me this 22nd day of 2000

Notary Public



Member, Pennsylvania Association of Notarics



I am Manager, Regulatory and Licensing Engineering, in the Nuclear Services Business Unit, of the Westinghouse Electric Company (LLC), and as such, I have been specifically delegated the function of reviewing the proprietary information sought to be withheld from public disclosure in connection with nuclear power plant licensing and rulemaking proceedings, and am authorized to apply for its withholding on behalf of the Westinghouse Electric Company LLC.

- (2) I am making this Affidavit in conformance with the provisions of 10CFR Section 2.790 of the Commission's regulations and in conjunction with the Westinghouse application for withholding accompanying this Affidavit.
- (3) I have personal knowledge of the criteria and procedures utilized by Westinghouse Electric Company LLC in designating information as a trade secret, privileged or as confidential commercial or financial information.
- (4) Pursuant to the provisions of paragraph (b)(4) of Section 2.790 of the Commission's regulations, the following is furnished for consideration by the Commission in determining whether the information sought to be withheld from public disclosure should be withheld.
  - (i) The information sought to be withheld from public disclosure is owned and has been held in confidence by Westinghouse.
  - (ii) The information is of a type customarily held in confidence by Westinghouse and not customarily disclosed to the public. Westinghouse has a rational basis for determining the types of information customarily held in confidence by it and, in that connection, utilizes a system to determine when and whether to hold certain types of information in confidence. The application of that system and the substance of that system constitutes Westinghouse policy and provides the rational basis required.

Under that system, information is held in confidence if it falls in one or more of several types, the release of which might result in the loss of an existing or potential competitive advantage, as follows:

- (a) The information reveals the distinguishing aspects of a process (or component, structure, tool, method, etc.) where prevention of its use by any of
   Westinghouse's competitors without license from Westinghouse constitutes a competitive economic advantage over other companies.
- (b) It consists of supporting data, including test data, relative to a process (or component, structure, tool, method, etc.), the application of which data secures a competitive economic advantage, e.g., by optimization or improved marketability.
- Its use by a competitor would reduce his expenditure of resources or improve his competitive position in the design, manufacture, shipment, installation, assurance of quality, or licensing a similar product.
- (d) It reveals cost or price information, production capacities, budget levels, or commercial strategies of Westinghouse, its customers or suppliers.
- (e) It reveals aspects of past, present, or future Westinghouse or customer funded development plans and programs of potential commercial value to Westinghouse.
- (f) It contains patentable ideas, for which patent protection may be desirable.

There are sound policy reasons behind the Westinghouse system which include the following:

(a) The use of such information by Westinghouse gives Westinghouse a competitive advantage over its competitors. It is, therefore, withheld from disclosure to protect the Westinghouse competitive position.

- (b) It is information which is marketable in many ways. The extent to which such information is available to competitors diminishes the Westinghouse ability to sell products and services involving the use of the information.
- Use by our competitor would put Westinghouse at a competitive disadvantage
   by reducing his expenditure of resources at our expense.
- (d) Each component of proprietary information pertinent to a particular competitive advantage is potentially as valuable as the total competitive advantage. If competitors acquire components of proprietary information, any one component may be the key to the entire puzzle, thereby depriving Westinghouse of a competitive advantage.
- Unrestricted disclosure would jeopardize the position of prominence of Westinghouse in the world market, and thereby give a market advantage to the competition of those countries.
- (f) The Westinghouse capacity to invest corporate assets in research and development depends upon the success in obtaining and maintaining a competitive advantage.
- (iii) The information is being transmitted to the Commission in confidence and, under the provisions of 10CFR Section 2.790, it is to be received in confidence by the Commission.
- (iv) The information sought to be protected is not available in public sources or available information has not been previously employed in the same original manner or method to the best of our knowledge and belief.

(v) The proprietary information sought to be withheld in this submittal is that which is appropriately marked in the "Tubesheet Region Tube Alternate Plugging (F\*) Criteria for Tennessee Valley Authority Watts Bar Nuclear Station Units 1 and 2 Steam Generators", WCAP-13084 (Proprietary) and WCAP-13085 (Non-Proprietary), being transmitted by the Tennessee Valley Authority letter and Application Withholding Proprietary Information from Public Disclosure, to the Document Control Desk, Attention Mr. Samuel J. Collins. The proprietary information as submitted for use by the Tennessee Valley Authority Watts Bar Station Units 1 and 2 for the alternate tube plugging criteria is expected to be applicable in other licensee submittals in response to certain NRC requirements for justification for similar changes in Structural Design Basis.

Further this information has substantial commercial value as follows:

- (a) Westinghouse plans to sell the use of similar information to its customers for purposes of meeting requirements for licensing documentation.
- (b) Westinghouse can sell support and defense of the technology to its customers in the licensing process.

Public disclosure of this proprietary information is likely to cause substantial harm to the competitive position of Westinghouse because it would enhance the ability of competitors to provide similar methodologies and licensing defense services for commercial power reactors without commensurate expenses. Also, public disclosure of the information would enable others to use the information to meet NRC requirements for licensing documentation without purchasing the right to use the information.

The development of the technology described in part by the information is the result of applying the results of many years of experience in an intensive Westinghouse effort and the expenditure of a considerable sum of money.

In order for competitors of Westinghouse to duplicate this information, similar technical programs would have to be performed and a significant manpower effort, having the requisite talent and experience, would have to be expended for developing, testing and analytical methods.

Further the deponent sayeth not.

#### ENCLOSURE 1

### TENNESSEE VALLEY AUTHORITY WATTS BAR NUCLEAR PLANT (WBN) UNIT 1 DOCKET NO. 50-390

#### PROPOSED TECHNICAL SPECIFICATION (TS) CHANGE WBN-TS-99-013 DESCRIPTION AND EVALUATION OF THE PROPOSED CHANGE

#### I. DESCRIPTION OF THE PROPOSED CHANGE

The proposed license amendment requests NRC's approval to use an alternate repair criteria F\* (pronounced F-Star) in the tubesheet region of the steam generator. The F\* criterion addresses the action required when degradation has been detected in the top of the mechanically expanded portion of steam generator tubes within the steam generator tubesheet. (See attached Figure) Existing tube repair or plugging criteria do not take into account the effect of the tubesheet on the external surface of the The presence of the tubesheet will enhance the tube. integrity of potentially degraded tubes in that region by precluding tube deformation beyond the expanded outside diameter. An axial length of sound roll expansion equal to the F\* length at the top of the tube/tubesheet roll expansion provides sufficient structural integrity to preclude pull out of the tube due to pressure effects, even after assuming that the tube has experienced a complete circumferential severance within the tubesheet region, at or below the bottom of the F\* distance. This same axial length of roll expansion of the tube into the tubesheet also provides a barrier to significant leakage for through wall cracking of the tube in the expanded region.

The proposed change designates a portion of the tube for which tube degradation of a defined type does not necessitate remedial action, except as dictated for compliance with tube leakage limits as set forth in the WBN Unit 1 Technical Specifications. As noted above, the region of the tube subject to this change is in the expanded portion of the tube within the tubesheet of the steam generators. The length of mechanical expansion required to prevent pullout for all normal operating and postulated accident conditions, designated F\*, has been determined to be 1.06 inches.

The proposed amendment would modify Technical Specification 5.7.2.12, "Steam Generator (SG) Tube Surveillance Program," which provides tube inspection requirements and acceptance criteria to determine the level of degradation for which the tube may remain in service. The proposed amendment would add definitions required for the F\* alternate plugging criterion and prescribe the portion of the tube subject to the criterion. The use of F\* repair criteria has previously been approved by NRC for other plants e.g., Point Beach Unit 2 on November 22, 1995, Zion Units 1 and 2 on September 11, 1995, and Prairie Island on May 15, 1995, etc.

The specific changes to the technical specification are noted in the marked up copies of the applicable technical specification pages provided in Enclosure 2. By separate letter, TVA is also submitting a request for an alternate repair criteria for outside diameter stress corrosion cracking (ODSCC) that affects some of same technical specification pages. If changes are needed to the enclosed technical specification pages because of prior approval of the ODSCC criteria, this effort will be coordinated through the WBN NRC Project Manager.

#### II. REASON FOR THE PROPOSED CHANGE

The amendment has been proposed to address potential eddy current indications of tube degradation which may occur in the roll expanded portion of the tubes within the tubesheet in the steam generators at WBN Unit 1. These steam generators were fabricated with a full depth roll expansion in the tubesheet. Interpretation of eddy current data from similar plants has shown a potential for primary water stress corrosion cracking (PWSCC) in the roll expanded portion of the tube within the tubesheet. It can be shown that tube plugging or repair is not required in many cases to maintain steam generator tube integrity. Using existing technical specification tube plugging criteria, many of the tubes with potential indications would have to be repaired or removed from service. The proposed amendment would preclude occupational radiation exposure that would otherwise be incurred by plant workers involved in tube plugging or repair operations. The proposed amendment would minimize the loss of margin in the reactor coolant flow through the steam generator assumed in the loss-of-coolant-accident (LOCA) analyses and therefore, assist in assuring that minimum flow rates are maintained in excess of that required for operation at full power. Reductions in the amount of tube plugging or repair required can reduce the length of plant outages and reduce the time that the steam generator is open to the containment environment during an outage.

The possibility of tube repair by sleeving should not be considered a reason to exclude use of the alternate tubesheet plugging criterion, but should be considered one of the options used to address degradation in the expanded region of the tube. The disadvantages of tube plugs noted above also apply to some extent to sleeves. Additionally, installation of sleeves involves some impact on eddy current testing due to the changes in geometry at the ends and the joints of the sleeve and the size of probe that can pass through the reduced diameter of the sleeve.

#### III. SAFETY ANALYSIS

WCAP-13084, "Tubesheet Region Tube Alternate Plugging (F\*) Criteria for the Tennessee Valley Authority Watts Bar Nuclear Station Units 1 and 2 Steam Generators," (Proprietary) and WCAP-13085, "Tubesheet Region Tube Alternate Plugging (F\*) Criteria for the Tennessee Valley Authority Watts Bar Nuclear Station Units 1 and 2 Steam Generators," (Non-Proprietary) (Enclosure 4), summarizes an evaluation consisting of analysis and testing programs aimed at qualifying and verifying that the residual radial preload of Westinghouse steam generator tubes hardrolled into the tubesheet to determine the length of hardroll engagement necessary to resist tube pullout forces during normal and faulted condition loadings.

The limiting primary to secondary pressure differential used for the normal operating condition analysis was 1400 psig. The limiting F\* distance based on the normal operating conditions analysis, with a safety factor of 3, is 1.04 inches. The WBNP pressurizer power operated relief valves (PORV) are qualified for operation during postulated accident conditions, and therefore, would be expected to be available during plant recovery from a MSLB (Generic Letter 95-05, Attachment 1, Section 2 event. allows the use of PORV setpoint plus 3 percent as the limiting reactor coolant system pressure). As such, the maximum reactor coolant system pressure attained during recovery from a MSLB would be approximately 2405 psig. At a maximum primary to secondary pressure differential of 2405 psig during the limiting accident conditions, with a safety factor of 1.43, the appropriate F\* distance is found to be approximately 1.02 inches. For purposes of this report, the F\* distance of 1.06 inches originally specified in WCAP-13084 is used. This F\* distance is measured from the bottom of the transition between the roll expansion and the unexpanded portion of the tube or from the top of the tubesheet, whichever is lower, and does not include an allowance for eddy current elevation measurement uncertainty.

The engagement length determination method was derived from preload testing and was verified as conservative by both tube pullout and hydraulic proof (pressure) testing. Specifically, the F\* criterion was calculated from a derived preload force and a conservative static coefficient of friction for tube-to-tubesheet contact. Both the tube pullout and hydraulic proof testing conducted on rolled joints provided support for the derived preload force. Also, in assessing the F\* criterion, it has been verified that the radial preload resulting from the roll is sufficient to significantly restrict leakage during normal operating and postulated accident condition loadings. The stress levels in the tube above the F\* elevation would not be any larger in the event of a circumferential break below F\* than for a tube without a break. Thus, the stress levels would not be in excess of allowable limits for normal and postulated accident conditions.

On the basis of this evaluation, it was determined that tubes with any tube degradation within the tubesheet region below the F\* pullout criterion (1.06 inches) could be left in service. This specified distance did not include an allowance for eddy current uncertainty in locating the elevation of an indication. An evaluation of eddy current measurement uncertainties was performed for WBN Unit 1 for use in applying the F\* alternate plugging criterion. NDE measurement uncertainty lengths are provided for three types of eddy current probes. By adding these NDE measurement uncertainty values to the limiting F\* value of 1.06 inch, the evaluation provides F\* distances that include NDE uncertainty for three types of eddy current probes, as follows:

F* Va	alues (Including NDE	Measurement Uncert	ainty)
	115 mil Pancake Coil	80 mil Pancake Coil	Plus Point Coil
F* Distance	1.34″	1.36″	1.40″

Depending on the probe type used for inspection, tubes with degradation which is located a distance of less than the above F\* values below the bottom of the roll transition or the top of the tubesheet (whichever is lower in elevation) should be removed from service by plugging or repaired in accordance with plant technical specification requirements.

It should be noted that changes to the plant technical specifications, prepared as part of this License Amendment Package for F\* application, reflect the 1.06 inch F\* length "plus an allowance for NDE uncertainty." Specification of an F\* length including NDE uncertainty is not recommended for inclusion in the technical specifications, in order to preclude future technical specification changes when probes of a different type than those evaluated above are used, or in the event that future evaluations result in changes to the currently calculated NDE uncertainties.

#### IV. NO SIGNIFICANT HAZARDS CONSIDERATION DETERMINATION

TVA has concluded that operation of Watts Bar Nuclear Plant (WBN) Unit 1 in accordance with the proposed change to the technical specifications does not involve a significant hazards consideration. TVA's conclusion is based on its evaluation, in accordance with 10 CFR 50.91(a)(1), of the three standards set forth in 10 CFR 50.92(c).

#### A. The proposed amendment does not involve a significant increase in the probability or consequences of an accident previously evaluated.

The presence of the tubesheet enhances the tube integrity in the region of the hardroll by precluding tube deformation beyond its initial expanded outside diameter. The resistance to both tube rupture and tube collapse is strengthened by the presence of the tubesheet in that region. Hardrolling of the tube into the tubesheet results in an interference fit between the tube and the tubesheet. Tube rupture can not occur because the contact between the tube and tubesheet does not permit sufficient movement of tube material. In a similar manner, the tubesheet does not permit sufficient movement of tube material to permit buckling collapse of the tube during postulated loss-of-coolant-accident (LOCA) loadings.

The type of degradation for which the alternate plugging criterion, F\*, has been developed (cracking with a circumferential orientation) can theoretically lead to a postulated tube rupture event, provided that the postulated through-wall circumferential crack exists near the top of the tubesheet. An evaluation including analysis and testing has been performed to determine the resistive strength of roll expanded tubes within the tubesheet. That evaluation provides the basis for the acceptance criteria for tube degradation subject to the F\* criterion.

The F\* length of roll expansion is sufficient to preclude tube pullout from tube degradation located below the F\* distance, regardless of the extent of the tube degradation. The existing technical specification leakage rate requirements and accident analysis assumptions remain unchanged in the unlikely event that significant leakage from this region does occur. As noted above, tube rupture and pullout are not expected for tubes using the F\* alternate plugging criterion. Any leakage out of the tube from within the tubesheet at any elevation in the tubesheet is fully bounded by the existing steam generator tube rupture analysis included in the WBN Unit 1 Final Safety Analysis Report (FSAR). The proposed alternate plugging criterion (F\*) does not adversely impact any other previously evaluated design basis accident.

## B. The proposed amendment does not create the possibility of a new or different kind of accident from any accident previously evaluated.

Implementation of the proposed F\* tubesheet alternate plugging criterion does not introduce any significant changes to the plant design basis. Use of the criterion does not provide a mechanism to result in an accident initiated outside of the region of the tubesheet expansion. A hypothetical accident as a result of any tube degradation in the expanded portion of the tube would be bounded by the existing tube rupture accident analysis. Tube bundle structural integrity and leaktightness are expected to be maintained. Therefore, the proposed change does not create the possibility of a new or different kind of accident from any accident previously evaluated.

## C. The proposed amendment does not involve a significant reduction in a margin of safety.

The use of the tubesheet alternate plugging criterion has been demonstrated to maintain the integrity of the tube bundle commensurate with the requirements of Regulatory Guide 1.121, "Bases for Plugging Degraded PWR Steam Generator Tubes," for indications in the free span of tubes and the primary to secondary pressure boundary under normal and postulated accident conditions. Acceptable tube degradation for the F\* criterion is any degradation indication in the tubesheet region, more than the F\* distance below either the bottom of the transition between the roll expansion and the unexpanded tube, or the top of the tubesheet, whichever is lower. The safety factors used in the verification of the strength of the degraded tube are consistent with the safety factors in the American Society of Mechanical Engineering (ASME) Boiler and Pressure Vessel Code used in steam generator design. The F\* distance has been verified by testing to be greater than the length of roll expansion required to preclude both tube pullout and significant leakage during normal and postulated accident conditions. Resistance to tube pullout is based upon the primary to secondary pressure differential as it acts on the surface area of the tube, which includes the tube wall cross-section, in addition to the inside diameter-based area of the tube. The leak testing acceptance criteria are based on the primary to secondary leakage limit in the technical specifications and the leakage assumptions used in the FSAR accident analyses.

Implementation of the alternate tubesheet plugging criterion will decrease the number of tubes which must be taken out of service with tube plugs or repaired with sleeves. Both plugs and sleeves reduce the RCS flow margin; thus, implementation of the F\* alternate plugging criterion will maintain the margin of flow that would otherwise be reduced in the event of increased plugging or sleeving. Based on the above, it is concluded that the proposed change does not result in a significant reduction in a loss of margin with respect to plant safety as defined in the FSAR or the bases of the WBN technical specifications.

#### D. Conclusion

Based on the preceding analysis, it is concluded that operation of the WBN Unit 1 in accordance with the proposed amendment does not result in the creation of an unreviewed safety question, an increase in the probability of an accident previously evaluated, create the possibility of a new or different kind of accident from any accident previously evaluated, nor reduce any margins to plant safety. Therefore, the license amendment does not involve a Significant Hazards Consideration as defined in 10 CFR 50.92.

#### V. ENVIRONMENTAL IMPACT CONSIDERATION

The proposed change does not involve a significant hazards consideration, a significant change in the types of or significant increase in the amounts of any effluents that may be released offsite, or a significant increase in individual or cumulative occupational radiation exposure. Therefore, the proposed change meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Therefore, pursuant to 10 CFR 51.22(b), an environmental assessment of the proposed change is not required.

## TUBESHEET AREA FOR F\* CRITERION



#### ENCLOSURE 2

### TENNESSEE VALLEY AUTHORITY WATTS BAR NUCLEAR PLANT (WBN) UNIT 1

## PROPOSED TECHNICAL SPECIFICATION (TS) CHANGE WBN-TS-99-014 MARKED PAGES

#### I. AFFECTED PAGE LIST

5.0-16 5.0-18 5.0-19 5.0-35

## II. MARKED PAGES

See attached.

#### 5.7 Procedures, Programs, and Manuals

5.7.2.12 Steam Generator (SG) Tube Surveillance Program (continued)

c) A tube inspection (pursuant to Specification 5.7.2.12.f) shall be performed on each selected tube. If any selected tube does not permit the passage of the eddy current probe for a tube inspection, this shall be recorded and an adjacent tube shall be selected and subjected to a tube inspection and



- c. <u>Examination Results</u> The results of each sample inspection shall be classified into one of the following three categories:
  - C-1 Less than 5% of the total tubes inspected are degraded tubes and none of the inspected tubes are defective.
  - C-2 One or more tubes, but not more than 1% of the total tubes inspected are defective, or between 5% and 10% of the total tubes inspected are degraded tubes.
- C-3 More than 10% of the total tubes inspected are degraded tubes or more than 1% of the inspected tubes are defective. In all inspections, previously degraded tubes must exhibit significant (greater than 10%) further wall penetrations to be included in the above percentage calculations.
  - d. <u>Supplemental Sampling Requirements</u> The tubes selected as the second and third samples (if required by Table 5.7.2.12-1) may be subjected to a partial tube inspection provided:
    - 1. The tubes selected for these samples include the tubes from those areas of the tube sheet array where tubes with imperfections were previously found, and
    - 2. The inspections include those portions of the tubes where imperfections were previously found.

(continued)

#### 5.7 Procedures, Programs, and Manuals

5.7.2.12	Stea	m Gen	erato	r (SG) Tube Surveillance Program (continued)
			b)	A seismic occurrence greater than the Operating Basis Earthquake, or
			c)	A loss-of-coolant accident requiring actuation of the Engineered Safety Features, or
			d)	A main steam line or feedwater line break.
	f.	Accep	tance	e Criteria
		1.	Term as f	s as used in this specification will be defined ollows:
			a)	Degradation - A service-induced cracking, wastage, wear, or general corrosion occurring on either inside or outside of a tube;
			b)	Degraded Tube - A tube containing imperfections greater than or equal to 20% of the nominal wall thickness caused by degradation;
			c)	<pre>% Degradation - The percentage of the tube wall thickness affected or removed by degradation;</pre>
			d)	Defect - An imperfection of such severity that it exceeds the plugging limit. A tube containing a defect is defective;
DELETE ar ADD INSER	nd FA		e)	Imperfection - An exception to the dimensions, finish, or contour of a tube from that required by fabrication drawings or specifications. Eddy-current testing indications below 20% of the nominal tube wall thickness, if detectable, may be considered as imperfections;
		r	¥,	Plugging Limit The imperfection depth at or
				beyond which the tube shall be removed from service and is equal to 40% of the nominal tube wall thickness;
			g)	Preservice Inspection - An inspection of the full length of each tube in each SG performed by eddy current techniques prior to service to establish a baseline condition of the tubing. This inspection shall be performed prior to

(continued)

.

5.7.2.12 Ste	am Generator	(SG)	Tube	Surveillance	Program	(continued)
--------------	--------------	------	------	--------------	---------	-------------

initial MODE 1 operation using the equipment and techniques expected to be used during subsequent inservice inspections.

- h) Tube Inspection An inspection of the SG tube from the point of entry (hot leg side) completely around the U-bend to the top support of the cold leg; and
- Unserviceable The condition of a tube if it leaks or contains a defect large enough to affect its structural integrity in the event of an Operational Basis Earthquake, a loss-of-coolant accident, or a steam line or feedwater line break accident as specified in Specification 5.7.2.12.f.
- j) F\* Distance is the distance into the tubesheet from the bottom of the steam generator tube roll transition or the top of the tubesheet, whichever is lower in elevation (further into the tubesheet), that has been conservatively chosen to be 1.06 inches (plus an allowance for NDE uncertainty).
  k) F\* Tube is the tube with degradation equal to or
  - K) F\* Tube is the tube with degradation equal to or greater than 40%, below the F\* distance and not degraded (i.e., no indications of degradation) within the F\* distance.
  - 2. The SG shall be determined OPERABLE after completing the corresponding actions (plug all tubes exceeding the plugging limit and all tubes containing throughwall cracks) required by Table 5.7.2.12-1.
- h. <u>Reports</u> The content and frequency of written reports shall be in accordance with Specification 5.9.9.

ADD

(continued)

#### 5.9 Reporting Requirements

5.9.9 SG Tube Inspection Report (continued)

The complete results of the SG tube inservice inspection shall be submitted to the NRC within 12 months following the completion of the inspection. The report shall include:

- 1. Number and extent of tubes inspected,
- 2. Location and percent of wall-thickness penetration for each indication of an imperfection, and
- 3. Identification of tubes plugged.

Results of SG tube inspections that fall into Category C-3 shall be reported to the NRC in accordance with 10 CFR 50.72. This report shall provide a description of investigations conducted to determine cause of the tube degradation and corrective measures taken to prevent recurrence.

The results of the inspection of  $F^*$  tubes shall be reported to the Commission in accordance with 10 CFR 50.4, prior to the restart of the unit. This report shall include:

- 1. Identification of F\* tubes.
- 2. Uppermost elevation of the degradation and extent of the degradation.

NRC approval of this report is not required prior to restart.

ADD

#### INSERT A

#### PAGE 5.0-18

- f) <u>Plugging Limit</u> means the imperfection depth at or beyond which the tube shall be removed from service and is equal to 40% of the nominal tube wall thickness. This definition does not apply to the portion of the tube in the tubesheet below the F\* distance provided the tube is not degraded within the F\* distance for F\* tubes.
  - For tubes to which the F\* criteria is applied, a minimum of 1.5 inches of the tube into the tubesheet from the top of the tubesheet shall be inspected using rotating pancake coil eddy current technique or an inspection method shown to give equivalent or better information on the orientation and length of cracking. A minimum of 1.06 inches (plus an allowance for NDE uncertainty) of continuous, sound expanded tube must be established, extending from either the bottom of the roll transition or the top of the tubesheet, whichever is lower in elevation, to the uppermost extent of the indication.

### ENCLOSURE 3

#### TENNESSEE VALLEY AUTHORITY WATTS BAR NUCLEAR PLANT (WBN) UNIT 1

#### PROPOSED TECHNICAL SPECIFICATION (TS) CHANGE WBN-TS-99-013 REVISED PAGES

## I. AFFECTED PAGE LIST

5.0-16 5.0-18 5.0-19 5.0-35

#### II. REVISED PAGES

See attached.

5.7 Procedures, Programs, and Manuals

5.7.2.12	Stea	m Gen	erator	: (SG)	Tube	Survei	llance	Program	n (cont	inued)
			с)	A tub 5.7.2 tube. passa inspe adjac a tub	e insp .12.f) If ar ge of ction, ent tu e insp	bection shall by sele the ed this be sha bection	(pursu be per cted tu dy curr shall b ll be s and	ant to formed ube does rent pro- be reco selected	Specif on eac s not p obe for rded an d and s	fication th selected permit the ta tube ad an subjected to
			d)	In ad 5.7.2 had t in th exclu previ was 1 (plus exten gener tubes	ditior .12.b. he F* e tube ded fr ous wa ocated an al ding f ator t heet,	to th 2.a) t criter esheet com 5.7 all pen d below clowanc from ei cube ro whiche	e sampi hrough ion app region .2.12.1 etration the F the for N ther th ll tran ver is	les req c), al olied w . Thes on of g * dista NDE unc he bott hsition lower	uired i l tubes ill be e F* tu provide reater nce of ertaint om of t or the in elev	n s which have inspected bes may be ed the only than 20% 1.06 inches cy) the steam top of the ration.
	c.	<u>Exami</u> inspe three	<u>natio</u> ction cate	<u>n Resu</u> shall gories	<u>lts</u> - be c s:	The re lassif	esults led int	of each o one c	sample of the	e following
		C-1	Less degra defec	than ded to tive.	5% of ubes a	the to nd non	tal tuk e of tł	es insp e inspe	ected ected t	are ubes are
		C-2	One c tubes of th	or more inspected and tota	e tube ected al tub	s, but are de es ins	not mo fective pected	ore than e, or be are dee	n 1% of etween graded	the total 5% and 10% tubes.
		C-3	More degra are d	than ded t lefect	10% of ubes c ive.	the to r more	otal tu than 1	bes ins % of th	spected ne insp	are ected tubes
			In al exhib penet calcu	l inspoit side station and sta	pectic gnific ns to ns.	ons, pre ant (g. be inc	evious] reater luded i	y degra than 10 n the a	aded tu )%) fur above p	bes must ther wall ercentage
	d.	Suppl the s 5.7.2 provi	ement second 2.12-1 ded:	al San and t ) may	npling chird be su	Requin samples bjected	rements 3 (if r 1 to a	- The equired partial	tubes by Tai tube	selected as ble inspection
		1.	The t tubes tubes	ubes from with	select those imper	ed for areas fectio	these of the ns were	samples tube s previo	s inclu sheet a ously f	de the rray where ound, and
		2.	The i where	nspec impe	tions rfecti	includ ons we	e those re prev	e portio viously	ons of found.	the tubes
										(continued)

Amendment

,

Watts Bar-Unit 1

## 5.7 Procedures, Programs, and Manuals

5.7.2.12	Steam Gen	erato	or (SG) Tube Surveillance Program (continued)
		b)	A seismic occurrence greater than the Operating Basis Earthquake, or
		c)	A loss-of-coolant accident requiring actuation of the Engineered Safety Features, or
		d)	A main steam line or feedwater line break.
	f. <u>Accep</u>	otanc	e Criteria
	1.	Tern as f	ns as used in this specification will be defined Follows:
		a)	Degradation - A service-induced cracking, wastage, wear, or general corrosion occurring on either inside or outside of a tube;
		b)	Degraded Tube - A tube containing imperfections greater than or equal to 20% of the nominal wall thickness caused by degradation;
		c)	% Degradation - The percentage of the tube wall thickness affected or removed by degradation;
		d)	Defect - An imperfection of such severity that it exceeds the plugging limit. A tube containing a defect is defective;
		e)	Imperfection - An exception to the dimensions, finish, or contour of a tube from that required by fabrication drawings or specifications. Eddy-current testing indications below 20% of the nominal tube wall thickness, if detectable, may be considered as imperfections;
		f)	<u>Plugging Limit</u> means the imperfection depth at or beyond which the tube shall be removed from service and is equal to 40% of the nominal tube wall thickness. This definition does not apply to the portion of the tube in the tubesheet below the F* distance provided the tube is not degraded within the F* distance for F* tubes.
			For tubes to which the F* criteria is applied, a minimum of 1.5 inches of the tube into the tubesheet from the top of the tubesheet shall be inspected using rotating pancake coil eddy current technique or an inspection method shown to give equivalent or better information on the orientation and length of cracking. A minimum of 1.06 inches (plus an allowance for NDE uncertainty) of continuous, sound expanded tube must be established, extending from either the bottom of the roll transition or

(continued)

Amendment

Watts Bar-Unit 1

••

5.0-18

5.7.2.12	Steam	Generator	(SG) Tube Surveillance Program (continued)
			the top of the tubesheet, whichever is lower in elevation, to the uppermost extent of the indication.
		g)	Preservice Inspection - An inspection of the full length of each tube in each SG performed by eddy current techniques prior to service to establish a baseline condition of the tubing. This inspection shall be performed prior to initial MODE 1 operation using the equipment and techniques expected to be used during subsequent inservice inspections.
		h)	Tube Inspection - An inspection of the SG tube from the point of entry (hot leg side) completely around the U-bend to the top support of the cold leg; and
		i)	Unserviceable - The condition of a tube if it leaks or contains a defect large enough to affect its structural integrity in the event of an Operational Basis Earthquake, a loss-of- coolant accident, or a steam line or feedwater line break accident as specified in Specification 5.7.2.12.f.
		j)	F* Distance is the distance into the tubesheet from the bottom of the steam generator tube roll transition or the top of the tubesheet, whichever is lower in elevation (further into the tubesheet), that has been conservatively chosen to be 1.06 inches (plus an allowance for NDE uncertainty).
		k)	F* Tube is the tube with degradation equal to or greater than 40%, below the F* distance and not degraded (i.e., no indications of degradation) within the F* distance.
		2. The the the wal	SG shall be determined OPERABLE after completing corresponding actions (plug all tubes exceeding plugging limit and all tubes containing through- l cracks) required by Table 5.7.2.12-1.
	h.	<u>Reports</u> shall be	- The content and frequency of written reports in accordance with Specification 5.9.9.

#### 5.9 Reporting Requirements

5.9.9 SG Tube Inspection Report (continued)

The complete results of the SG tube inservice inspection shall be submitted to the NRC within 12 months following the completion of the inspection. The report shall include:

- 1. Number and extent of tubes inspected,
- 2. Location and percent of wall-thickness penetration for each indication of an imperfection, and
- 3. Identification of tubes plugged.

Results of SG tube inspections that fall into Category C-3 shall be reported to the NRC in accordance with 10 CFR 50.72. This report shall provide a description of investigations conducted to determine cause of the tube degradation and corrective measures taken to prevent recurrence.

The results of the inspection of  $F^*$  tubes shall be reported to the Commission in accordance with 10 CFR 50.4 prior to the restart of the unit. This report shall include:

- 1. Identification of F\* tubes.
- 2. Uppermost elevation of the degradation and extent of the degradation.

NRC approval of this report is not required prior to restart.

#### ENCLOSURE 4

#### WATTS BAR NUCLEAR PLANT UNIT 1

WCAP-13084 (PROPRIETARY) WCAP-13085 (NON-PROPRIETARY) WESTINGHOUSE CLASS 3

- 8863 - 8862

WCAP-13085

# T 33 930917 979

TUBESHEET REGION TUBE ALTERNATE PLUGGING (F\*) CRITERION FOR THE TENNESSEE VALLEY AUTHORITY WATTS BAR UNITS 1 AND 2 NUCLEAR POWER PLANT STEAM GENERATORS

October, 1991

Work Performed Under Charge No. 71C 62-54114-1

WESTINGHOUSE ELECTRIC CORPORATION NUCLEAR SERVICES DIVISION P. 0. BOX 3377 PITTSBURGH, PENNSYLVANIA 15230

© 1991 Westinghouse Electric Corporation All Rights Reserved

#### **ABSTRACT**

An evaluation was performed to develop a plugging criterion, known as the F\* criterion, for determining whether or not repairing or plugging of full depth hardroll expanded steam generator tubes is necessary for potential degradation of the tube located within the tubesheet. The evaluation consisted of analysis and testing programs aimed at quantifying the residual radial preload of Westinghouse Model D steam generator tubes hardrolled into the tubesheet. An analysis was performed to determine the length of hardroll engagement required to resist tube pullout forces during normal and faulted plant operation. The analytically determined values were verified as conservative by both pullout and proof pressure testing. The result of the evaluation is the identification of a distance, designated \*F (and identified as the F\* criterion), below the bottom of the roll transition or top of the tubesheet, whichever is lower in elevation, below which tube degradation of any extent does not necessitate remedial action, e.g., plugging or sleeving. It was postulated that the radial preload would be sufficient to significantly restrict leakage during normal operation and faulted conditions. This was also verified by the proof tests which exhibited no leakage under simulated operating mechanical conditions. On this basis an F\* criterion value of 1.06 inches was established as sufficient for continued plant operation regardless of the extent of tube degradation below F\*. The evaluation also demonstrates that application of the F\* criterion for tube degradation within the tubesheet affords a level of plant protection commensurate with that provided by RG 1.121 for degradation located outside of the tubesheet region.

## CONTENTS

		TOPIC		PAGE
1.0	INTRO	DUCTION		5
2.0	EVALUA	ATION		6
	2.1	Determination of Elastic Preload Between Tube and the Tubesheet	the	8
		2.1.1 Radial Preload Test Configuration 2.1.2 Preload Test Results Discussion a 2.1.3 Residual Radial Preload During Pl	Description nd Analysis ant Operation	9 10 12
	2.2	Engagement Distance Determination		15
		<ul> <li>2.2.1 Applied Loads</li> <li>2.2.2 End Effects</li> <li>2.2.3 Calculation of Engagement Distanc</li> <li>2.2.4 Other Transient Considerations</li> <li>2.2.5 Other Faulted Loads Consideration</li> </ul>	e Required, F* s	15 16 17 18 19
	2.3	Rolled Tube Pullout Tests		20
		2.3.1 Pullout Test Configuration Descri 2.3.2 Pullout Test Results, Discussion	iption & Analysis	20 21
	2.4	Rolled Tube Hydraulic Proof Tests		22
		2.4.1 Proof Test Configuration Descrip 2.4.2 Proof Test Results, Discussion &	tion Analysis	22 23
	2.5	5 Limitation of Primary to Secondary Leak	age	25
		2.5.1 Operating Condition Leak Conside	rations	25
		2.5.2 Postulated Accident Condition Le Considerations 2.5.3 Operating Plant Leakage Experien Tubesheet Tube Cracks	ice for	27 28
	2.0	6 Tube Integrity Under Postulated Limitir	ng Conditions	28
	2.	7 Chemistry Considerations		28
		2.7.1 Tubesheet Corrosion Testing 2.7.2 Tubesheet Corrosion Discussion		29 31
3	.0 SU	IMMARY		32
4	.0 RE	FERENCES		33
# TABLES

-----

Table 1.	Model D Preload Measurement Tests - TEST DATA	35
Table 2.	Model D Preload Measurement Tests - STRESS RESULTS	38
Table 3.	Model D Preload Measurement Tests - PRELOAD ANALYSIS SUMMARY	39
Table 4.	Model D Rolled Tube Pullout Tests	40
Table 5.	Model D Rolled Tube Hydraulic Proof Tests	40

# APPENDICES

Appendix	I	- Disposition of Tubes with Indicat	ons 41
		Above F*.	

Appendix II - Tube Wall Temperatures of Plugged Tubes 45

# TUBESHEET REGION TUBE ALTERNATE PLUGGING (F\*) CRITERION FOR THE TENNESSEE VALLEY AUTHORITY WATTS BAR UNITS 1 AND 2 NUCLEAR POWER PLANT STEAM GENERATORS

#### 1.0 INTRODUCTION

The purpose of this report is to document the development of a criterion to be used in determining whether or not repairing or plugging of full depth hardroll expanded steam generator tubes is necessary for potential degradation in that portion of the tube which is within the tubesheet. Existing Tennessee Valley Authority Watts Bar Units 1 and 2 Nuclear Power Plant Technical Specification tube repairing/plugging criteria apply throughout the tube length, but do not take into account the reinforcing effect of the tubesheet on the external surface of the tube. (It should be noted that the two units will be hereinafter referred to simply as Watts Bar.) The presence of the tubesheet will constrain the tube and will complement its integrity in that region by essentially precluding tube deformation beyond its expanded outside diameter. The resistance to both tube rupture and tube collapse is significantly strengthened by the tubesheet. In addition, the proximity of the tubesheet significantly affects the leak behavior of through wall tube cracks in this region, i.e., no significant leakage relative to plant technical specification allowables is to be expected. Based on these considerations, the use of an alternate criterion for establishing plugging margin is justified.

This evaluation forms the basis for the development of a criterion for obviating the need to repair a tube (by sleeving) or to remove a tube from service (by plugging) due to detection of indications, e.g., by eddy current testing (ECT), in a region extending over most of the length of tubing within the tubesheet. This evaluation applies to the Watts Bar Westinghouse Model D steam generators and assesses the integrity of the tube bundle, for tube ECT indications occurring on the length of tubing within the tubesheet, relative to:

- Maintenance of tube integrity for all loadings associated with normal plant conditions, including startup, operation in power range, hot standby and cooldown, as well as all anticipated transients.
- Maintenance of tube integrity under postulated limiting conditions of primary-to-secondary and secondary-to-primary differential pressure, e.g., steamline break (SLB).
- 3) Limitation of primary-to-secondary leakage consistent with accident analysis assumptions.

The result of the evaluation is the identification of a distance, designated  $F^*$  (and identified as the  $F^*$  criterion), below the bottom of the roll transition or the top of the tubesheet, whichever is lower in elevation, for which tube degradation of any extent does not necessitate remedial action, e.g., plugging or sleeving. The  $F^*$  criterion provides for sufficient engagement of the tube-to-tubesheet hardroll such that pullout forces that could be developed during normal or accident operating conditions would be successfully resisted by the elastic preload between the tube and tubesheet. The necessary engagement length applicable to the Watts Bar steam generator was found to be 1.06 inches based on preload analysis. Verification that this value is significantly conservative was demonstrated by both pullout and hydraulic proof testing of tubes in tubesheet simulating collars. Application of the F\* criterion provides a level of protection for tube degradation in the tubesheet region commensurate with that afforded by Regulatory Guide (RG) 1.121, Reference 1, for degradation located outside the tubesheet region.

## 2.0 EVALUATION

Tube rupture in the conventional sense, i.e., characterized by an axially oriented "fishmouth" opening in the side of the tube, is not possible within the tubesheet. The reason for this is that the tubesheet material prevents the wall of the tube from expanding outward in response to the internally acting pressure forces. The forces which would normally act to cause crack

extension are transmitted into the walls of the tubesheet, the same as for a nondegraded tube, instead of acting on the tube material. Thus, axially oriented linear indications, e.g., cracks, cannot lead to tube rupture within the tubesheet and may be considered on the basis of leakage effects only.

Likewise, a circumferentially oriented tube rupture is resisted because the tube is not free to deform in bending within the tubesheet. When degradation has occurred such that the remaining tube cross sectional area does not present a uniform resistance to axial loading, bending stresses are developed which may significantly accelerate failure. When bending forces are resisted by lateral support loads, provided by the tubesheet, the acceleration mechanism is mitigated and a tube separation mode similar to that which would occur in a simple tensile results. Such a separation mode, however, requires the application of significantly higher loads than for the unsupported case.

In order to evaluate the applicability of any developed criterion for indications within the tubesheet some postulated type of degradation must necessarily be considered. For this evaluation it was postulated that a circumferential severance of a tube could occur, contrary to existing plant operating experience. However, implicit in assuming a circumferential severance to occur, is the consideration that degradation of any extent could be demonstrated to be tolerable below the location determined acceptable for the postulated condition.

When the tubes have been hardrolled into the tubesheet, any axial loads developed by pressure and/or mechanical forces acting on the tubes are resisted by frictional forces developed by the elastic preload that exists between the tube and the tubesheet. For some specific length of engagement of the hardroll, no significant axial forces will be transmitted further along the tube, and that length of tubing, i.e., F\*, will be sufficient to anchor the tube in the tubesheet. In order to determine the value of F\* for application in Model D steam generators a testing program was conducted to measure the elastic preload of the tubes in the tubesheet.

The presence of the elastic preload also presents a significant resistance to flow of primary-to-secondary or secondary-to-primary water for degradation which has progressed fully through the thickness of the tube. In effect, no leakage would be expected if a sufficient length of hardroll is present. This has been demonstrated in high pressure fossil boilers where hardrolling of tube-to-tubesheet joints was at one time the only mechanism resisting flow, and in steam generator sleeve-to-tube joints made by the Westinghouse sleeve mechanical joint process.

# 2.1 DETERMINATION OF ELASTIC PRELOAD BETWEEN THE TUBE AND TUBESHEET

Tubes are installed in the steam generator tubesheet by a hardrolling process which expands the tube to bring the outside surface into intimate contact with the tubesheet hole. The roll process and roll torque are specified to result in a metal-to-metal interference fit between the tube and the tubesheet.

A test program was conducted by Westinghouse to quantify the degree of interference fit between the tube and the tubesheet provided by the full depth mechanical hardrolling operation. The data generated in these tests has been analyzed to determine the length of hardroll required to preclude axial tube forces from being transmitted further along the tube, i.e., to establish the F\* criterion. The amount of interference was determined by installing tube specimens in collars specifically designed to simulate the tubesheet radial stiffness. A hardroll process representative of that used during steam generator manufacture was used in order to obtain specimens which would exhibit installed preload characteristics like the tubes in the tubesheet.

Once the hardrolling was completed, the test collars were removed from the tube specimens and the springback of the tube was measured. The amount of springback was used in an analysis to determine the magnitude of the interference fit, which is, therefore, representative of the residual tube-to-tubesheet radial load in Westinghouse Model D steam generators.

#### 2.1.1 RADIAL PRELOAD TEST CONFIGURATION DESCRIPTION

......

The test program was designed to simulate the interface of a tube-to-tubesheet full depth hardroll for a Model D steam generator. The test configuration consisted of six cylindrical collars, approximately []<sup>a,c,e</sup> inches in ]<sup>a,c,e</sup> inches in outside diameter, and [ l<sup>a,c,e</sup> inch in length, [ inside diameter. A mill annealed, Alloy 600 (ASME SB-163), tubing specimen, approximately []<sup>a,C,e</sup> inches long with a nominal [ l<sup>a,c,e</sup> OD before rolling, was hard rolled into each collar using a process which simulated actual tube installation conditions. The roll expansion process used for this test was the same as that used during steam generator manufacture. It was designed to provide approximately the same preload independent of tubesheet hole diameter, within the acceptable range of tube thinning. The preload in the factory and in this test was determined by tube thinning which, in turn, was determined by roll expander motor stalling torque. A single nominal stalling torque value was used for all tube-to-tubesheet joints in this test.

The design of the collars was based on the results of performing finite element analysis of a section of the steam generator tubesheet to determine radial stiffness and flexibility. The ID of the collar was chosen to match the size of holes drilled in the tubesheet. The OD was selected to result in the same radial stiffness as the tubesheet.

The collars were fabricated from AISI 1018 cold rolled carbon steel similar in mechanical properties to the actual tubesheet material. The collar assembly was clamped in a vise during the rolling process and for the post roll measurements of the tube ID. Following the recording of all post roll measurements, the collars were saw cut to within a small distance from the tube wall. The collars were then split for removal from the tube and tube ID and OD measurements repeated. In addition, the axial length of the tube within the collar was measured both before and after collar removal.

Two end boundary conditions were imposed on the tube specimen during rolling. The end was restrained from axial motion in order to perform a tack roll at the bottom end, and was allowed to expand freely during the final roll.

#### 2.1.2 PRELOAD TEST RESULTS DISCUSSION AND ANALYSIS

an a shiri na shiri a s

All measurements taken during the test program are tabulated in Table 1. The data recorded was that necessary to determine the interfacial conditions of the tubes and collars. These consisted of the ID and OD of the tubes prior to and after rolling and removal from the collars as well as the inside and outside dimensions of each collar before and after tube rolling. Two orthogonal measurements were taken at each of six axial locations within the collars and tubes. In addition, gage marks were put on the tubes so that any axial deformation that occurred during collar removal might be monitored. All measured dimensions given in Table 1 are in inch units. The remainder of the data of particular interest was calculated from these specific dimensions. The calculated dimensions included wall thickness, change in wall thickness for both rolling and removal of the tubes from the collars, and percent of spring-back. It is to be noted that location number 1 of the test data was in the roll transition area. Reproducibility of the measurements was not representative of the actual hardroll region and the data for this location was not included in the calculations for averages of deflection and stress.

Using the measured and calculated physical dimensions, an analysis of the tube deflections was performed to determine the amount of preload radial stress present following the hardrolling. The analysis consisted of application of conventional thick walled cylinder equations to account for variation of structural parameters through the wall thickness. However, traditional application of cylinder analysis considers the tube to be in a state of plane stress. For these tests the results implied that the tubes were in a state of plane strain elastically. This is in agreement with historical findings that theoretical values for radial residual preload are below those actually measured, and that axial frictional stress between the tube and the tubesheet increases the residual pressure, References 2 and 3. In a plane stress analysis such stress is taken to be zero. Based on this information the classical equations relating tube deformation and stress to applied pressure were modified to reflect plane strain assumptions.

The standard analysis of thick walled cylinders results in an equation for the radial deflection of the tube as:

$$U = C_1 + r + C_2 / r$$
 (1)

where, U = radial deflection

r = radial position within the tube wall,

and the constants,  $C_1$  and  $C_2$  are found from the boundary conditions to be functions of the elastic modulus of the material, Poisson's ratio for the material, the inside and outside radii, and the applied internal and external pressures. The difference between an analysis assuming plane stress and one assuming plane strain is manifested only in a change in the constant  $C_2$ . The first constant is the same for both conditions. For materials having a Poisson's ratio of 0.3, the following relation holds for the second constant:

$$C_2(Plane Strain) = 0.862 * C_2(Plane Stress)$$
 (2)

The effect on the calculated residual pressure is that plane strain results are higher than plane stress results by slightly less than 10 percent. Comparing this effect with the results reported in Reference 2 indicated that better agreement with test values is achieved. It is to be noted that the residual radial pressure at the tube-to-tubesheet interface is the compressive radial stress at the OD of the tube.

By substituting the expressions for the constants into equation (1) the deflection at any radial location within the tube wall as a function of the internal and external pressure (radial stress at the ID and OD) is found. This expression was differentiated to obtain flexibility values for the tube deflection at the ID and OD respectively, e.g., dUi/dPo is the ratio of the radial deflection at the ID due to an OD pressure. Thus, dUi/dPo was used to find the interface pressure and radial stress between the tube and the tubesheet as:

$$S_{ro} = -P_{o} = -$$
 (ID Radial Springback) / (dUi/dPo) (3)

The calculated radial residual stress for each specimen at each location is tabulated in Table 2. Using all of the data, except location 1 for each specimen, and location 6 for specimen 2 (which was judged to be an outlier as it is more than three standard deviations from the mean of the data), the mean residual radial stress and the standard deviation was found to be [ $]^{a,C,e}$  psi and [ $]^{a,C,e}$  psi respectively. In order to determine a value to be used in the analysis, a tolerance factor for [ $]^{a,C,e}$  percent confidence to contain [ $]^{a,C,e}$  percent of the population was calculated, considering the [ $]^{a,C,e}$  useable data points, to be [ $]^{a,C,e}$ . Thus, a [ $]^{a,C,e}$  lower tolerance limit (LTL) for the radial residual preload at room temperature is [ $]^{a,C,e}$  psi.

# 2.1.3 RESIDUAL RADIAL PRELOAD DURING PLANT OPERATION

During plant operation the amount of preload will change depending on the pressure and temperature conditions experienced by the tube. The room temperature preload stresses, i.e., radial, circumferential and axial, are such that the material is nearly in the yield state if a comparison is made to ASME Code, Reference 4, minimum material properties. Since the coefficient of thermal expansion of the tube is greater than that of the tubesheet, heatup of the plant will result in an increase in the preload and could result in some yielding of the tube. In addition, the yield strength of the tube material decreases with temperature. Both of these effects may result in the preload being reduced upon return to ambient temperature conditions, i.e., in the cold condition. Based on the results obtained from the pullout tests, reported in Section 2.3.2, this is not expected to be the case as even with a very high thermal relaxation soak the results show the analysis to be conservative.

The plant operating pressure influences the preload directly based on the application of the pressure load to the ID of the tube, thus increasing the amount of interface loading. The pressure also acts indirectly to decrease the amount of interface loading by causing the tubesheet to bow upward. This bow results in a dilatation of the tubesheet holes, thus, reducing the amount of tube-to-tubesheet preload. Each of these effects may be quantitatively treated.

The maximum amount of tubesheet bow loss of preload will occur at the top of the tubesheet. Since F\* is measured from the bottom of the hardroll transition (BRT) or the top of the tubesheet, whichever is lower in elevation, and leakage is to be restricted by the portion of the tube above F\*, the potential for the tube section above F\* to experience a net loosening during operation is considered for evaluation. The effects of the three identified mechanisms affecting the preload are considered as follows:

1. Thermal Expansion Tightening - The mean coefficient of thermal expansion for the Inconel tubing between ambient conditions and  $600^{\circ}$ F is  $7.80^{*}10^{-6}$  in/in/°F. That for the steam generator tubesheet is  $7.28^{*}10^{-6}$  in/in/°F. Thus, there is a net difference of  $0.52^{*}10^{-6}$  in/in/°F in the expansion property of the two materials. Considering a temperature difference of  $550^{\circ}$ F between ambient and operating conditions the increase in preload between the tube and the tubesheet (TS) was calculated as:

7<sup>a,c,e</sup> (4)

This calculation was also performed and tabulated in Table 2. The results indicate that the increase in preload radial stress due to thermal expansion is  $[]^{a,c,e}$  psi. It is to be noted that this value applies for both normal operating and faulted conditions.

Γ

The 600°F tube temperature was selected to be a temperature, which, when multiplied by the difference between the coefficients of linear expansion of the two materials in Eq. 4, provides a lower bound (conservative) tightening effect on both the hot and cold legs of the steam generators. The property values used in Equation 4 are those for the hot leg (HL) and Delta T was taken as 550 degrees F. This is a slightly conservative value; the actual Delta T for the HL was 557 degrees F. This provides a lower value for the interfacial radial contact pressure, "S sub rT" than obtained by using the alphas and Delta T for the cold leg (CL) conditions. Therefore, with everything else being equal, the F\* value calculated is conservative for the CL.

2. Internal Pressure Tightening - The maximum normal operating differential pressure from the primary to secondary side of the steam generator is [ ]<sup>a,C,e</sup> psi during a loss of load transient. The internal pressure acting on the wall of the tube will result in an increase of the radial preload on the order of the pressure value. The increase was found as:

Γ

bows downward.

 $]^{a,c,e}$  (5)

In actuality, the increase in preload will be more dependent on the internal pressure of the tube since water at secondary side pressure would not be expected between the tube and the tubesheet.

Results from the performance of this calculation are tabulated in Table 2 for normal operating conditions and summarized on the summary sheet for both normal and faulted conditions. The results indicate that the increase in preload radial stress is  $[]^{a,C,e}$  psi for normal operating conditions and  $[]^{a,C,e}$  psi for faulted (feedline break, FLB) operating conditions.

3. Tubesheet Bow Loosening - An analysis of the Model D tubesheet was performed to evaluate the loss of preload stress that would occur as a result of tubesheet bow. The analysis was based on performing finite element analysis of the tubesheet and SG shell using equivalent perforated plate properties for the tubesheet, Reference 3. Boundary conditions from the results were then applied to a smaller, but more detailed model, in order to obtain results for the tubesheet holes. Basically the deflection of the tubesheet was used to find the stresses active on the top surface and then the presence of the holes was accounted for. For the location where the loss of preload is a maximum, the radial preload stress would be reduced by ]<sup>a,C,e</sup> psi during normal operation and [ l<sup>a,c,e</sup> psi Г during faulted (SLB) operating conditions. During LOCA the differential operating pressure is from secondary to primary. Thus, the radial preload will increase by [ ]<sup>a,c,e</sup> psi as the tubesheet

In Table 2, the absolute value of the "Total Radial Stress" may be compared with the "von Mises" stress to gain a general understanding of the stress state of the tube. The absolute value of the Total Radial Stress is seen to be only approx. 14 percent of the von Mises stress. The conclusion drawn from this comparison was that the tube had ample elastic recovery in the radial direction to maintain the tube-to-tubesheet interference fit.

Combining the room temperature hardroll preload with the thermal and pressure effects results in a net operating preload of  $[]^{a,c,e}$  psi during normal operation and  $[]^{a,c,e}$  psi for faulted operation. In addition to restraining the tube in the tubesheet, this preload should effectively retard leakage from indications in the tubesheet region of the tubes.

# 2.2 ENGAGEMENT DISTANCE DETERMINATION

The calculation of the value of F\* recommended for application to the Watts Bar steam generators is based on determining the length of hardroll necessary to equilibrate the applied loads during the maximum normal operating conditions or faulted conditions, whichever provides the largest value. Thus, the applied loads are equilibrated to the load carrying ability of the hardrolled tube for both of the above conditions. In performing the analysis, consideration is made of the potential for the ends of the hardroll at the hardroll transition and the assumed severed condition to have a reduced load carrying capability.

## 2.2.1 APPLIED LOADS

The applied loads to the tubes which could result in pullout from the tubesheet during all normal and postulated accident conditions are predominantly axial and due to the internal to external pressure differences. For a tube which has not been degraded, the axial pressure load is given by the product of the pressure with the internal cross-sectional area. However, for a tube with internal degradation, e.g., cracks oriented at an angle to the

axis of the tube, the internal pressure may also act on the flanks of the degradation. Thus, for a tube which is conservatively postulated to be severed at some location within the tubesheet, the total force acting to remove the tube from the tubesheet is given by the product of the pressure and the cross-sectional area of the tubesheet hole. The force resulting from the pressure and internal area acts to pull the tube from the tubesheet and the force acting on the end of the tubesheet hole diameter has been used to determine the magnitude of the pressure forces acting on the tube. The forces acting to remove the tube from the tubesheet are []<sup>a,C,e</sup> pounds and []<sup>a,C,e</sup> pounds respectively for normal and faulted operating conditions. Any other forces such as fluid drag forces in the U-bends and vertical seismic forces are negligible by comparison.

# 2.2.2 END EFFECTS

The analysis for the radial preload pressure between the tube and the tubesheet made no consideration of the effect of the material discontinuity at the hardroll transition to the unexpanded length of tubing. In addition, for a tube which is postulated to be severed within the tubesheet there is a material discontinuity at the location where the tube is severed. For a small distance from each discontinuity the stiffness, and hence the radial preload, of the tube is reduced relative to that remote from the ends. The analysis of end effects in thin cylinders is based on the analysis of a beam on an elastic foundation. For a tube with a given radial deflection at the end, the deflection of points away from the end relative to the end deflection is given by:

 $u_{rx} / u_{ro} = e^{-kx} * cosine (k * x)$  (6) where, k = [ ]<sup>a,c,e</sup> for Model D roll expanded tubes.

x = Distance from the end of the tube.

For the radially preloaded tube, the distance for the end effects to become negligible is the location where the cosine term becomes zero. Thus, for the

• •

roll expanded Model D tubes the distance corresponds to the product of "k" times "x" being equal to (pi/2) or [ ]<sup>a,C,e</sup> inch.

The above equation can be integrated to find the average deflection over the affected length to be 0.384 of the end deflection. This means that on the average the stiffness of the material over the affected length is 0.616 of the stiffness of the material remote from the ends. Therefore, the effective preload for the affected end lengths is 61.6 percent of the preload at regions more than  $[]^{a,c,e}$  inch from the ends. For example, for the normal operating net preload of  $[]^{a,c,e}$  psi or  $[]^{a,c,e}$  pounds per inch of length, the effective preload for a distance of  $[]^{a,c,e}$  inch from the end is  $[]^{a,c,e}$  pounds per inch or  $[]^{a,c,e}$  pounds.

## 2.2.3 CALCULATION OF ENGAGEMENT DISTANCE REQUIRED, F\*

The calculation of the required engagement distance is based on determining the length for preload frictional forces to equilibrate the applied operating loads. The axial friction force was found as the product of the radial preload force and the coefficient of friction between the tube and the tubesheet. The value assumed for the coefficient of friction was ]<sup>a,c,e</sup> as justified in Section 2.4.2 in this report for hydraulic load E l<sup>a,c,e</sup> psi or conditions. For normal operation the radial preload is [ ]<sup>a,C,e</sup> pounds per inch of engagement. Thus, the axial friction Γ ]<sup>a,C,e</sup> pounds per inch of engagement. It is to be resistance force is [ noted that this value applies away from the ends of the tube. For any given engagement length, the total axial resistance is the sum of that provided by the two ends plus that provided by the length minus the two end lengths. From l<sup>a,c,e</sup> the preceding section the axial resistance of each end is [ pounds. Considering both ends of the presumed severed tube, i.e., the hardroll transition is considered one end, the axial resistance is ]<sup>a,c,e</sup> pounds plus the resistance of the material between the ends, Г ]<sup>a,c,e</sup> inch. For example, a i.e., the total length of engagement minus [ one inch length has an axial resistance of.

Γ

]<sup>a,c,e</sup>

Conversely, for the maximum normal pressure applied load of  $[ ]^{a,c,e}$  pounds, considered as  $[ ]^{a,c,e}$  pounds with a safety factor of 3, the length of hardroll required is given by,

$$F^* = [ ]^{a,c,e} = 1.04 inch.$$

Similarly, the required engagement length for faulted conditions can be found to be 1.06 inch using a safety factor of 1.43 (corresponding to an ASME Code safety factor of 1.0/0.7 for allowable stress for faulted conditions).

The calculation of the above values is summarized in Table 3. The F\* value thus determined for the required length of hardroll engagement below the BRT or the top of the tubesheet, whichever is greater relative to the top of the tubesheet, for normal operation is sufficient to resist tube pullout during both normal and postulated accident condition loadings.

Based on the results of the testing and analysis, it is concluded that following the installation of a tube by the standard hardrolling process, a residual radial preload stress exists due to the plastic deformation of the tube and tubesheet interface. This residual stress is expected to restrain the tube in the tubesheet while providing a leak limiting seal condition.

# 2.2.4 OTHER TRANSIENT CONSIDERATIONS

An evaluation was performed to consider operating transients which could result in the condition where the tube would be at a temperature lower than the tubesheet. In this situation some of the engagement preload would be lost as the tube would shrink relative to the tubesheet. The worst case occurs for a Reactor Trip from Full Power where the tube temperature becomes about  $[]^{a,C,e}$  degrees lower than the tubesheet temperature. This temperature difference will result in a loss of preload of about  $[]^{a,C,e}$  percent of the LTL used in the analysis. However, the transient starts from a full power condition where the differential pressure,  $[]^{a,C,e}$  psi, is about  $[]^{a,C,e}$  percent lower than the maximum differential pressure used in the

analysis performed to determine the required length of engagement. Thus, the applied pressure load decreases relatively more than the tube to tubesheet preload and the margin of safety is not reduced.

## 2.2.5 OTHER FAULTED LOADS CONSIDERATIONS

The differential pressure acting across the Flow Distribution Baffle (FDB) during a FLB would be expected to cause an out-of-plane rotation of the FDB. If the pressure loading is high enough, the FDB rotation will result in tube contact and the generation of axial loads on the tubes. A nonlinear, elasticplastic finite element analysis, Reference 5, using the computer code WECAN, Reference 6, was performed to determine the magnitude of the tube axial loads due to interaction of the FDB with the tubes during an FLB.

The finite element model used for the analysis considered the FDB as an equivalent solid plate using three dimensional plastic shell elements. The equivalent material properties for the plate were calculated on the basis of nominal tube hole and pitch dimensions. However, in calculating the plate deflection to result in initial plate-to-tube contact the minimum tube-to-plate clearance dimensions were used. Tube stiffnesses were incorporated into the solution when plate rotation was determined to be at a level which would result in tube contact. The model also considered the stayrod spacer pipes as flexible supports, while the back-up bars on the boundary were assumed to act as rigid supports with out of plane restraint only. No plate restraint was considered to be offered by the wedges.

The maximum plate rotation and axial tube loads were found to occur near the center of the baffle plate. The analysis was also performed considering a reduced free rotation of the plate prior to contact and loading of a tube in order to consider the results of postulated tube denting. The maximum axial tube loading was obtained utilizing the pressure differential for the highest loaded tube support plate located anywhere in the preheater.

For the cases considered the maximum axial loading on the tubes was found to be insignificant relative to the axial pressure loads.

Seismic analysis of Model D steam generators, Reference 7, has likewise shown that axial loading of the tubes is negligible during a safe shutdown earthquake (SSE).

## 2.3 ROLLED TUBE PULLOUT TESTS

The engagement distance determination discussed in Section 2.2.3 was calculated from a derived preload force and an assumed static coefficient of friction for tube to tubesheet contact. A direct measurement of this static coefficient of friction is difficult. However, a simple pull test on a rolled tube joint provided both support for the derived preload force (less the effects of thermal expansion and internal pressure tightening) as well as an indirect measurement of the static coefficient of friction. The results of the testing verify the calculation as being conservative. An estimate of the static coefficient of friction vas calculated using the end effect adjustment described in Section 2.2.2.

# 2.3.1 <u>PULLOUT TEST CONFIGURATION DESCRIPTION</u>

Pullout tests were conducted on rolled joints of [ la'c'e inches in length and with nominal degrees of wall thinning of [ ]<sup>a,c,e</sup>. Wall thinning at the [ ]<sup>a,c,e</sup> levels were difficult to control and the actual wall thinning as measured represents the best achievable. As with the preload tests, the test configuration consisted of mill annealed, Alloy 600 (ASME SB-163) Model D tubing, hard rolled into carbon steel collars with an OD to simulate tubesheet rigidity. Inside surface roughness values of the collars were measured and recorded. The specification of surface roughness for the fabrication of the collars was the same as that used for the fabrication of the Model D tubesheets. Prior to rolling, the tubing was tack rolled and welded to the collar similar to the installation of tubes in the steam generators. The hard rolling was done in a direction away from the weld and in all aspects simulated actual tube installation conditions. After rolling, an inside circumferential cut was machined through the wall of the tube at a controlled distance from the bottom of the hardroll transition (opposite the tube weld). The machined cut simulated a severed

# 2.3.2 <u>PULLOUT TEST RESULTS, DISCUSSION AND ANALYSIS</u>

The results of these tests are tabulated in Table 4. During the pull, the tube typically showed some small load relaxation and recovery prior to achieving the maximum pullout value. This is probably due to slippage on a microscopic scale at the interface in order to further distribute the load along the length of the interface. It is thought that some initial small movement within the joint was necessary to develop the maximum contact and resistance to pullout. This was not directly observed, and would be difficult to observe directly as the axial loads required were on a scale which could cause yielding of the tube in the axial direction. For a rolled joint of ]<sup>a,c,e</sup> inch length with nominal wall thinning, the maximum pullout force Г ]<sup>a,c,e</sup> lbs, corresponding to an axial stress of was typically [ ]<sup>a,c,e</sup> psi. Г Based on the previously derived nominal preload stress ]<sup>a,C,e</sup> psi, the implied maximum coefficient of due to hardrolling of [ friction (f) would be:

Γ

<sub>7</sub>a,c,e

The [ ]<sup>a,c,e</sup> factor represents the reduction in effective length due to the loss of rigidity at the ends (end effect). The tubesheet simulant ID in the test, i.e., the tube-to-tubesheet interface diameter, 0.765 in., was set at approximately the largest hole diameter expected. Other diameters, such as the nominal or smallest could have been selected. The pullout forces

would have been expected to be proportionately lower for the smaller diameters. The coefficient of friction was expected to be independent of area of contact. Based on the observed pullout forces, the coefficient of friction assumed previously ([ $]^{a,c,e}$ ) is conservative by a factor of [ $]^{a,c,e}$  relative to a dry interface between the tube and collar.

## 2.4 ROLLED TUBE HYDRAULIC PROOF TESTS

The pullout tests discussed in the previous section provided support for the derived preload force (less the effects of thermal expansion and pressure tightening) and provided an indirect measurement of the static coefficient of friction between the tube and the tubesheet. Similar tests were conducted that used internal pressure as the acting force on the tube. While the thermal expansion tightening and the tubesheet bow loosening effects would not be represented by the this test, it would include the other factors such as preload force due to rolling, internal pressure tightening, tube-to-tubesheet coefficient of friction, tube end effects, and leakage propensity. Thermal expansion tightening and tubesheet bow loosening, being approximately the same magnitude under normal operating conditions, would offset each other. Therefore, by using internal pressure as the acting force, the rolled joint mechanics would be most like the postulated FLB or SLB conditions and would thereby represent a direct verification of the conservative nature of the calculated required engagement distance.

## 2.4.1 PROOF TEST CONFIGURATION DESCRIPTION

Similar to the rolled tube pullout tests, pressure tests were conducted on rolled joints of [  $]^{a,c,e}$  in length and with nominal degrees of wall thinning of [  $]^{a,c,e}$ . As with the preload and pullout tests, the test configuration consisted of mill annealed, Alloy 600 (ASME SB-163) Model D tubing, hard rolled into carbon steel collars with an outside diameter to simulate tubesheet rigidity. As with the pullout test samples, a machined cut was used to simulate a severed tube condition. To simulate any possible effects of reduced preload force due to tube yielding during manufacturing heat treatment, these samples were also subjected to a

heat soak of [  $]^{a,c,e}$ . The pressure tests were performed at room temperature using deionized water at a pressurizing rate of approximately [  $]^{a,c,e}$ .

## 2.4.2 <u>PROOF TEST RESULTS, DISCUSSION AND ANALYSIS</u>

The results of these tests are tabulated in Table 5. The free span length of tubing outside of the collars was reinforced with external sleeves (using 7/8" tubing) after it was discovered that the retention forces were greater than those required to burst the tubes. Even with external sleeves, most of the tests resulted in the tubing bursting near the collar or near the fittings used to pressurize the samples.

No tubes with rolled joints of greater than  $[ ]^{a,c,e}$  were expelled from the collars despite some samples being subjected to pressures as high as  $[ ]^{a,c,e}$  psi. For the  $[ ]^{a,c,e}$  engagement length tubes that were expelled, a clear absence of galling was evident. This indicates that the tube did not release primarily due to axial forces overcoming the tube-to-tubesheet friction for the length of the release, but possibly due to loss of pressure tightening caused by water ultimately being forced between the tube and the collar. Rationale supporting this postulated mechanism of release is based on the observation that the tubes did not slowly release from the collar, i.e., overcoming friction and/or galling as in the pull tests, rather for the few tubes that were expelled, the event was sudden.

Since leakage may be indicative of some loss of internal pressure tightening, tests that ended with the rolled joint leaking may be considered as approaching the expulsion load. Throughout the tests, no leakage was observed other than when the tests were terminated due to leakage.

The data reported in Table 5 were evaluated to determine an effective break-away coefficient of friction for the rolled joint under hydraulic loading conditions. The analysis consisted of comparing the internal pressure induced axial load to the radial interface load between the tube and the tubesheet-simulating collar at the time of the termination of the test. For

the specimens which were expelled from the collar a value of the coefficient was found, and for the tests terminated due to leakage at the joint a lower bound for the coefficient was found. Considering equilibrium of the pressure induced forces leads to the following expression for the coefficient of friction:

$$f_{c} = (r_{o}/2*l_{e}) * \{P_{i}/(S_{rP} + P_{r})\}$$

where,  $f_{c} = coefficient of friction$  $r_0 =$  inside radius of the collar 1 = effective length of engagement P; = internal pressure  $P_r$  = residual radial preload pressure,

Two tubes were expelled from the collars during the proof testing program. Considering the residual radial preload pressure from Table 2 results in the <sub>l</sub>a,c,e determination of coefficient of friction values of [ In addition, for the tubes which leaked, resulting in stopping the test before expulsion, lower bound values for the coefficient of friction, i.e., values which must be less than the actual coefficient of friction, i.e., values which must be less than the actual coefficient of friction, were determined to be 1<sup>a,C,e</sup>. For the tubes that burst before joint Г leakage or tube expulsion the determination of a lower bound coefficient of friction value is meaningless. On the basis of these results the use of a coefficient of friction value of [ ]<sup>a,c,e</sup> was considered adequately justified. It should be noted that if some loss of pressure tightening did occur as postulated in a previous paragraph it would mean that the actual effective break-away coefficient of friction was higher than the calculated value.

The proof tests show that even for rolled joints of [ l<sup>a,c,e</sup> in length at less-than-nominal wall thinning, pressure induced axial forces of several thousands of pounds or greater are necessary to cause the tube to release from the tubesheet. Thus, the preload based calculation of required engagement distance is indicated to be conservative.

#### 2.5 LIMITATION OF PRIMARY-TO-SECONDARY LEAKAGE

The allowable amount of primary-to-secondary leakage in a steam generator during normal plant operation is limited by plant technical specifications, generally to 0.35 gpm. This limit, based on plant radiological release considerations and implicitly enveloping the leak before break consideration for a throughwall crack in the free span of a tube, is also applicable to a leak source within the tubesheet. In evaluating the primary-to-secondary leakage aspect of the F\* criterion, the relationship between the tubesheet region leak rate at postulated FLB or SLB conditions is assessed relative to that at normal plant operating conditions. The analysis was performed by assuming the existence of a leak path, however, no actual leak path would be expected due to the hardrolling of the tubes into the tubesheet. No leakage from any of the hydraulic proof test specimens occurred for pressures up to and in excess of faulted operating conditions.

#### 2.5.1 OPERATING CONDITION LEAK CONSIDERATIONS

In actuality, as the test results substantiate for as little as [ ]a,c,e inch of hardroll engagement, the hardrolled joint would be expected to be leak tight, i.e., the plant would not be expected to experience leak sources emanating below F\*. Since the presence of the tubesheet tube indications is not expected to increase the likelihood that the plant would experience a significant number of leaks, it could also be expected, that if a primary to secondary leak is detected in a steam generator it is not in the tube region below F\*. Thus, no significant radiation exposure due to the need for personnel to look for tube tubesheet leaks should be anticipated, i.e., the use of the F\* criterion is consistent with ALARA considerations. As an additional benefit relative to ALARA considerations, precluding the need to install plugs below the F\* criterion would result in a significant reduction of unnecessary radiation exposure to installing personnel.

The issue of leakage within the F\* region up to the top of the mechanical roll transition (RT) assuming the as manufactured position of the roll transition is below the secondary side of the tubesheet includes the consideration of

postulated accident conditions in which the violation of the tube wall is very extensive, i.e., that no material is required at all below F\*. Based on operating plant and laboratory experience the expected configuration of any cracks, should they occur, is axial. The existence of significant circumferential cracking is considered to be of very low probability. Thus, consideration of whether or not a plant will come off-line to search for leaks a significant number of times should be based on the type of degradation that might be expected to occur, i.e., axial cracks. Axial cracks have been found both in plant operation and in laboratory experiments to be short, about 0.5 inch in length, and tight. In addition, for both the field and laboratory experience, once the cracks have grown so that the crack front is out of the skiproll or transition areas, they arrest.

Axial cracks in the free span portion of the tube, with no superimposed thinning, would leak at rates compatible with the technical specification acceptable leak rate. For a crack within the F\* region of the tubesheet, expected leakage would be significantly less. Leakage through cracks in tubes has been investigated experimentally within Westinghouse for a significant number of tube wall thicknesses and thinning lengths, Reference 7. In general, the amount of leakage through a crack for a particular size tube has been found to be approximately proportional to the fourth power of the crack length. Analyses have also been performed which show, on an approximate basis for both elastic and elastic-plastic crack behavior, that the expected dependency of the crack opening area for an unrestrained tube is on the order of the fourth power, e.g., see NUREG CR-3464. The amount of leakage through a crack will be proportional to the area of the opening, thus, the analytic results substantiate the test results.

.....

The presence of the tubesheet will preclude deformation of the tube wall adjacent to the crack, i.e., the crack flanks, and the crack opening area may be considered to be directly proportional to the length. The additional dependency, i.e., fourth power relative to first power, is due to the dilatation of the unconstrained tube in the vicinity of the crack and the bending of the side faces or flanks of the crack. For a tube crack located within the tubesheet, the dilatation of the tube and bending of the side faces

of the crack are suppressed. Thus, a 0.5 inch crack located within the F\* region up to the top of the roll transition would be expected to leak, without considering the flow path between the tube and tubesheet, at a rate less than a similar crack in the free span, i.e., less than the Watts Bar technical specification limit of 0.35 gpm. Leakage would be expected to be about equal to that from a 0.0625 inch free span crack. Additional resistance provided by the tube-to-tubesheet annulus would reduce this amount even further, and in the hardroll region the residual radial preload would be expected to eliminate it. This conclusion is supported by the results of the preload testing and analysis, which demonstrated that a residual radial preload of about  $[ ]^{a,C,e}$  psi exists between the tube and the tubesheet at normal operating conditions. The conclusion was further supported by the hydraulic proof testing which showed no leakage for any of the joints tested at pressures significantly exceeding normal operating conditions.

# 2.5.2 POSTULATED ACCIDENT CONDITION LEAKAGE CONSIDERATIONS

For the postulated leak source within the tubesheet, increasing the tube differential pressure increases the driving head for the leak and increases the tube-to-tubesheet loading. For an initial location of a leak source below the top of the tubesheet equal to F\*, and without considering hardroll effects, the FLB pressure differential results in approximately a 10 percent increase in the leak rate relative to that which could be associated with normal plant operation. This small effect is reduced by the increased tube to tubesheet loading associated with the increased differential pressure. Thus, for a circumferential indication within the tubesheet region which is left in service in accordance with the pullout criterion (F\*), the existing technical specification limit is consistent with accident analysis assumptions.

For axial indications in a full depth hardrolled tube below the bottom of the roll transition zone (which is assumed to remain in the tubesheet region), the tube end remains structurally intact and axial loads would be resisted by the remaining hardrolled region of the tube. For this case, the leak rate due to FLB differential pressure would be bounded by the leak rate for a free span leak source with the same crack length, which is the basis for the accident analysis assumptions.

For postulated accident conditions, the preload testing and analysis showed that a residual radial preload of about  $[]^{a,c,e}$  psi would exist between the tube and the tubesheet. In addition, the hydraulic proof test specimens did not leak, even at the minimum length of engagement, until applied pressures were significantly above those associated with accident conditions.

## 2.5.3 OPERATING PLANT LEAKAGE EXPERIENCE FOR TUBESHEET TUBE CRACKS

A significant number of tubesheet tube indications have been reported for some non-domestic steam generator units. The attitude toward operation with these indications present has been to tolerate them with no remedial action relative to plugging or sleeving. No significant number of shutdowns occurring due to leaks through these indications have been reported.

# 2.6 TUBE INTEGRITY UNDER POSTULATED LIMITING CONDITIONS

The final aspect of the evaluation is to demonstrate tube integrity under the postulated loss of coolant accident (LOCA) condition of secondary-to-primary differential pressure. A review of tube collapse strength characteristics indicates that the constraint provided to the tube by the tubesheet gives a significant margin between tube collapse strength and the limiting secondary to primary differential pressure condition, even in the presence of circumferential or axial indications.

The maximum secondary-to-primary differential pressure during a postulated LOCA is  $[ ]^{a,c,e}$  psi. This value is significantly below the residual radial preload between the tubes and the tubesheet. Therefore, no significant secondary-to-primary leakage would be expected to occur. In addition, loading on the tubes is axially toward the tubesheet and could not contribute to pullout.

#### 2.7 CHEMISTRY CONSIDERATIONS

The concern that boric acid attack of the tubesheet due to the presence of a throughwall flaw within the hardroll region of the tubesheet may result in

loss of contact pressure assumed in the development of the F\* Criterion is addressed below. In addition, the potential for the existence of a lubricated interface between the tube and tubesheet as a result of localized primary-tosecondary leakage and subsequent effects on the friction coefficient assumed in the development of the F\* Criterion is also discussed.

١

## 2.7.1 TUBESHEET CORROSION TESTING

Corrosion testing performed by Westinghouse specifically addressed the question of corrosion rates of tubesheet material exposed to reactor coolant. The corrosion specimens were assembled by bolting a steel (A336) coupon to an Alloy 600 coupon. The coupon dimensions were 3 inches x 3/4 inch x 1/8 inch and were bolted on both ends. A torque wrench was used to tighten the bolts to a load of 3 foot-pounds.

The specimens were tested under three types of conditions:

- 1. Wet-layup conditions
- 2. Wet-layup and operating conditions
- 3. Operating conditions only

The wet-layup condition was used to simulate shutdown conditions at high boric acid concentrations. The specimens were exposed to a fully aerated 2000 ppm boron (as boric acid) solution at 140 degrees F. Exposure periods were 2, 4, 6, and 8 weeks. Test solutions were refreshed weekly.

While lithium hydroxide is normally added to the reactor coolant as a corrosion inhibitor, it was not added in these tests in order to provide a more severe test environment. Previous testing by Westinghouse has shown that the presence of lithium hydroxide reduces corrosion of Alloy 600 and steel in a borated solution at operating temperatures.

Another set of specimens were used to simulate startup conditions with some operational exposure. The specimens were exposed to a 2000 parts per million boron (as boric acid) solution for one week in the wet-layup condition

(140 degrees F), and 4 weeks at operating conditions (600 degrees F, 2000 psi). During wet layup, the test solution was aerated but at operating conditions the solution was deaerated. The high temperature testing was performed in an Inconel autoclave. Removal of oxygen was attained by heating the solution in the autoclave to 250 degrees F and then degassing. This method of removing the oxygen results in oxygen concentrations of less than 100 parts per billion.

Additional specimens were exposed under operating conditions only for 4 weeks in the autoclave as described above.

High temperature exposure to reactor coolant chemistry resulted in steel corrosion rates of about 1 mil per year. This rate was higher than would be anticipated in a steam generator since no attempt was made to completely remove the oxygen from the autoclave during heatup. Even with this amount of corrosion, the rate was still a factor of nine less than the corrosion rate observed during the low temperature exposure. This differential corrosion rate observed between high and low temperature exposure was expected because of the decreasing acidity of the boric acid at high temperatures and the corrosive effect of the high oxygen at low temperatures.

These corrosion tests are considered to be very conservative since they were conducted at maximum boric acid concentrations, in the absence of lithium hydroxide, with no special precaution to deaerate the solutions, and they were of short duration. The latter point is very significant since parabolic corrosion rates are expected in these types of tests, which leads one to overestimate actual corrosion rates when working with data from tests of short duration.

Also note that the ratio of solution to surface area is high in these tests compared to the scenario of concern, i.e., corrosion caused by reactor coolant leakage through a tube wall into the region between the tube and the tubesheet.

#### 2.7.2 TUBESHEET CORROSION DISCUSSION

At low temperatures, e.g., less than 140 degrees F, aerated boric acid solutions comparable in strength to primary coolant concentrations can produce corrosion of carbon steels. Deaerated solutions are much less aggressive and deaerated solutions at reactor coolant temperatures produce very low corrosion rates due to the fact that boric acid is a very much weaker acid at high temperature, e.g., 610 degrees F, than at 70 degrees F.

In the event that a crack occurred within the hardroll region of the tubesheet, as the amount of leakage would be expected to be insufficient to be noticed by leak detection techniques and is largely retained in the crevice, then a very small volume of primary fluid would be involved. Any oxygen present in this very small volume would quickly be consumed by surface reactions, i.e., any corrosion that would occur would tend to cause existing crevices to narrow due to oxide expansion and, without a mode for replenishment, would represent a very benign corrosion condition. In any event the high temperature corrosion rate of the carbon steel in this very local region would be extremely low (significantly less than 1 mil per year).

Contrast the proposed concern for corrosion relative to  $F^*$  with the fact that Westinghouse has qualified boric acid for use on the secondary side of steam generators where it is in contact with the full surface of the tubesheet and other structural components made of steel. The latter usage involves concentrations of 5 - 10 ppm boron, but, crevice flushing procedures have been conducted using concentrations of 1000 to 2000 ppm boron on the secondary side (at approximately 275 degrees F where boric acid is more aggressive than at 610 degrees F).

Relative to the lubricating effects of boron, the presence of boric acid in water may change the wetting characteristics (surface tension) of the water but Westinghouse is not aware of any significant lubricating effect. In fact, any corrosion that would occur would result in oxides that would occupy more space than the parent metals, thus reducing crevice volume or possibly even merging the respective oxides.

#### 3.0 <u>SUMMARY</u>

١

On the basis of this evaluation, it is determined that tubes with eddy current indications in the tubesheet region below the F\* pullout criterion shown in Table 3 can be left in service. Tubes with circumferentially oriented eddy current indications of pluggable magnitude and located a distance less than F\* below the bottom of the hardroll transition or the top of the tubesheet, whichever is greater relative to the top of the tubesheet, should be removed from service by plugging or repaired in accordance with the plant technical specification plugging limit. The conservativeness of the F\* criterion was demonstrated by preload testing and analysis commensurate with the requirements of RG 1.121 for indications in the free span of the tubes, and by both pullout testing and hydraulic proof testing of thermally relaxed test specimens.

For tubes with axial indications, the criterion which should be used to determine whether tube plugging or repairing is necessary should be based on leakage since the axial strength of a tube is not reduced by axial cracks. Under these circumstances it has been demonstrated that significant leakage would not be expected to occur for throughwall indications greater than  $[]^{a,C,e}$  inch below the bottom of the hardroll transition.

In addition, it has been determined, see Appendix II, that there is no need to stabilize tubes which are removed from service due to eddy current indications in the region between the top of the tubesheet and F\*.

NOTE: The methodology for developing the F\* criterion was first reported in a previous publication, Reference 8, on the same subject. The difference being that the previously developed criterion, known as P\*, was based on the available clearance for tube motion before it would be impeded by a neighboring tube or some other physical feature of the tube bundle. The values reported herein for F\* are slightly larger than those reported for P\*.

### 4.0 REFERENCES

- United States Nuclear Regulatory Commission, Regulatory Guide 1.121, "Bases for Plugging Degraded PWR Steam Generator Tubes," August, 1976.
- Goodier, J. N., and Schoessow, G. J., "The Holding Power and Hydraulic Tightness of Expanded Tube Joints: Analysis of the Stress and Deformation," Transactions of the A.S.M.E., July, 1943, pp. 489-496.
- 3. Grimison, E. D., and Lee, G. H., "Experimental Investigation of Tube Expanding,", Transactions of the A.S.M.E., July, 1943, pp. 497-505).
- 4. ASME Boiler and Pressure Vessel Code, Section III, "Rules for Construction of Nuclear Power Plant Components," The American Society of Mechanical Engineers, New York, New York, 1983.
- 5. WCAP-9675, "Preheat Steam Generator Tube Integrity Evaluation Under Accident Condition Loadings with Postulated Circumferential Cracks," Patel, M., R., Westinghouse Electric Corporation, March, 1980. (Proprietary Class 2)
- 6. "WECAN Westinghouse Electric Corporation Computer Analysis," Westinghouse Electric Corporation, Research and Development Center, Pittsburgh, Pa.
- 7. WCAP-10012, "Steam Generator Tube Plugging Margin Analysis for the McGuire Nos. 1 and 2 Nuclear Power Plants," Villasor, A. P., Westinghouse Electric Corporation, December, 1981. (Proprietary Class 2)

WCAP-9912, Rev. 2, "Steam Generator Tube Plugging Margin Analysis for the V. C. Summer Nuclear Power Plant," Villasor, A. P., Westinghouse Electric Corporation, November, 1981. (Proprietary Class 2) REFERENCES

 WCAP-10949, "Tubesheet Region Plugging Criterion for Full Depth Hardroll Expanded Tubes," Westinghouse Electric Corporation, September, 1985. (Proprietary Class 2)

Model D Steam Generator Tube Roll Pre-Load Test - TEST DATA													
Test Locat No. No.	Location	n Collar ID Pre-Roll			Collar OD Pre-Roll			Tube ID Before Roll			Tube OD Before Roll		
	NO.	0 Deg.	90 Deg.	Avg.	0 Deg.	90 Deg.	Avg.	0 Deg.	90 Deg.	Avg.	0 Deg.	90 Deg.	Avg.
1	1 2 3 4 5 6 Average												
2	1 2 3 4 5 6 Average												
3	1 2 3 4 5 6 Average												
4	1 2 3 4 5 6 Average												
5	1 2 3 4 5 6 Average												
6	1 2 3 4 5 6 Average												
Col	. Avgs:	Notes:	<ol> <li>All meas</li> <li>Column a (These w</li> </ol>	sured dim averages were in t	mensions do not i the roll	are in inch nclude Loca transition.	nes. ation Num .)	nber 1.					

÷.

# TABLE 1.

TABLE 1. (CONT.)



 $p_{\tau}(t)$ 

#### Model D Steam Generator Tube Roll Pre-Load Test - TEST DATA

.

#### TABLE 1. (CONT.)



#### Model D Steam Generator Tube Roll Pre-Load Test - TEST DATA

TABLE 2	-
---------	---



Material Properties:		Tube/Tubesheet Dimensions (Tested):	<i>a</i> с е
Elastic Modulus: Poisson's Ratio: I600 Expansion: T/S Expansion: Oper. Delta T: Normal Delta P: Faulted Delta P:	2.87E+07 psi 0.30 7.80E-06 in/in/F 7.28E-06 in/in/F 550.00 F 1400.00 psi 2650.00 psi	Tube OD: Tube Thickness: Tubesheet ID: Thinning: Apparent Thinning:	
Additional Analysis Inpu	t:		
Tubesheet Bow Stress	Reduction	Coefficient of Friction:	
Normal: Faulted:		End Effects: Mean Radius (Rolled):	
Lower Tolerance Limit	: Factor:	Thickness (Rolled): Lambda	
95/95 LTL:	2.2324 (N = 29)	End Effect Length: Load Factor:	

Model D Steam Generator Tube Roll Pre-Load Test - PRELOAD ANALYSIS SUMMARY

TABLE 3.

EVALUATION OF REQUIRED ENGAGEMENT LENGTH



NOTES: 1. 95/95 Lower Tolerance Limit Rolled Preload Used.

έ.

For NORMAL Operation a Safety Factor of 3 was Used.
 For FAULTED Conditions a Safety Factor of 1.43 was Used

Corresponding to ASME Code use of 0.7 on Ultimate Strength. 4. The Required Length Does NOT Include Eddy Current Inspection

Uncertainty for the Location of the Bottom of the Hardroll. or the Top of the Tubesheet, Relative to the Degradation.
## TABLE 4.

# MODEL D STEAM GENERATOR ROLLED TUBE PULLOUT TESTS

Sample ID	Surface Rough. (RMS)	Engage Length (in)	Nom Reduct (%)	Actual Reduct (%)	Pullout Force (lbs)	Equiv Pres. (psi)	Ratio Oper. Pres.	to FLB Pres.	Comment
									<i>q</i> ,c,e
73									
62	1								
50									
69									
56									
51									
52									
64									
68									
53									

### TABLE 5.

# MODEL D STEAM GENERATOR ROLLED TUBE HYDRAULIC PROOF TESTS

Sample ID	Surface Rough. (RMS)	Engage Length (in)	Nom Reduct (%)	Actual Reduct (%)	Appl. Pres. (psi)	Equiv Force (lbs)	Ratio Oper. Pres.	to FLB Pres.	Comment	<del>: 14</del>
72 54 74										q,C,e
16 60 57									•	
58 67										

-

## APPENDIX I - DISPOSITION OF TUBES WITH INDICATIONS ABOVE F\*

Complementary to the criterion for leaving a tube in service with axial or circumferential indications below the top of the tubesheet is a criterion for determining the need to stabilize tubes which are removed from service due to circumferential indications below the top of the tubesheet. As was previously stated, ECT indications located above the F\* criterion are to be dispositioned in accordance with the plant technical specification plugging limit which is based on USNRC RG 1.121, which does not distinguish between circumferential and axial cracks. Moreover, RG 1.121 is concerned with the depth of penetration of tube wall degradation, i.e., when the plugging limit is reached, the tube is either plugged or sleeved. RG 1.121 does not require stabilization of plugged tubes.

The kinetics of stress corrosion cracking of mill annealed Alloy 600 in primary water is highly temperature dependent. High temperatures accelerate rates of cracking. Laboratory measurements of Arrhenius relation type activation energies typically range from 30 to 75 kcal per mole. Field experience with row 1 U-bends in domestic steam generators and roll transitions in foreign units indicate an activation energy of 85 kcal per mole.

Conditions in tubes leading to lower tube metal temperatures greatly retard the kinetics of any subsequent cracking even if applied or residual stresses are maintained. Below an assumed temperature, Thot, of 620 degrees F, cracking is retarded by a factor of 4 at 600 degrees F, a factor of 15.5 at 580 degrees F, and a factor of 64 at 560 degrees F. Moreover, the presence of hydrogen in primary water is another important consideration relative to the kinetics of cracking of Alloy 600. Laboratory measurements show that standard concentrations of hydrogen in primary water accelerates cracking by approximately a factor of 2 to 5 compared to control tests in the absence of hydrogen.

For use in a materials evaluation, in determining whether a tube plugged for an eddy current indication above the F\* criterion should be stabilized due to the potential for continued growth of an ID stress corrosion crack, tube temperatures within and above the tubesheet region were assessed, refer to Appendix II. A plugged tube was postulated to exist in a variety of environments that would influence tube temperature, including the buildup of sludge around the tube, as the sludge may act as an insulator and alter the heat conduction patterns and surface metal temperature of the tube.

١

For conservatism, active tubes adjacent to the plugged tubes, and the tubesheet itself except at the secondary surface are assumed to be at primary fluid temperature. For this tubesheet temperature condition, several sludge deposition cases were hypothesized:

CASE 1 considers no sludge buildup adjacent to the tube and the tube does not have a through wall penetration prior to plugging. Certain conditions in tubes (such as wet walls prior to plugging) may lead to the presence of superheated steam existing within the tube. Limited data on Alloy 600 at high temperatures is consistent with general observations on aluminum and steel alloys in low temperature water vapor. At low superheat, i.e., high relative humidity, the cracking response in water vapor is essentially equivalent to that in the liquid phase at the same temperature, while at high superheat, i.e., low relative humidity, the cracking kinetics are much reduced. A plugged tube is essentially dry on its ID when plugged; therefore, although the ID temperature of the tube in the region within the tubesheet would most likely be equivalent to  $T_{hot}$ , the ratio of the vapor pressure of any water trapped in the tube during plugging to the pressure of saturated water vapor would be low, i.e., high superheat, thus greatly reducing the cracking kinetics. Also, as previously discussed, the lack of the presence of hydrogen in a plugged tube significantly retards further cracking. Therefore, combining the above two effects, the probability a plugged tube with degradation that has not progressed through wall would continue to degrade is small in this environment and would not require stabilization. It is noted that this case is really independent of

whether or not sludge is postulated to be present, i.e., the temperature inside the tube in the tubesheet region will be near Thot regardless of the presence of sludge.

CASE 2 considers no sludge buildup either adjacent to a plugged tube or in a plugged tube. A through wall indication is postulated and the tube is filled with water due to the ingress of secondary side water through the penetration. The water contained in the tube in the tubesheet area boils. This rapid heat transfer mechanism maintains the tube inner diameter metal surface at or slightly above Tsat for the portion of the tube in the tubesheet. The relatively low secondary side temperature will significantly inhibit the continuation and/or initiation of stress corrosion cracking. Therefore, considering both the effects of the reduced secondary side temperature and the lack of the presence of any hydrogen concentration on continued stress corrosion cracking, the probability of a plugged tube with a through wall penetration continuing to degrade is very small and would not require remedial action other than plugging or sleeving.

CASE 3 considers the effect of sludge buildup on the tubesheet adjacent to a plugged tube with a through wall penetration. Since the sludge acts as a poor conductor, the mechanisms for cooling the tube are not as efficient as for the previous two cases. If the secondary side water ingress remains primarily in liquid form with some localized boiling at the tube wall, and the sludge pile depth is less than about 4 inches, the temperature on the inner diameter of the tube will probably be slightly above T<sub>sat</sub>. As discussed previously, certain conditions in plugged tubes may lead to the presence of superheated steam rather than liquid water the through wall degraded tube. It was also stated that at low superheat, the cracking response in water vapor is essentially equivalent to that in the liquid phase at the same temperature. At sludge depths greater than about 8 inches, the tube metal temperature in the tubesheet approaches plant hot leg temperature. The effect of low superheat and higher temperatures could result in additional crack growth. However, the above two scenarios are not expected to occur. In steam generators with

٠,

a flow distribution baffle, sludge buildup to a height of 8 inches is precluded by geometry constraints. Moreover, as the postulated crack would most likely limit the ingress of the secondary side water in the through wall degraded tube, the most likely scenario would be that the tube is essentially dry on the inside and the ratio of the vapor pressure of the water to its saturation pressure is relatively low, thereby greatly reducing the crack kinetics. With the lack of the presence of any hydrogen concentrations, the potential for additional crack growth would be significantly reduced; therefore, tube stabilization is not required.

An extension to CASE 3 could be postulated such that the throughwall penetration is of such size as to initially admit water into the plugged tube. The water subsequently boils and the internal pressure prevents any further water from entering the tube. In this case the steam would be at the secondary side pressure, i.e., high superheat conditions, and for reasons cited in consideration of case 1, further crack growth would not be expected.

#### APPENDIX II - TUBE WALL TEMPERATURES OF PLUGGED TUBES

To assess whether further degradation due to postulated PWSCC can occur in a plugged tube and to disposition tubes with indications above the F\* criterion as to whether they should be stabilized when plugged, the metal temperature of the tube inside diameter at elevations above the F\* criterion, but, below the top of the tubesheet, was evaluated. Active tubes adjacent to the plugged tube, and the tubesheet itself except at the secondary surface, are at the primary fluid temperature. For a tubesheet temperature condition equivalent to  $T_{hot}$ , five different sludge deposition cases were hypothesized.

- 1. An intact tube without sludge deposition on the tubesheet
- 2. A perforated tube without sludge on the tubesheet
- 3. An intact tube with sludge deposition on the tubesheet.
- 4. A perforated tube with sludge deposition on the tubesheet.
- A perforated tube with/without sludge deposition on the tubesheet without secondary water ingress.

An intact tube is defined as a plugged tube with no throughwall penetration i.e., no secondary water comes in contact with the tube inner wall, while a perforated tube is defined as a tube with a throughwall penetration i.e., secondary water comes in contact with the tube inner wall.

1.1 Intact Tube Without Sludge Deposition

With the exception of a shallow layer at the tubesheet surface, the tubesheet metal temperature adjacent to active tubes just below the top surface of the tubesheet is expected to be at primary coolant inlet temperature (i.e.  $T_{hot}$ ) for the hot leg side of the tube bundle. Therefore, the outer wall temperature can be as high as  $T_{hot}$  for a full depth hardroll expanded tube. For an intact tube, the inner wall of the tube is essentially dry. The inner wall maximum tube temperature along the length of the tubesheet would approach  $T_{hot}$ .

## 1.2 A Perforated Tube Without Sludge Deposition

Once a plugged tube is perforated, secondary water can ingress into the primary side of the inactive tube. The water contained in that portion of the tube within the tubesheet boils. This rapid heat transfer mechanism keeps the inner tube wall temperature at approximately  $T_{sat} + 5^{\circ}F$  (allowing for a localized wall superheat effect).

## 1.3 Intact Tube With Sludge Deposition

With sludge accumulation on the top of the tubesheet, the whole depth of the tubesheet is expected to be at  $T_{hot}$ . As is the case without sludge deposition, the inner wall of the inactive intact tube would be essentially dry with a maximum temperature of  $T_{hot}$  anticipated along the length of the tubesheet.

1.4 A Perforated Tube With Sludge Deposition

Similar to the case of a perforated tube with sludge deposition, secondary water can ingress into the primary side of the inactive tube. The heat transfer mechanism for cooling the tube inner wall metal temperature would be the same as with the case of no sludge deposition on the tubesheet. The inner wall temperature would be at approximately  $T_{sat}$  + 5°F because of the boiling occurring inside the tube.

1.5 A Perforated Tube Without Communication

A situation could develop such that only a limited amount of secondary water would initially leak into a tube with a throughwall penetration. It can be postulated that the small amount of water ingressing into the tube inner diameter could evaporate and form superheated steam within the depth of the tubesheet or the tubesheet plus the height of the sludge. This case would be similar to an intact tube as the superheated steam would prevent the water from entering into the primary side of the tube. The inner wall of the tube would essentially be in a dry condition and the maximum inner wall metal temperature would be  $T_{hot}$ .

In summary, the inner wall temperature for the perforated tube within the depth of the tubesheet, both with or without sludge deposition, is essentially at  $T_{sat}$  + 5°F when there is water communication due to a through wall penetration. The inner wall temperature for a perforated tube without water communication could be as high as  $T_{hot}$ . Finally, the inner wall temperature for an intact tube with or without sludge deposition could be as high as  $T_{hot}$ .

## ENCLOSURE 6

WATTS BAR NUCLEAR PLANT UNIT 1 ALTERNATE REPAIR CRITERIA F\*

COMMITMENT LIST

### ENCLOSURE 6

### WATTS BAR NUCLEAR PLANT UNIT 1 ALTERNATE REPAIR CRITERIA F\*

### COMMITMENT LIST

TVA will revise the Updated Final Safety Analysis Report to include a reference to this letter for implementing the alternate repair criteria F\*.