

Examination Outline Comments

JPM to feed w/ AFW appears to duplicate actions in scenario 1

The JPM's for BAM tank recirc and Swap COLSS appear simplistic

Scenario 1 needs a better condition/event to drive a controlled reactivity change

TS coverage may be low

Admin JPM's for plant computer and rod programming may be more system than admin