

FENOC

FirstEnergy Nuclear Operating Company

50-440

Perry Nuclear Power Plant
10 Center Road
Perry, Ohio 44081

John K. Wood
Vice President, Nuclear

440-280-5224
Fax: 440-280-8029

June 13, 2000
PY-CEI/LCDU-0058L


Attention: Robert Shelby, Mentor Waste Facility
Lake County Department of Utilities
P.O. Box 490
Painesville, Ohio 44077-0490

Ladies and Gentlemen:

Enclosed are the results of an isotopic analysis performed for industrial wastewater from the Perry Nuclear Power Plant. No radioactive material attributable to the Perry Nuclear Power Plant was detected.

If you have questions or require additional information, please contact Ms. Donna Tizzano at (440) 280-5514.

Very truly yours,



DGT:sc

Enclosures

cc: NRC Region III
NRC Resident Inspector Office
NRC Project Manager
NRC Document Control Desk (Docket No. 50-440)

C001

Note: NOTE

MPL Number:	SEWAGE	Sched Sampled Date:	0:00:00 4/01/00
Sample ID:	256458	Actual Sampled Date:	10:00:00 5/16/00
System Name:	ENVIRONMEN	Desc:	Environmental Sample
Mode Number:	6	Desc:	At All Times
Reason/Freq:	0	Desc:	Quarterly

Isotopic by Gamma Spectroscopy

Status: PV

Limit: 0.00 to 0.00

0.00E+00 uci/ml

MCA: 1002

NOTE: A numeric result of zero indicates 'None Detected'