



Entergy Operations, Inc.
Waterloo Road
P.O. Box 756
Port Gibson, MS 39150
Tel 601 437 6470

Jerry C. Roberts
Director
Nuclear Safety Assurance

June 1, 2000

U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Document Control Desk

Subject: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-29
Changes to Emergency Plan Implementing Procedure

GNRO-2000/00045

Gentlemen:

Entergy Operations, Inc. submits in accordance with 10CFR50 Appendix E, Section V changes to an Emergency Plan Implementing Procedure.

The following Emergency Plan Procedure is attached:

<u>Procedure No.</u>	<u>Issue Date</u>
10-S-01-1, Rev. 106	05/02/00

Should you have any questions or concerns regarding the attachment, please contact Mr. W. B. Abraham at (601) 437-2319.

Yours truly,

A handwritten signature in black ink, appearing to read "J. Roberts".

JCR/WBA/amt

attachment: 10-S-01-1, Rev. 106. "Activation of the Emergency Plan"
cc: (See Next Page)

G200531

NRR-037

A045

June 1, 2000
GNRO-2000/00045
Page 2 of 2

cc: Ms. J. L. Dixon-Herrity, GGNS Senior Resident (w/a)
Mr. D. E. Levanway (Wise Carter)
Mr. L. J. Smith (Wise Carter) (w/a)
Mr. N. S. Reynolds (w/a)
Mr. H. L. Thomas (w/o)

Mr. E. W. Merschoff (w/2)
Regional Administrator
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

Mr. S. P. Sekerak, NRR/DLPM/PD IV-I (W/2)
U.S. Nuclear Regulatory Commission
One White Flint North, Mail Stop 04-D3
11555 Rockville Pike
Rockville, MD 20852-2378

PLANT OPERATIONS MANUAL

Volume 10
Section 01

10-S-01-1
Revision: 106
Date: 5/2/00

EMERGENCY PLAN PROCEDURE

ACTIVATION OF THE EMERGENCY PLAN

SAFETY RELATED

Prepared: K. McDonald
Reviewed: W. Russell
 Technical
Concurred: W. Carroll
 Manager, Operations
PSRC: [Signature]
Approved: J. Denah M. [Signature]
 Plant General Manager Manager, Emergency Preparedness

List of Effective Pages:

Pages 1-11

Attachments I, II

EPP 01-02 (Flowchart) Dated 4/5/00

List of TCNs Incorporated:

<u>Revision</u>	<u>TCN</u>
1-4	None
5	1, 2
6	3
7	4
8	5, 6
9	None
10	7, 8
11	None
12	9
13	10
14, 15	None
16	11
17	None
18	12
19	None
20	None
21	None
22	13, 14
23	None
100	15
101	None
102	16
103	None
104	None
105	None
106	None

OKS

57

Title: Activation of the Emergency Plan	No.: 10-S-01-1	Revision: 106	Safety Evaluation
---	----------------	---------------	-------------------

Facility:	GRAND GULF
-----------	------------

I. SIGNATURES

Preparer:		Kelly McDonald	4/4/00
	Signature	Name (print)	Date
Reviewer:		W.A. Russell	4/5/00
	Signature	Name (print)	Date

II. OVERVIEW

Document Evaluated: (Include document number, revision, and title)
Activation of the Emergency Plan 10-S-01-1 Revision 106
Brief Description of the Proposed Change:
See attached description

III. PRE-SCREENING

Check the applicable boxes below. If any of the boxes are checked, neither a Screening nor a 50.59 Evaluation is necessary. Provide supporting documentation or references as appropriate.

- ☐ The change is editorial as defined in either Section 5.3.4 ____ or Section 5.4.1.1 ____ of this procedure. (Insert item # from Section 5.3.4 or Section 5.4.1.1). Provide document change request to the appropriate department, if required.
- ☐ The change is a substitute part per Section 5.4.1.2.
- ☒ The change will be controlled in its entirety under 10CFR50.54 instead of 10CFR50.59 per Section 5.4.1.3 of this procedure.
- ☐ An approved, valid Screening or 50.59 Evaluation covering all aspects of the change already exists per Section 5.4.1.4. Reference 50.59 Evaluation # ____ or attach documentation. Verify the previous Screening or 50.59 Evaluation remains valid.
- ☐ The proposed change, in its entirety, has been approved by the NRC per Section 5.4.1.5.
Reference:
- ☐ The change is being made to conform to the SAR per Sections 5.4.1.6.

BASIS: (Discuss how the activity meets the Pre-Screening criteria.) This procedure revision incorporates revision 41 of the Emergency Plan which is controlled under 10CFR 50.54. All other changes were evaluated and found not to affect the Emergency Plan.

EVALUATION FOR EMERGENCY PREPAREDNESS PROCEDURE CHANGE

Procedure number 10-S-01-1, Rev. 106

Proposed Change:

1. Change page number in "Table of Contents" for Details and section 6.1 to page number 6 and section 6.2 to page 9.

Justification: Editorial, added definitions in section 5 of Revision 105 caused steps to be located on subsequent pages.
2. Change Attachment IV in step 1.2.1 and step 6.3.1 to EPP 01-02 (Flowchart)

Justification: Attachment IV is a flowchart version of Attachment I. Any time that there is any change to the body of the procedure 10- S- 01-1, new flowcharts must be printed out on a plotter and then attached to the procedure for distribution, even if no change occurred to the contents of the flowchart. Changing Attachment IV to an EPP form will eliminate the requirement to printout new flowcharts unless the contents of the flowchart or Attachment I are changed. A note has been added to the EMERGENCY CLASSIFICATION TABLE OF CONTENTS (Attachment I) to have EPP 01-02 (Flow Chart) updated if a change to information contained in Attachment I occurs. This is to ensure that EPP 01-02 (Flow chart) is kept updated with Attachment I.
3. Delete step 4.4 that list Emergency Classification Flowchart as Attachment IV

Justification: See justification for #2 above.
4. Changes step 6.1.2 to read "or EPP 01-02 (Flowchart)" and deletes "or IV".

Justification: Editorial, see justification for #2 above.
5. Adds "or phone # 6426" to step 6.1.4.f.

Justification: Phone # 6426 ties the telephone system into the Gaitronics paging system. Adding this number allows making announcements over the Gaitronics loud speakers from plant telephones without requiring use of the Gaitronics handsets. Provides the user with the option to use either method for announcements.
6. Adds a note at the bottom of page 1 of Attachment I (Emergency Classification Table of Contents) stating that any changes to the information contained in Attachment 1 may require changes to EPP 01-02 (Flowchart) .

Justification: To ensure that the Flowchart version of Attachment I is reviewed for impact if Attachment I is updated or changed.
7. Adds the Control Room and Remote Shutdown Panel to EAL 14.4.1 (Security Threats General Emergency Classification) for areas of the plant that are occupied by unauthorized personnel.

Justification: EAL 14.4.1 was changed to add a condition where unauthorized personnel are occupying the Control Room or the Remote Shutdown Panel. These areas were added to address the NRC's concern of the potential confusion over wording that was previously used which involves unauthorized personnel controlling Decay Heat Removal, Reactor Water Level, or Reactivity Control and not specific areas of the plant.

Title: Activation of the Emergency Plan	No.: 10-S-01-1	Revision: 106	Emergency Procedure Evaluation
--	----------------	---------------	--------------------------------------

EVALUATION OF EMERGENCY PREPAREDNESS PROCEDURE

Procedure Number: 10-S-01-1

Procedure Name: Activation of Emergency Plan

Revision / TCN Number: Revision 106

Does the procedure Revision / TCN require an Emergency Plan change?

☐ Yes ☒ NoNOTE: IF YES, THIS PROCEDURE CAN NOT BE ISSUED UNTIL THE EMERGENCY PLAN IS CHANGED /
REVISED.

Reason for 'No' response:

This procedure revision incorporates revision 41 of the Emergency Plan. All other
changes were evaluated and found not to affect the emergency Plan.

Prepared:

K. McDonald

Approved:

M. J. H.
Manager, Emergency Preparedness

Title: Activation of the Emergency Plan	No.: 10-S-01-1	Revision: 106	Page: i
--	----------------	---------------	---------

Periodic Review Required:

☐ YES☒ NO

If Yes, list frequency: _____ Year

If No, refer to Attachment XIX of 01-S-02-3 for a list of procedure review methods and fill in the appropriate letter(s) below; if "Other," specify method.

Method(s) of Review

M

10CFR50.59 Review Required:

☐ Yes - If Yes, attach 50.59 Review.☒ No - Not required per section 6.3.2.b
(enter Section 6.3.2(b) or 6.3.2(c) of procedure
01-S-02-3)

Cross-discipline review required:

☒ YES☐ NO

Tech Reviewer's Initials

WAC

Initials

Reviewed by: Offsite Emergency Coordinator Position LeadEmergency Director Position LeadSuperintendent, OperationsSecurity CoordinatorCWEWACBlmDoes this directive contain Tech Spec Triggers? ☐ YES ☒ NO

Title: Activation of the Emergency Plan	No.: 10-S-01-1	Revision: 106	Page: ii
--	----------------	---------------	----------

REQUIREMENTS CROSS-REFERENCE LIST

Requirement Implemented by Directive		Directive Paragraph Number That Implements Requirement
Name	Paragraph Number	
ANSI N18.7	5.3.9.2.S1	*
GGNS Emer Plan	2.4.S3	1.1.1
GGNS Emer Plan	3.3.S1	2.1.2
GGNS Emer Plan	6.2.2.S3 & S4	2.1.1, 6.1.2 S2
GGNS Emer Plan	5.4.5.a,b,c	2.2
GGNS Emer Plan	5.4.4	2.3
GGNS Emer Plan	3.1.S2	6.1.2
GGNS Emer Plan	6.2.2.S1 & S2	6.1.2 (Note)
GGNS Emer Plan	4.1.4.S3	Attachment I
GGNS Emer Plan	4.1.S3	6.1.4, 6.3
GGNS Emer Plan	4.1.S13	6.1.3 (Note)
GGNS Emer Plan	3.3.S6.b	6.1.3
GGNS Emer Plan	6.2.4.S11 & S12	6.1.4.i(1)
GGNS Emer Plan	6.2.4.S13	6.1.4.i(2)
GGNS Emer Plan	6.2.4.S14	6.1.4.i(3)
GGNS Emer Plan	4.1.4.S2	6.1.4.j(1)
GGNS Emer Plan	6.3.1.S1 & S2	6.2.1
GGNS Emer Plan	6.3.2	6.2.1a
GGNS Emer Plan	6.3.3, 6.3.4	6.2.1b
GGNS Emer Plan	9.3.S7	Attachment II (Note)
GGNS Emer Plan	Table 4-1	Attachment I
GGNS Emer Plan	7.5.3.a.2.e	5.30
GNRI-93/00171	93-13-01, Item 6	Attachment I, 17.1.1
GGNS Emer Plan	6.5.1.b.S5, S6	6.1.4.j(1)
GGNS Emer Plan	7.5.3.a.3.c	6.1.4.d
GGNS Emer Plan	6.2.4.S2	2.1.2
GGNS Emer Plan	6.2.4.S7 & S8	2.4
GGNS Emer Plan	5.4.S6	6.1.4.i(1), i(2), i(3)
GGNS Emer Plan	3.3.S3 & S4	2.4
GGNS Emer Plan	6.5.1.b	6.1.4

* Covered by directive as a whole or by various paragraphs of the directive.

Current Revision Statement

Revision 106:

1. Change page number in "Table of Contents" for Details section and section 6.1 to page number 6 and section 6.2 to page 9.
2. Change Attachment IV in step 1.2.1 and 6.3.1 to EPP 01-02 (Flowchart)
3. Delete step 4.4 that list Emergency Classification Flowchart as Attachment IV
4. Changes step 6.1.2 to read "or EPP 01-02 (Flowchart)" and deletes "or IV".
5. Adds "or phone # 6426" to step 6.1.4.f.
6. Adds a note at the bottom of page 1 of Attachment I (Emergency Classification Table of Contents) to update EPP 01-02 (Flowchart) anytime that the information contained in Attachment I is changed.
7. Adds the Control Room and Remote Shutdown Panel to EAL 14.4.1 (Security Threats General Emergency Classification) for areas of the plant that are occupied by unauthorized personnel.

Title: Activation of the Emergency Plan	No.: 10-S-01-1	Revision: 106	Page: 1
--	----------------	---------------	---------

TABLE OF CONTENTS

	<u>Page</u>
1.0 PURPOSE AND DISCUSSION	2
2.0 RESPONSIBILITIES	2
3.0 REFERENCES	3
4.0 ATTACHMENTS	3
5.0 DEFINITIONS	3
6.0 DETAILS	6
6.1 Activation of Emergency Plan	6
6.2 Supplemental Actions	9
6.3 Upgrading Emergency Classifications	10
6.4 Terminating Emergency	10
6.5 Records and Reports	11

Title: Activation of the Emergency Plan	No.: 10-S-01-1	Revision: 106	Page: 2
--	----------------	---------------	---------

1.0 PURPOSE AND DISCUSSION

1.1 Purpose

1.1.1 This procedure provides guidance to:

- a. Classify an emergency according to severity.
- b. Assign responsibilities for emergency actions.
- c. Establish lines of authority and communication.
- d. Initiate emergency actions to safeguard the public and plant personnel.
- e. Upgrade or terminate emergency classification when severity of event changes.

1.2 Discussion

1.2.1 Whenever plant conditions are identified that meet the Emergency Action Level Criteria in Attachment I or EPP 01-02 (Flowchart), this emergency plan procedure shall be implemented.

1.3 Changes required for implementation of 1994 TSIP were incorporated in Revision 100. For historical reference this statement should not be deleted.

2.0 RESPONSIBILITIES

2.1 Shift Superintendent - Is responsible for determining if emergency declaration is required.

2.1.1 If an Emergency Action Level (EAL) is reached or exceeded, the Shift Superintendent shall:

- a. Classify the emergency and make the appropriate declaration if required.
- b. Take action to ensure safe operation of plant and protection of plant personnel, the general public, and plant equipment.
- c. Perform assessment actions.
- d. Perform any other emergency actions as appropriate.

2.1.2 The Shift Superintendent assumes the role of Emergency Director upon initial classification of an emergency, and becomes the Operations Coordinator, when relieved by the On-Call Manager (as Emergency Director), until relieved by the On-Call Operations Coordinator.

2.2 Operations Coordinator - Reports directly to the Emergency Director and is responsible for:

2.2.1 Coordinating all activities in the Control Room.

Title: Activation of the Emergency Plan	No.: 10-S-01-1	Revision: 106	Page: 3
--	----------------	---------------	---------

- 2.2.2 Coordinating Operations activities outside of the Control Room with the TSC Coordinator.
- 2.2.3 Providing technical assistance to the Shift Superintendent.
- 2.3 Security Coordinator - Reports directly to the Emergency Director and is responsible for managing the Security Force during an emergency.
- 2.4 On-Call Manager - Is responsible for:
 - 2.4.1 Reporting to the site to assume the duties of Emergency Director upon notification of an Alert or higher classification.
 - 2.4.2 Assuming the duties of Emergency Director after The TSC is declared operational.
 - 2.4.3 Reporting to the site to assume duties of Emergency Director upon notification of an Unusual Event if he deems it necessary.
 - 2.4.4 Evaluating the accident conditions and verifying that the correct emergency classification has been made.

3.0 REFERENCES

- 3.1 NRC Memorandum dated July 11, 1994 concerning "Branch Position on Acceptable Deviations to Appendix 1 to NUREG-0654/FEMA-REP-1".
- 3.2 GGNS Emergency Plan

4.0 ATTACHMENTS

- 4.1 Attachment I - Emergency Classifications
- 4.2 Attachment II - Guidelines to Terminate Emergency
- 4.3 Deleted
- 4.4 Deleted

5.0 DEFINITIONS

- 5.1 Alert - An emergency classification in which events are in progress or have occurred that involve an actual or potential substantial degradation of the level of safety of the plant. Any releases are expected to be limited to small fractions of the Environmental Protection Agency (EPA) Protective Action Guideline exposure levels.
- 5.2 Assessment Action - Actions taken during or after an accident to obtain and process information necessary to make decisions to implement specific emergency measures.
- 5.3 CAS - Central Alarm Station
- 5.4 Downwind - An area located beyond a fixed point in the same direction the wind is blowing. The area covers three sectors, the sector containing the plume centerline, and the two adjacent sectors. If the plume is on a sector line, four sectors are used until the three sector criteria can be identified.

Title: Activation of the Emergency Plan	No.: 10-S-01-1	Revision: 106	Page: 4
--	----------------	---------------	---------

- 5.5 Emergency - A sudden, urgent, usually unforeseen occurrence or occasion requiring immediate action. It may result from accidental causes, natural causes, or malicious man-made actions. There are four classes of emergencies considered: Unusual Event, Alert, Site Area Emergency, and General Emergency.
- 5.6 Emergency Action Levels (EALs) - Radiological dose rates, specific contamination levels of airborne, waterborne, or surface-deposited concentrations of radioactive materials; or specific instrument indications (including their rates of change) that are used as thresholds for initiating such specific emergency measures as designated for a particular class of emergency, initiating a notification procedure, or initiating a particular protective action.
- 5.7 Emergency Classification - Emergency conditions (four classes) covering the entire spectrum of possible situations from minor, local incidents to hypothetical, major radiological emergencies. The four classes are listed in increasing order of severity: Unusual Event, Alert, Site Area Emergency and General Emergency.
- 5.8 Emergency Director - An individual designated onsite having the authority and responsibility to initiate the Emergency Plan and coordinate efforts to reduce the consequences of the event and bring it under control
- 5.9 Emergency Operations Facility (EOF) - A near-site emergency center from which the offsite emergency support activities are controlled
- 5.10 EPP - Emergency Plan Procedure
- 5.11 Emergency Planning Zone (EPZ) - Areas designated for which planning is provided to assure that prompt and effective action is initiated to protect the public in the event of an emergency
- 5.12 ESC - Energy Services Center
- 5.13 Exclusion Area - Area surrounding the plant, owned by the licensee, in which the licensee has the authority to determine all activities including exclusion or removal of personnel and/or property
- 5.14 General Emergency - An emergency classification in which events are in progress or have occurred which involve actual or imminent substantial core degradation or melting with potential for loss of containment integrity. Releases can be reasonably expected to exceed EPA Protective Action Guideline exposure levels offsite for more than the immediate site area.
- 5.15 ERDS - Emergency Response Data System
- 5.16 LOCA - Loss of Coolant Accident
- 5.17 OEC - Offsite Emergency Coordinator
- 5.18 Offsite - For accountability purposes, any area outside the GGNS protected area
- 5.19 OMT - Offsite Monitoring Team
- 5.20 Onsite - For accountability purposes, the area within the GGNS protected area

Title: Activation of the Emergency Plan	No.: 10-S-01-1	Revision: 106	Page: 5
--	----------------	---------------	---------

- 5.21 Operations Support Center (OSC) - Location from which onsite non-Control Room activities are staged and implemented
- 5.22 PA - Public Address System
- 5.23 PAG - Protective Action Guide
- 5.24 PAR - Protective Action Recommendation
- 5.25 Site Area Emergency - An emergency classification in which events are in progress or have occurred which involve major failures of plant functions needed for protection of the public. Any releases are not expected to exceed EPA Protective Action Guideline exposure levels except near the site boundary.
- 5.26 SAS - Secondary Alarm Station
- 5.27 TLD - Thermoluminescent Dosimeter
- 5.28 TSC - Technical Support Center
- 5.29 Unusual Event - An emergency classification in which events are in progress or have occurred which indicate a potential degradation of the level of safety of the plant. No releases of radioactive material requiring offsite response or monitoring are expected unless further degradation of safety systems occurs. (This is the same as the Notification of Unusual Event defined in NUREG-0654; the two expressions are used interchangeably in the E-Plan and related procedures as appropriate.)
- 5.30 ERDS - Emergency Response Data System. A near real-time data link from the GGNS Balance of Plant computer to the NRC Operations Center. This system monitors specific data and is activated by the GGNS Shift Superintendent no later than one hour after an ALERT (or higher) declaration.
- 5.31 CDE (Thyroid) (Committed Dose Equivalent) - The radiation dose to the adult thyroid gland due to radioiodines over a fifty year period following inhalation or ingestion.
- 5.32 TEDE (Total Effective Dose Equivalent) - Sum of the EDE and CEDE to nonpregnant adults from exposure and intake during an emergency situation.
- 5.33 Vital Areas- Areas within the Protected Area that house safety-related equipment. The failure or destruction of this equipment could directly or indirectly endanger the public health and safety by exposure to radiation. The following areas are considered Vital Areas: Auxiliary Building (including Containment), Control Building (including Control Room Complex), Diesel Generator Building, Inverter Room (166' elevation Turbine Building), SSW Pump and Valve rooms.
- 5.34 SSW Standby Service Water

Title: Activation of the Emergency Plan	No.: 10-S-01-1	Revision: 106	Page: 6
--	----------------	---------------	---------

6.0 DETAILS

6.1 Activation of Emergency Plan

6.1.1 Any person having knowledge of abnormal plant conditions should notify the Shift Supervisor/Superintendent.

6.1.2 The Shift Supervisor/Superintendent, when notified of abnormal plant conditions, should refer to Attachment I or EPP 01-02 (Flowchart) to determine if an emergency action level has been reached. If an emergency action level has been reached, the emergency plan shall be implemented.

NOTE

The Shift Supervisor/Superintendent is responsible for determining if the declaration of an emergency is required. If a declaration is required, he is responsible for activating the emergency plan.

6.1.3 Whenever there is doubt as to the classification of the emergency condition or if more than one EAL is reached, the more conservative classification should be used.

NOTE

When EALs are observed in conjunction with plant or equipment status due to planned maintenance or testing activities, an emergency condition may or may not exist and the situation must be evaluated on a case-by-case basis.

6.1.4 Once an emergency classification is declared, the following actions are taken by the Shift Superintendent/Emergency Director:

NOTE

After becoming aware that an emergency condition exists, the Shift Superintendent/Emergency Director's first priorities are:

- Take actions to ensure safety of plant personnel and general public.
- Take actions to ensure safe operation of plant.
- Other duties and responsibilities of the Emergency Director are contained in 10-S-01-30, Technical Support Center (TSC) Operations.

a. Initiate Emergency Director's Checklist (EPP Form 01-1).

Title: Activation of the Emergency Plan	No.: 10-S-01-1	Revision: 106	Page: 7
--	----------------	---------------	---------

- b. Announce to Control Room personnel that you are the Emergency Director.

NOTE

The NRC shall be notified of the declaration of the emergency IMMEDIATELY AFTER THE NOTIFICATION OF THE STATE AND LOCAL AGENCIES and not later than one hour after the emergency declaration.

- c. Designate an individual as communicator to perform the initial notification in accordance with 10-S-01-6. The Shift Superintendent shall ensure that the primary or secondary state and local agencies are notified within 15 minutes of an emergency declaration or reclassification.

NOTE

In the event of Security emergencies, each Security related incident should be evaluated. Only those support groups and facilities which are needed should be activated, regardless of the emergency classification, so as to minimize the risk to personnel. Utilization of the ERO call tree rather than VIP 2000 may be required to inform responders of emergency situation and prevent manning of unneeded facilities.

- d. Activate and verify activation of the VIP 2000 per 10-S-01-6.
- e. Activate ERDS within one hour of an Alert or higher declaration Per 10-S-01-6.
- f. Announce nature and classification of event:

NOTE

For security emergencies, inform all personnel to take shelter, to NOT move around in the plant, and to man only those emergency facilities which are necessary and that don't pose a risk to personnel.

- (1) Over Plant PA System or phone #6426.
- (2) Over Site Paging (#7929).
- g. If an evacuation of affected areas of the plant is required, perform in accordance with 10-S-01-11.

Title: Activation of the Emergency Plan	No.: 10-S-01-1	Revision: 106	Page: 8
--	----------------	---------------	---------

- h. Implement plant operating procedures and emergency plan procedures as required to perform emergency corrective and assessment actions.
- i. Activate emergency facilities as follows:
 - (1) If Unusual Event has been declared, no activation of facilities is required unless the Emergency Director feels there is a reasonable possibility of escalation of emergency to a higher classification.
 - (2) If an Alert has been declared, the TSC, OSC, ENMC and EIC must be activated.
 - (3) If a Site Area or General Emergency has been declared, all emergency facilities must be activated and a Site Evacuation should be seriously considered.
- j. If an Alert, Site Area Emergency, or General Emergency has been declared, determine offsite doses in accordance with 10-S-01-12.
 - (1) Protective actions shall be recommended to State and Local Agencies upon declaration of a General Emergency as follows:

Condition	Protective Action Recommendation
General Emergency Declared	EVACUATE: 2 Miles All Sectors <u>and</u> EVACUATE: 5 Miles in Downwind Sectors <u>and</u> SHELTER: Remainder of 10 Mile Emergency Planning Zone (EPZ)
General Emergency Declared <u>and</u> Dose Projection or Field Measurement at ≥ 5 miles corresponds to 1 Rem TEDE <u>or</u> 5 Rem Thyroid.CDE	EVACUATE: 2 Miles All Sectors <u>and</u> EVACUATE: 10 Miles in Downwind Sectors <u>and</u> SHELTER: Remainder of 10 Mile Emergency Planning Zone (EPZ)

Title: Activation of the Emergency Plan	No.: 10-S-01-1	Revision: 106	Page: 9
--	----------------	---------------	---------

- k. Designate shift personnel to perform emergency corrective and assessment actions.

6.2 Supplemental Actions

- 6.2.1 Continuous assessment is necessary to effectively coordinate and direct emergency response. In any emergency situation, attention must be paid to parameters that may indicate a possible worsening of conditions (i.e., radioactive releases).
- a. If an Alert condition is declared, the following assessment actions are required:
- (1) Increased surveillance of applicable in-plant instrumentation.
 - (2) Visual observation of affected plant area.
 - (3) Onsite and offsite radiological monitoring if a release has taken place or is suspected.
 - (4) Determination of offsite doses if applicable.
- b. In addition to the above, a Site Area Emergency or General Emergency would require these additional assessment actions.
- (1) Monitor meteorological data.
 - (2) Dispatch offsite radiological monitoring teams down wind of the release in conjunction with state radiological monitoring efforts.
 - (3) Assess onsite and offsite radiation doses. (TEDE and Thyroid CDE).
- 6.2.2 Emergency Director should ensure that periodic announcements are made over the plant PA and site PA (#7929) concerning:
- a. Nature and location of event.
 - b. Required personnel actions.
 - c. Any other information necessary.
- 6.2.3 The Emergency Director (while in the Control Room) logs all information in the Shift Superintendent/Control Room Operator Log as necessary for event reconstruction.
- 6.2.4 The Emergency Director (while in the TSC) may delegate to the TSC Coordinator and/or Radiation Protection Manager the responsibility for logging all information relative to the emergency (for event reconstruction).
- 6.2.5 The Offsite Emergency Coordinator may delegate to the Offsite Emergency Coordinator Technical Assistant the responsibility for logging all information relative to the emergency (for event reconstruction).

Title: Activation of the Emergency Plan	No.: 10-S-01-1	Revision: 106	Page: 10
--	----------------	---------------	----------

6.2.6 Upon activation of the EOF, the following activities must be transferred to the OEC:

- a. Notifications to offsite agencies
- b. Offsite radiological and environmental surveys
- c. Protective action recommendations to offsite agencies
- d. Classification of the emergency

6.2.7 If extended emergency operations are necessary, the Emergency Director/Offsite Emergency Coordinator should authorize preparation of an emergency organization shift schedule to support 24-hour emergency operation.

6.3 Upgrading Emergency Classifications

6.3.1 If conditions worsen, refer to Attachment I or EPP 01-02 (Flowchart) to determine if the emergency classification requires upgrading. If the classification is upgraded, ensure the following steps are taken:

- a. Declare appropriate emergency classification in accordance with Step 6.1.2.
- b. Announce nature and classification of event in accordance with Step 6.1.4.f.
- c. If an evacuation is required, notify Security if possible and evacuate affected areas in accordance with Step 6.1.4g.
- d. Initiate plant operating procedures and emergency plan procedures as required.
- e. Activate additional emergency facilities as necessary in accordance with Step 6.1.4i.
- f. Determine offsite doses in accordance with Step 6.1.4j.
- g. Conduct additional assessment actions as necessary in accordance with Step 6.2.

6.4 Terminating Emergency

6.4.1 Terminating

If EALs are no longer met or exceeded, the Emergency Director/Offsite Emergency Coordinator refers to Attachment II to determine whether or not to terminate emergency.

6.4.2 Reentry and Recovery

Once the corrective and protective actions taken have established effective control over the situation, the Emergency Director may refer to 10-S-01-22 to determine if reentry and recovery actions may be initiated. If the reentry/recovery criteria are met, the Emergency Director may advise the Offsite Emergency Coordinator that reentry/recovery may start.

Title: Activation of the Emergency Plan	No.: 10-S-01-1	Revision: 106	Page: 11
--	----------------	---------------	----------

6.5 Records and Reports

6.5.1 The Manager, Emergency Preparedness is responsible for generating a report on the activation of the Emergency Plan. The report should include the following:

- a. Copies of appropriate paperwork generated by the event including: notification forms, checklists, logbooks, survey maps, dose calculations etc.
- b. Observations and comments from the personnel involved in the event.

6.5.2 The Manager, Emergency Preparedness is responsible for ensuring that all observations and comments are tracked in Emergency Preparedness Action Tracking System, in accordance with 01-S-10-3.

10-S-01-1	Revision 106
Attachment I	Page 1 of 25

EMERGENCY CLASSIFICATIONS
TABLE OF CONTENTS

<u>CATEGORY</u>	<u>PAGE</u>
1. Safety System Functions	2,3
2. Abnormal Primary Leak Rate/Low Reactor Water Level	4
3. Core Fuel Damage	5,6,7,8
4. Steam Leaks	8
5. Abnormal Effluent, Gaseous	9,10,11
6. Abnormal Effluent, Liquid	11
7. Major Electrical Failures, AC	12,13
8. Major Electrical Failures, DC	13
9. Control Room Evacuation	14
10. Fire	14
11. Plant Shutdown Function	15,16
12. Abnormal In-plant Radiation/Airborne Contamination Levels	17
13. Fuel Handling Accident	17,18
14. Security Threat	19
15. Hazards to Plant Operations	20,21,22
16. Natural Events	23
17. Loss of Assessment, Communication, Annunciator Equipment	24
18. Discretionary	24,25

NOTE

Any changes made to information in Attachment I may require changes to EPP 01-02 (Flowchart).

10-S-01-1	Revision 106
Attachment I	Page 2 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
1. Safety System Functions	1. Inability to reach required shutdown within Technical Specification time limits	Failure to reach the required Plant Mode within Technical Specification action statement time frames for any of the following LCO's: 1. Safety/relief Valves 3.4.4 <u>or</u> 2. ECCS - Operating 3.5.1 <u>or</u> 3. Primary Containment 3.6.1.1 <u>or</u> 4. Primary Containment Airlocks 3.6.1.2 <u>or</u> 5. Primary Containment Isolation Valves 3.6.1.3 <u>or</u> 6. Low Low Set Valves 3.6.1.6 <u>or</u> 7. Residual Heat Removal Containment Spray 3.6.1.7 <u>or</u> 8. Suppression Pool Average Temperature 3.6.2.1 <u>or</u> 9. Suppression Pool Level 3.6.2.2 (Continued)	UNUSUAL EVENT

10-S-01-1	Revision 106
Attachment I	Page 3 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
1. Safety System Functions (Cont.)		<u>or</u> 10. Suppression Pool Makeup System 3.6.2.4 <u>or</u> 11. Second Containment 3.6.4.1 <u>or</u> 12. Second Containment Isolation Valve 3.6.4.2 <u>or</u> 13. Standby Gas Treatment System 3.6.4.3 <u>or</u> 14. Drywell 3.6.5.1 <u>or</u> 15. Drywell Airlocks 3.6.5.2 <u>or</u> 16. Drywell Isolation Valves 3.6.5.3	UNUSUAL EVENT
	2. Failure of a safety/relief valve to close following reduction of applicable pressure to below reset point	1. Shift Superintendent determines a SRV is stuck open in plant Mode 1, 2, or 3.	

ECCS - Emergency Core Cooling System

10-S-01-1	Revision 106
Attachment I	Page 4 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
2. Abnormal Primary Leak Rate/ Low Reactor Water Level	1. Exceeding primary coolant system leak rate	While in modes 1,2, or 3: 1. > 5 gpm unidentified leakage <u>or</u> 2. > 30 gpm total leakage Averages over previous 24 hr period	UNUSUAL EVENT
	2. Coolant leak rate > 50 gpm	1. Total leakage calculated to be > 50 gpm while in Plant Mode 1, 2 or 3	ALERT
	3. Known loss of coolant greater than makeup pump capacity	1. RPV water level < -167 inch <u>and</u> 2. Makeup capacity unable to increase reactor water level	SITE AREA EMERGENCY

10-S-01-1	Revision 106
Attachment I	Page 5 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
3. Core Fuel Damage	1. Fuel damage indication	1. Increase of 285 mR/hr in 30 minutes on OFFGAS pretreatment monitor <u>or</u> 2. OFFGAS pretreatment monitor reading > 1,400 mR/Hr <u>or</u> 3. Laboratory analysis of coolant sample indicates > 0.2 $\mu\text{Ci/ml}$ dose equivalent I-131 for more than 48 hours <u>or</u> 4. Laboratory analysis of coolant sample indicates > 4.0 $\mu\text{Ci/ml}$ dose equivalent I-131	UNUSUAL EVENT
	2. Severe loss of fuel cladding	1. OffGAS pretreatment monitor reading > 14,000 mR/HR <u>or</u> 2. Coolant sample analysis indicates >300 $\mu\text{Ci/ml}$ dose equivalent I-131 <u>or</u> 3. Main steam line radiation exceeds radiation monitor trip setpoint	ALERT

 μCi - Micro Curies

10-S-01-1	Revision 106
Attachment I	Page 6 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
3. Core Fuel Damage (Cont.)	3. Degraded core with possible loss of coolant	1. RPV water level < -167" or cannot be determined <u>and</u> 2. a. High coolant activity indicated by analysis of sample > 300 μ Ci/ml dose equivalent I-131 <u>or</u> b. Containment or Dry-well hydrogen concentration greater than 0.5%	SITE AREA EMERGENCY

μ Ci - micro Curies

10-S-01-1	Revision 106
Attachment I	Page 7 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
3. Core Fuel Damage (Cont.)	4. Loss of 2 of 3 fission product barriers with a potential loss of 3rd barrier	1. Loss of any two of the following fission product boundaries with a potential for loss of the third: <u>Fuel Cladding Loss</u> a. Coolant sample analysis indicates >300 $\mu\text{Ci/ml}$ dose equivalent I-131 <u>or</u> b. >1000 R/Hr in Drywell <u>Potential Loss</u> a. RPV water level cannot be restored and maintained > -167 in. <u>or</u> b. RPV pressure cannot be restored and maintained > 57 psig when in RPV flooding. <u>or</u> c. >100 R/Hr in Drywell <u>Reactor Pressure Boundary Loss</u> a. Drywell pressure >1.23 psig <u>and</u> indication of a steam leak in the drywell <u>or</u> b. Main steam line not isolated <u>or</u> c. RCIC steam line break outside containment with inability to isolate <u>Potential Loss</u> a. Total reactor coolant leakage calculated to be >50 gpm <u>or</u> b. >10 R/hr in Containment	GENERAL EMERGENCY

 μCi - Micro Curies

10-S-01-1	Revision 106
Attachment I	Page 8 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
3. Core Fuel Damage (Cont.)	4. Loss of 2 of 3 fission Product Barriers with a Potential loss of 3rd barrier. (Cont.)	<u>Primary Containment Loss</u> a. Primary Containment pressure >56 psig <u>or</u> b. Loss of ability to isolate Drywell or primary containment Leakage into Areas Outside the Primary Containment <u>Potential Loss</u> a. Primary containment pressure >22 psig <u>or</u> b. Operation in the Unsafe Region of HCTL <u>or</u> PSP Curve. <u>or</u> c. Operation in the Unsafe Region of HDOL Curve with Hydrogen Igniters De-Energized	GENERAL EMERGENCY
4. Steam Leaks	1. Main steam line break outside the containment with significant MSIV leakage.	1. Isolation initiated and abnormal leakage down stream of MSIVs (> 10 gpm or 5000 lbm/hr)	ALERT
	2. RCIC steam line break outside the containment with significant isolation valve leakage	1. Isolation initiated and abnormal leakage down stream of isolation valves (> 10 gpm or 5000 lbm/hr)	
	3. Main steam line break outside of containment which cannot be isolated.	1. Isolation required due to confirmed steam line break <u>and</u> One or more main steam lines fail to isolate	SITE AREA EMERGENCY
	4. RCIC steam line break outside of containment which cannot be isolated.	1. Isolation required due to confirmed steam line break <u>and</u> RCIC steam line fails to isolate	

MSIV - Main Steam Isolation Valve PSP - Pressure Suppression limit
RCIC - Reactor Core Isolation Cooling
HCTL - Heat Capacity Temperature Limit
HDOL - Hydrogen Deflagration Overpressure Limit

10-S-01-1	Revision 106
Attachment I	Page 9 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
5. Abnormal Effluent, GASEOUS	1. Radiological effluent release rate exceeds TRM Spec limit	1. Entering the action statement of the following LCOs in the Radioactive Gaseous Effluent section of the TRM Specs 6.11.4, 6.11.5, and 6.11.6	UNUSUAL EVENT
	2. Radiological effluent >10 times TRM Spec limit	1. High high radiation alarms on <u>ONE OR MORE monitors</u> : a. Radwaste Bldg vent exhaust b. Fuel handling vent exhaust c. Containment vent exhaust d. Turbine Bldg vent exhaust <u>and</u> Summation of monitors (including SGTS A and B) exceeds 10 times TRM Spec limit (6.11.4)	ALERT

LCO - Limited Condition for Operation

SGTS - Standby Gas Treatment System

TRM - Technical Requirements Manual

10-S-01-1	Revision 106
Attachment I	Page 10 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
5. Abnormal Effluent, GASEOUS (Cont.)	3. Effluent monitors detect levels corresponding to site boundary exposure of: a. ≥ 50 mR/Hr (for 30 minutes) Whole Body <u>or</u> b. ≥ 500 mR/Hr (for 2 minutes) Whole Body <u>or</u> c. ≥ 250 mR/hr (for 30 min) to the Thyroid.	1. Any post accident effluent radiation monitor confirm release rates corresponding to: a. 0.5 Ci/sec Noble Gas for 30 minutes <u>or</u> b. 6.0 E-4 Ci/sec Iodine for 30 minutes <u>or</u> c. 5.0 Ci/sec Noble Gas for 2 minutes <u>or</u> d. 6.0 E-3 Ci/sec Iodine for 2 minutes <u>or</u>	SITE AREA EMERGENCY
	<u>NOTE</u> "Adverse Meteorology" -Stability Class F, wind speed 1 m/sec, site boundary X/Q 1080 E-6 sec/m^3 (FSAR Table 15 6-12)	2. Radiation monitoring teams report radiation and/or Iodine concentration readings at the site boundary corresponding to: a. 50 mR/Hr for 30 minutes <u>or</u> b. 500 mR/Hr for 2 minutes <u>or</u> c. 6.0E-6 $\mu\text{Ci/cc}$ Iodine <u>or</u>	
		3. Containment Post Accident Radiation Monitor: a. >330 R/HR for 30 minutes <u>or</u> b. >3300 R/HR for 2 minutes	

FSAR - Final Safety Analysis Report

 μCi - micro Curies

Ci - Curies

10-S-01-1	Revision 106
Attachment I	Page 11 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
5. Abnormal Effluent, GASEOUS (Cont.)	4. Effluent monitor(s) (UNDER ACTUAL METEOROLOGICAL CONDITIONS) detect levels corresponding to site boundary exposure of: 1000 mRem Dose Commitment Whole Body <u>or</u> 5000 mRem Dose Commitment Thyroid	1. Effluent monitor(s) (UNDER ACTUAL METEOROLOGICAL CONDITIONS) confirms release rates corresponding to site boundary exposure of: a. 1000 mRem TEDE <u>or</u> b. 5000 mRem Thyroid CDE <u>or</u> 2. Radiation monitoring teams report radiation and/or iodine concentrations readings (at the site boundary) corresponding to: a. 1000 mRem TEDE <u>or</u> b. $1.2E-5 \mu\text{Ci/cc}$ Iodine	GENERAL EMERGENCY
6. Abnormal Effluent, LIQUID	1. Radiological Effluent Release Rate exceeds TRM Spec limit	1. Entering the action statement of TRM Spec 6.11.1, in the Radioactive Liquid Effluent section of TRM Spec	UNUSUAL EVENT
	2. Radiological Effluent >10 times TRM Spec limit	1. Liquid release > 10 times the limit of TRM Spec 6.11.1 in the Radioactive Liquid Effluent section of TRM Spec	ALERT

TEDE - Total Effective Dose Equivalent

CDE - Committed Dose Equivalent

TRM - Technical Requirements Manual

10-S-01-1	Revision 106
Attachment I	Page 12 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
7. Major Electrical Failures (AC)	1. Total loss of offsite power <u>or</u> Loss of onsite AC power capability	1. Loss of offsite power to: a. 15AA <u>and</u> b. 16AB <u>and</u> c. 17AC <u>or</u> 2. Loss of <u>ALL</u> three divisional diesel generators while in Plant Operational Condition 1, 2 or 3	UNUSUAL EVENT
	2. Total loss of offsite power <u>and</u> Loss of ALL onsite power $\leq$ 15 minutes	1. Loss of offsite power to: a. 15AA <u>and</u> b. 16AB <u>and</u> c. 17AC <u>and</u> 2. Loss of all three divisional diesel generators <u>and</u> 3. $\leq$ 15 minutes	ALERT

10-S-01-1	Revision 106
Attachment I	Page 13 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
7. Major Electrical Failures (AC) (Cont.)	3. Total loss of offsite power and Loss of ALL onsite power >15 minutes	1. Loss of offsite power to: a. 15AA <u>and</u> b. 16AB <u>and</u> c. 17AC <u>and</u> 2. Loss of all three divisional diesel generators <u>and</u> 3. >15 minutes	SITE AREA EMERGENCY
8. Major Electrical Failures (DC)	1. Loss of onsite ESF DC power for ≤ 15 minutes	1. Loss of Division 1, 2 and 3 (125 Vdc for ≤15 minutes)	ALERT
	2. Loss of onsite ESF DC power for > 15 minutes	1. Loss of Division 1, 2 and 3 (125 Vdc for >15 MINUTES)	SITE AREA EMERGENCY

10-S-01-1	Revision 106
Attachment I	Page 14 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
9. Control Room Evacuation	1. Evacuation of the Control Room <u>and</u> Control established at the remote shutdown panel	1. Control Room evacuated <u>and</u> 2. Control of shutdown systems established at the remote shutdown panel	ALERT
	2. Evacuation of the Control Room <u>and</u> Control not established at the remote shutdown panel within 15 minutes	1. Control Room evacuated <u>and</u> 2. Unable to establish control of shutdown systems at the remote shutdown panel <u>within</u> 15 minutes of evacuating the Control Room	SITE AREA EMERGENCY
10. Fire	1. Fire lasting > 10 minutes after discovery	1. A fire within the power block, fire water pump house or CO ₂ skid lasting >10 minutes from the time of notification	UNUSUAL EVENT
	2. Fire potentially affects safety systems	1. A fire defeating <u>ONE</u> safety system electrical division	ALERT
	3. Fire compromising the functions of ESF Systems	1. A fire defeating <u>MORE THAN ONE</u> safety system electrical division	SITE AREA EMERGENCY

10-S-01-1	Revision 106
Attachment I	Page 15 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
11. Plant Shutdown Function	1. Complete loss of functions needed for plant <u>COLD</u> shutdown.	1. All control rods fully inserted <u>and</u> 2. The determination that there are no longer enough systems functional to attain or maintain the reactor coolant <200°F	ALERT
	2. Failure of the Reactor Protection System to initiate and complete a scram which brings the reactor subcritical	1. Scram conditions confirmed <u>and</u> 2a. More than one rod is greater than position 02 <u>or</u> rod position is unknown for more than one rod <u>and</u> 2b. SRM's are either upscale or countrate is increasing (Assuming SRMs are full in) <u>and</u> 3. Reactor power <4% on APRM (APRM Downscale light on)	

APRM - Average Power Range Monitor

10-S-01-1	Revision 106
Attachment I	Page 16 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
11. Plant Shutdown Function (Cont.)	3. Complete loss of functions needed for plant <u>HOT</u> shutdown	1. HPCS and RCIC not functional <u>and</u> 2. Not able to depressurize with SRVs <u>and</u> 3. Main Condenser is not available	SITE AREA EMERGENCY
	4. Transient requiring operation of shutdown systems with failure to scram and continued power generation	1. Scram conditions confirmed <u>and</u> 2. All control rods NOT <u>inserted</u> to between 00 and 02 <u>and</u> 3. Reactor power $\geq 4\%$ on APRM	

10-S-01-1	Revision 106
Attachment I	Page 17 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
12. Abnormal In-plant Radiation/ Airborne Contamination Levels	1. Radiation levels or airborne contamination indicate a severe degradation in the control of radioactive materials	1. Verification of area radiation monitor reading > 1000 times setpoint or Verification of CAM reading > 1000 times setpoint	ALERT
13. Fuel Handling Accident	1. Fuel damage accident with release of radioactivity to Containment or Auxiliary Building	1. Notification of a spent fuel damaging accident <u>and</u> 2. High high radiation alarms on either a. Fuel handling vent exhaust <u>or</u> b. Containment vent exhaust	ALERT
	2. Major damage to spent fuel assembly in Containment or Auxiliary Building	1.a. Notification of a spent fuel damaging accident <u>or</u> b. Low water level in spent fuel pool below top of spent fuel <u>and</u> unable to restore level to above fuel. <u>and</u> (Continued)	SITE AREA EMERGENCY

CAM - Continuous Air Monitor

10-S-01-1	Revision 106
Attachment I	Page 18 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
13. Fuel Handling Accident (Cont.)		2. Any post accident effluent radiation monitor confirms Noble Gas, Iodine release rates corresponding to: a. 0.5 Ci/sec Noble Gas (30 minutes) <u>or</u> b. 6.0 E-4 Ci/sec Iodine (30 minutes) <u>or</u> c. 5.0 Ci/sec Noble Gas (2 minutes) <u>or</u> d. 6.0 E-3 Ci/sec Iodine (2 minutes) <u>or</u> 3. Radiation monitoring teams report Radiation and/or Iodine concentration readings at the site boundary corresponding to: a. 50 mR/Hr (for 30 minutes) <u>or</u> b. 500 mR/Hr (for 2 minutes) <u>or</u> c. 6.0 E-6 μCi/cc Iodine	SITE AREA EMERGENCY

Ci - Curies

 μ Ci - Micro Curies

10-S-01-1	Revision 106
Attachment I	Page 19 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
14. Security Threat	1. Security threat <u>Or</u> Attempted entry sabotage	1. Based upon the assessment of the alarm or the event reported by Security. Actual threat must be determined prior to establishing an emergency classification.	UNUSUAL EVENT
	2. On-going Security compromise	1. Identification of adversaries attempting to command areas of the plant, but not controlling shutdown capability or vital areas.	ALERT
	3. Imminent loss of physical control of the plant.	1. Physical attack on the plant involving imminent occupancy of the Control Room, Remote Shutdown Panel or Vital areas.	SITE AREA EMERGENCY
	4. Loss of physical control of the plant.	1. Physical attack on the plant has resulted in unauthorized personnel occupying the Control Room or the Remote Shutdown Panel or controlling Decay Heat Removal, Reactor water Level or reactivity Control capability.	GENERAL EMERGENCY

10-S-01-1	Revision 106
Attachment I	Page 20 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
15. Hazards to Plant Operations	1. Hazards being experienced or projected with the <u>potential for degradation</u> of the level of safety of the plant	1. Notification of an aircraft crash onsite outside the protected area <u>or</u> 2. Notification of unusual aircraft activity over the facility <u>or</u> 3. Notification of an onsite explosion (does not affect plant operation) <u>or</u> 4. Determination that a release of toxic, oxygen displacing, or flammable gas will significantly hamper the ability of personnel to perform activities affecting plant safety <u>or</u> 5. A manual or automatic scram initiated because of a turbine blade failure that has not penetrated the casing	UNUSUAL EVENT

10-S-01-1	Revision 106
Attachment I	Page 21 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
15. Hazards to Plant Operations (Cont.)	2. Hazards being experienced or projected with <u>actual or potential</u> substantial degradation of the level of safety of the plant	1. Notification of an air-craft crash onsite inside the protected area, no damage to plant vital areas <u>or</u> 2. Notification of missile impacts on plant non-vital structures <u>or</u> 3. Notification of an onsite explosion affecting plant operation <u>or</u> 4. Determination that the entry of toxic or flammable gases into facility structures has threatened to render Safety Related equipment Inoperable <u>or</u> 5. Notification of a turbine failure that has resulted in casing penetration	ALERT

10-S-01-1	Revision 106
Attachment I	Page 22 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
15. Hazards to Plant Operations	3. Hazards being experienced or projected with the functions needed for protection of the public	1. Notification of an aircraft crash into plant vital areas <u>or</u> 2. Notification of severe damage to safe shutdown equipment from missiles or explosion <u>or</u> 3. Determination that the entry of toxic or flammable gases into vital areas	SITE AREA EMERGENCY

10-S-01-1	Revision 106
Attachment I	Page 23 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
16. Natural Events	1. Natural events being experienced or projected beyond usual levels	1. A verified earthquake detected by in-plant seismic instrumentation <u>or</u> 2. A tornado observed onsite <u>or</u> 3. A hurricane warning issued that includes the site area	UNUSUAL EVENT
	2. Severe natural event near site being experienced or projected	1. A verified earthquake detected by in-plant seismic instrumentation $\geq$ OBE levels <u>or</u> 2. A tornado causing damage to Safety Related structures <u>or</u> 3. Sustained winds $\geq$ 73 mph onsite	ALERT
	3. Severe natural event near site being experienced or projected with plant in Modes 1, 2, or 3	1. A verified earthquake detected by in-plant seismic instrumentation $\geq$ SSE levels <u>or</u> 2. Sustained winds $\geq$ 90 mph onsite	SITE AREA EMERGENCY
	4. Major internal <u>or</u> external events	1. Fires, earthquakes, etc., substantially beyond design basis which could or have caused massive common damage to plant systems	GENERAL EMERGENCY

OBE - Operating Earthquake

SSE - Safe Shutdown Earthquake

10-S-01-1	Revision 106
Attachment I	Page 24 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
17. Loss of assessment, communications, annunciators equipment	1. Significant loss of vital accident assessment or communications capability	1. Total loss of vital accident assessment equipment such as: a. All vessel level instruments <u>or</u> , b. All containment monitoring instruments, etc. or 2. Degradation of the offsite communication system to only one source	UNUSUAL EVENT
	2. Loss of ALL annunciators	1. Loss of <u>ALL</u> annunciators on the P680, P601, and P870 panels	ALERT
18. Discretionary	1. Other plant conditions exist that warrant increased awareness on the part of the plant operating staff. <u>AND/OR</u> State and Local Authorities	1. Plant conditions exist that warrant a precautionary notification to local and state authorities.	UNUSUAL EVENT
	2. Other plant conditions warrant activation of TSC	1. Plant conditions exist that warrant precautionary activation of the TSC and placing the EOF and key plant personnel on standby.	ALERT

TSC - Technical Support Center
EOF - Emergency Operations Facility

10-S-01-1	Revision 106
Attachment I	Page 25 of 25

EMERGENCY CLASSIFICATIONS

CATEGORY	INITIATING CONDITION	EMERGENCY ACTION LEVEL	EMERGENCY CLASSIFICATION
18. Discretionary	3. Other plant conditions exist that warrant activation of Emergency Facilities	1. Plant conditions exist that warrant: a. The activation of the EOF <u>or</u> b. A precautionary notification to the public near the site	SITE AREA EMERGENCY
	4. Other plant conditions exist that make <u>release of large amounts of radioactivity</u> in a short time possible	1. Plant conditions exist that make the release of large amounts of radioactivity in a short period of time likely. (Not limited to the following examples): Core damage is predicted to occur (within 2 hours) <u>and</u> Containment pressure is > 22 psig or containment is breached	GENERAL EMERGENCY

10-S-01-1	Revision 106
Attachment II	Page 1 of 2

GUIDELINES TO TERMINATE EMERGENCY

PURPOSE: To establish general guidelines to be followed should changing plant conditions warrant termination of an emergency classification.

NOTE

The Emergency Director/Offsite Emergency Coordinator must discuss existing offsite conditions with appropriated State officials prior to terminating an emergency.

I. Termination Guidelines

A. General

1. Conditions which caused the event have been terminated.
2. Circumstances which have arisen from the event are under control and the results of any and all pertinent data are evaluated.
3. All probability of recurrence of an event is removed, isolated or under control.

B. Specific Examples

CATEGORY	TERMINATION GUIDELINES
Fires	Removal/separation of any element of fire triangle. Fire under control/not spreading.
Spill	Tanks, pipes, valves, any other problem sources are empty, isolated, and out of service.
Airborne	Source identified and isolated and/or contained. Area controlled.
Explosion	Existing and potential hazards removed, destroyed and/or isolated.
Abnormal Effluent	Liquid discharge is terminated, sampling is completed, and statistics verified. Public exposure to Offsite radioactive material is reduced or eliminated. Airborne - Source identified and analysis complete. Release is terminated and its cause is under control. All Onsite and Offsite monitoring data is evaluated. Public exposure to Offsite radioactive material is reduced or eliminated.

10-S-01-1	Revision 106
Attachment II	Page 2 of 2

GUIDELINES TO TERMINATE OF THE EMERGENCY

B. Specific Examples (Cont.)

CATEGORY	TERMINATION GUIDELINES
Control Room Evacuation	Plant in normal emergency shutdown from remote stations. Cause of evacuation identified and under control. No radiological conditions exist which cause the Control Room to become uninhabitable.
Plant Shutdown Functions (not available or failed)	Unit is shut down by normal or emergency means. Unit is in cold shutdown and there is no potential for uncontrolled criticality.
Fuel Handling Accident - New or Spent Fuel Damage, Channeled or Unchanneled	Fuel elements, segments, pellets not in a critical configuration. Airborne activity has been evaluated and accountability of components complete.
Water Loss - LOCA Abnormal Primary Coolant Leak	Source of water loss is defined. Ability to restore or maintain water level adequate for proper cooling.
Earthquake or Other Natural Disaster	The plant has been returned to a safe condition. Threat of aftershock has passed and any damage has been evaluated as to risk, if any.
Security Threat	Threat to site is terminated. Probability of recurrence has been removed, with the concurrence of Security Supervisor and State, Local and Federal Officials.

**THIS PAGE IS AN
OVERSIZED DRAWING
OR FIGURE,**

**THAT CAN BE VIEWED AT
THE RECORD TITLED:**

NUMBER 10-S-01-1

PAGE 1 OF 2

**EMERGENCY CLASSIFICATION
FLOWCHART**

**WITHIN THIS PACKAGE...OR,
BY SEARCHING USING THE
DOCUMENT/REPORT**

NUMBER: 10-S-01-1

PAGE 1 OF 2

NOTE: Because of this page's large file size, it may be more convenient to copy the file to a local drive and use the Imaging (Wang) viewer, which can be accessed from the Programs/Accessories menu.

D-1

**THIS PAGE IS AN
OVERSIZED DRAWING
OR FIGURE,**

**THAT CAN BE VIEWED AT
THE RECORD TITLED:
NUMBER 10-S-01-1
PAGE 2 OF 2
EMERGENCY CLASSIFICATION
FLOWCHART
WITHIN THIS PACKAGE...OR,
BY SEARCHING USING THE
DOCUMENT/REPORT
NUMBER: 10-S-01-1
PAGE 2 OF 2**

NOTE: Because of this page's large file size, it may be more convenient to copy the file to a local drive and use the Imaging (Wang) viewer, which can be accessed from the Programs/Accessories menu.

D-2