



Entergy

Entergy Operations, Inc.
1448 S.R. 333
Russellville, AR 72802
Tel 501 858 5000

July 13, 2000

OCAN070004


U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Station OP1-17
Washington, DC 20555

Subject: Arkansas Nuclear One - Units 1 and 2
Docket Nos. 50-313 and 50-368
License Nos. DPR-51 and NPF-6
Monthly Operating Report

Gentlemen:

Arkansas Nuclear One (ANO), Units 1 and 2 Technical Specifications 6.12.2.3 and 6.9.1.6, respectively, require the submittal of a Monthly Operating Report. The purpose of this letter is to complete the reporting requirement for June 2000.

Very truly yours,


Jimmy D. Vandergrift
Director, Nuclear Safety Assurance

JDV/SLP
Attachment

IF24

cc: Mr. Ellis W. Merschoff
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

NRC Senior Resident Inspector
Arkansas Nuclear One
P.O. Box 310
London, AR 72847

Mr. M. Christopher Nolan
NRR Project Manager Region IV/ANO-1
U. S. Nuclear Regulatory Commission
NRR Mail Stop 04-D-03
One White Flint North
11555 Rockville Pike
Rockville, MD 20852

Mr. Thomas Alexion
NRR Project Manager Region IV/ANO-2
U. S. Nuclear Regulatory Commission
NRR Mail Stop 04-D-03
One White Flint North
11555 Rockville Pike
Rockville, MD 20852

OPERATING DATA REPORT

DOCKET NO. 50-313
UNIT NAME Arkansas Nuclear One - Unit 1
DATE July 15, 2000
COMPLETED BY Steven L. Coffman
TELEPHONE (501) 858-5560

REPORTING PERIOD: June 2000

1. **Design Electrical Rating (MWe-Net):** 850
 2. **Maximum Dependable Capacity (MWe-Net):** 836

	<u>MONTH</u>	<u>YR-TO-DATE</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical	720.0	3,345.3	171,988.6
4. Number of Hours Generator On-Line	720.0	3,308.0	169,401.8
5. Unit Reserve Shutdown Hours	0.0	0.0	817.5
6. Net Electrical Energy Generated (MWh)	606,417	2,655,596	128,621,699

UNIT SHUTDOWNS

<u>No.</u>	<u>Date</u>	<u>Type</u> F: Forced S: Scheduled	<u>Duration</u> (Hours)	<u>Reason</u> ¹	<u>Method of</u> <u>Shutting</u> <u>Down</u> ²	<u>Cause & Corrective Action</u> <u>Comments</u>
None						

SUMMARY: The Unit began the month at full power. On 06/07/00, power was reduced to ~78% to clean a condenser water box and perform turbine governor valve testing. The Unit was returned to full power on 06/08/00 and operated at full power for the remainder of the month.

1

Reason:

- A Equipment Failure (Explain)
- B Maintenance or Test
- C Refueling
- D Regulatory Restriction
- E Operator Training & License Examination
- F Administration
- G Operational Error (Explain)
- H Other (Explain)

2

Method:

- 1 Manual
- 2 Manual Trip/Scram.
- 3 Automatic Trip/Scram.
- 4 Continuation
- 5 Other (Explain)

OPERATING DATA REPORT

DOCKET NO. 50-368
UNIT NAME Arkansas Nuclear One - Unit 2
DATE July 15, 2000
COMPLETED BY Steven L. Coffman
TELEPHONE (501) 858-5560

REPORTING PERIOD: June 2000

1. **Design Electrical Rating (MWe-Net):** 912
 2. **Maximum Dependable Capacity (MWe-Net):** 858

	<u>MONTH</u>	<u>YR-TO-DATE</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical	<u>720.0</u>	<u>4,367.0</u>	<u>143,213.8</u>
4. Number of Hours Generator On-Line	<u>720.0</u>	<u>4,367.0</u>	<u>140,925.2</u>
5. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
6. Net Electrical Energy Generated (MWh)	<u>630,085</u>	<u>3,842,791</u>	<u>118,848,530</u>

UNIT SHUTDOWNS

<u>No.</u>	<u>Date</u>	<u>Type</u> F: Forced S: Scheduled	<u>Duration</u> (Hours)	<u>Reason</u> ¹	<u>Method of</u> <u>Shutting</u> <u>Down</u> ²	<u>Cause & Corrective Action</u> <u>Comments</u>
None						

SUMMARY: The Unit began the month operating at full power. On 06/24/00, power was reduced to ~ 96.8% due to an administrative limit of 600 degrees Fahrenheit imposed on the Reactor Coolant System hotleg temperature. The Unit operated under this administrative limit for the remainder of the month.

1

Reason:

- A Equipment Failure (Explain)
- B Maintenance or Test
- C Refueling
- D Regulatory Restriction
- E Operator Training & License Examination
- F Administration
- G Operational Error (Explain)
- H Other (Explain)

2

Method:

- 1 Manual
- 2 Manual Trip/Scram.
- 3 Automatic Trip/Scram.
- 4 Continuation
- 5 Other (Explain)