

August 24, 2000

Mr. Michael B. Sellman, President
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

SUBJECT: POINT BEACH NUCLEAR POWER PLANT, UNITS 1 AND 2 - REQUEST FOR
ADDITIONAL INFORMATION RE: SECTION 3.7.4 OF IMPROVED TECHNICAL
SPECIFICATIONS CONVERSION (TAC NOS. MA9247 AND MA9248)

Dear Mr. Sellman:

By letter dated November 15, 1999, the Wisconsin Electric Power Company submitted a license amendment request to convert the current Technical Specifications to improved Technical Specifications for Point Beach, Units 1 and 2.

The enclosed request was discussed with Mr. Jack Gadzala and Roger Scott of your staff during a conference call on August 14, 2000. A mutually agreeable target date of 30 days from the date of this letter for your response was established. If circumstances result in the need to revise the target date, please contact me at (301) 415-1355 at the earliest opportunity.

Sincerely,

/RA/

Beth A. Wetzel, Senior Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-266 and 50-301

Enclosure: Request for Additional Information

cc w/encl: See next page

August 24, 2000

Mr. Michael B. Sellman, President
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

SUBJECT: POINT BEACH NUCLEAR POWER PLANT, UNITS 1 AND 2 - REQUEST FOR
ADDITIONAL INFORMATION RE: SECTION 3.7.4 OF IMPROVED TECHNICAL
SPECIFICATIONS CONVERSION (TAC NOS. MA9247 AND MA9248)

Dear Mr. Sellman:

By letter dated November 15, 1999, the Wisconsin Electric Power Company submitted a license amendment request to convert the current Technical Specifications to improved Technical Specifications for Point Beach, Units 1 and 2.

The enclosed request was discussed with Mr. Jack Gadzala and Roger Scott of your staff during a conference call on August 14, 2000. A mutually agreeable target date of 30 days from the date of this letter for your response was established. If circumstances result in the need to revise the target date, please contact me at (301) 415-1355 at the earliest opportunity.

Sincerely,

/RA/

Beth A. Wetzel, Senior Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-266 and 50-301

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION

PUBLIC	RBouling
PDIII-1 Reading	LBerry
SBlack	OGC
CCraig	ACRS
BWetzel	RLanksbury, RIII

OFFICE	PDIII-1/PM	PDIII-1/PM	PDIII-1/LA	PDIII-1/SC
NAME	JLamb	BWetzel	RBouling	CCraig
DATE	8/22/00	8/18/00	8/18/00	8/22/00

Accession No. ML003742145

OFFICIAL RECORD COPY

Point Beach Nuclear Plant, Units 1 and 2

cc:

Mr. John H. O'Neill, Jr.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, NW
Washington, DC 20037-1128

Ms. Sarah Jenkins
Electric Division
Public Service Commission of Wisconsin
P.O. Box 7854
Madison, WI 53707-7854

Mr. Richard R. Grigg
President and Chief Operating Officer
Wisconsin Electric Power Company
231 West Michigan Street
Milwaukee, WI 53201

Mr. Mark E. Reddemann
Site Vice President
Point Beach Nuclear Plant
Wisconsin Electric Power Company
6610 Nuclear Road
Two Rivers, WI 54241

Mr. Ken Duveneck
Town Chairman
Town of Two Creeks
13017 State Highway 42
Mishicot, WI 54228

Chairman
Public Service Commission
of Wisconsin
P.O. Box 7854
Madison, WI 53707-7854

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Resident Inspector's Office
U.S. Nuclear Regulatory Commission
6612 Nuclear Road
Two Rivers, WI 54241

November 1999

REQUEST FOR ADDITIONAL INFORMATION

POINT BEACH NUCLEAR POWER PLANT, UNITS 1 AND 2

IMPROVED TECHNICAL SPECIFICATIONS (ITS), SECTION 3.7.4

1. The Atmospheric Dump Valves (ADV) are remote air-operated and manual-operated valves and the ADV block valves are local manually operated (only) valves upstream of the ADVs. Both are credited with being manually closed to isolate a stuck-open ADV and with being manually reopened to establish ADV flow. The proposed surveillance requirement in ITS 3.7.4 is to manually exercise the ADVs and the ADV block valves at an 18-month frequency with no steam pressure or steam flow required for the exercise tests. Provide design and/or qualification information which verifies that the ADVs and the ADV block valves are capable of being manually closed and opened within the required time period for the postulated ADV blowdown conditions. How will the proposed surveillance test with no pressure or flow assure that the valves continue to be capable of being operated under pressure and flow conditions?
2. Since the ADV block valves are gate valves and may be required to be reopened after being closed, provide verification that the valves will not be subject to thermal binding and/or pressure locking after being closed, or, if the valves are subject to thermal binding and/or pressure locking, provide the corrective actions taken to assure the valves can be successfully reopened.