



LEGEND

- ASME SECTION XI CLASS 1 PIPING
- ASME SECTION XI CLASS 2 PIPING
- ASME SECTION XI CLASS 3 PIPING
- NON-ISI NUCLEAR CLASS AND HSC CLASS
- PRESSURE BOUNDARY EXTENSION
- REFERENCE & CONTINUITY
- HVAC DUCT
- ANCHOR
- CONSTANT SPRING HANGER
- VARIABLE SPRING HANGER
- HYDRAULIC SNUBBER
- MECHANICAL SNUBBER
- NON-WELDED SUPPORT ATTACHMENT
- WELDED INTEGRAL SUPPORT ATTACHMENT
- RIGID SUPPORT
- SWAY STRUT
- SHOP WELD
- FIELD WELD
- LONGITUDINAL WELD
- WELD JET
- ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL

NOTES:

- MULTIPLE SWAY STRUTS, SPRING SUPPORTS OR SNUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE: 2MS - TWO HYDRAULIC TYPE SNUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE).
- THERE ARE NO SPOOL NUMBERS FOR LINE 8-HSC-91.
- SUPPORT NUMBERS AND LOCATIONS FOR THIS DRAWING ARE DERIVED FROM DRAWINGS 12501-HL-203H (SUPPLY TO APT 1-2) AND 12501-HL-1114, SHEET 1 (APT EXHAUST).
- THE SUPPORTS ON THE MAINSTEAM AUX. FEED PUMP SUPPLY LINE 4-EBD-19, 6-EBD-19, AND 8-EBD-91 ARE WITHIN THE ISI EXAMINATION BOUNDARY. THE PIPING WELDS IN THESE LINES ARE SHOWN FOR REFERENCE PURPOSES ONLY. THESE WELDS MAY NOT BE REPRESENTED IN THE ACTUAL AS-BUILT CONDITION.
- PIPING SYSTEMS ON THIS DRAWING WHICH ARE OUTSIDE OF THE ISI BOUNDARY, ARE SHOWN FOR REFERENCE AND CONTINUITY PURPOSES ONLY. THE CONFIGURATION SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.

REFERENCE DRAWINGS:

15102-003C MAIN STEAM AND REHEAT STEAM SYSTEM SHEET 3

GENERAL NOTE:

DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

1	INC DCN 151M2-203H-5 PER MOD 95-0000 SUP. 0 & GEN. UPDATE ZONE COND. FOR CONT. TO 151M2-203H (ZONE D-12)	SBW DVM	
2	INC DCN 151M2-203H-5 PER MOD 95-0000 SUP. 0 & GEN. UPDATE ZONE COND. FOR CONT. TO 151M2-203H (ZONE D-12)	INITIALS ON FILE	
3	INC DCN 151M2-203H-5 PER MOD 95-0000 SUP. 0 & GEN. UPDATE ZONE COND. FOR CONT. TO 151M2-203H (ZONE D-12)	INITIALS ON FILE	
4	INC DCN 151M2-203H-5 PER MOD 95-0000 SUP. 0 & GEN. UPDATE ZONE COND. FOR CONT. TO 151M2-203H (ZONE D-12)	INITIALS ON FILE	
5	INC DCN 151M2-203H-5 PER MOD 95-0000 SUP. 0 & GEN. UPDATE ZONE COND. FOR CONT. TO 151M2-203H (ZONE D-12)	INITIALS ON FILE	
6	ISSUED FOR SECOND 10 YEAR ISI PROGRAM	INITIALS ON FILE	
7	DATE	REVISIONS	BY
8	SCALE N.T.S.	DESIGNED	PROJECT
9	DAVIS-BESSE NUCLEAR POWER STATION UNIT NO. 1		
10	INSERVICE INSPECTION ISOMETRIC MAIN STEAM SYSTEM SUPPLY TO AUX. FEED PUMP TURBINE NO. 1-2 & EXHAUST		
11	DRAWING NO.	REV.	
12	151M2-203H	4	

D-99