

SEP 14 1983

DMB 016

MEMORANDUM FOR: James R. Miller, Chief
Operating Reactors Branch #4, DL

FROM: John F. Stolz, Chief
Operating Reactors Branch #4, DL

SUBJECT: REQUEST FOR PUBLICATION IN MONTHLY FR NOTICE -
NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING
LICENSE AND FINAL DETERMINATION OF NO SIGNIFICANT
HAZARDS CONSIDERATION (REPEAT OF INDIVIDUAL NOTICE)

GPU Nuclear Corporation, et al., Docket No. 50-289, Three Mile Island

Nuclear Station, Unit No. 1, Dauphin County, Pennsylvania

Date of application for amendment: May 9, 1983 ✓

Brief description of amendment: The amendment revised the license and the Technical Specifications to recognize and approve the steam generator tube kinetic expansion repair technique only for purposes of steam generator hot functional testing using pump heat (non-nuclear), and permits such testing. This amendment is in partial response to the May 9, 1983, application.

Date of issuance: August 25, 1983

Effective Date: August 25, 1983

Amendment No.: 86

Facility Operating License No.: DPR-50

Date of individual notice in Federal Register: September 1, 1983,

48 FR 39709

ORIGINAL SIGNED BY:
JOHN F. STOLZ

John F. Stolz, Chief
Operating Reactors Branch #4, DL

DISTRIBUTION:

Docket File
ORB #4 Rdg
Memo File
RIngram

JVan Vliet

PDR per JStolz 4/2/84

8309210506 830914
CF ADOCK 05000289
CF

OFFICE	ORB#4:DL	ORB#4:DL	ORB#4:DL				
SURNAME	RIngram	JVan Vliet;cf	JStolz				
DATE	9/9/83	9/11/83	9/14/83				