



Duke Power Company
A Duke Energy Company
Energy Center
P.O. Box 1006
Charlotte, NC 28201-1006

November 15, 2000

U.S Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Subject: Duke Energy Corporation
Oconee Nuclear Station, Units 1, 2, and 3
Docket Numbers 50-269, 50-270 and 50-287
Monthly Performance and Operation Status-October, 2000

Please find attached information concerning the performance and operation status of the Oconee Nuclear Station for the month of October, 2000.

Any questions or comments October be directed to Roger A. Williams at (704) 382-5346.

Sincerely,

Terry Dimmery, Manager
Nuclear Business Support

Attachment
XC:

L. A. Reyes, Regional Administrator
USNRC, Region II

Dave LaBarge, Project Manager
USNRC, ONRR

INPO Records Center

Ms. Margaret Aucoin
Nuclear Assurance Corporation

Dottie Sherman, ANI Library
American Nuclear Insurers

Oconee NRC Inspector

TE24

Document Control Desk
U.S. NRC - Oconee

bxc:

L. E. Nicholson (ON03RC)
RGC Site Licensing File
ELL (EC050)

Operating Data Report

Docket No. 50-269
Date November 15, 2000
Completed By Roger Williams
Telephone 704-382-5346

Operating Status

1. Unit Name: Oconee 1
2. Reporting Period: October 1, 2000 - October 31, 2000
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason for Restrictions, If any: _____

	This Month	YTD	Cumulative
11. Hours in Reporting Period	745.0	7320.0	239281.0
12. Number of Hours Reactor was Critical	745.0	6938.5	186766.7
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	745.0	6916.7	183530.3
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1913673	17653254	452976108
17. Gross Electrical Energy Generated (MWH)	662618	6138094	156574184
18. Net Electrical Energy Generated (MWH)	632850	5863324	148857360
19. Unit Service Factor	100.0	94.5	76.7
20. Unit Availability Factor	100.0	94.5	76.7
21. Unit Capacity Factor (Using MDC Net)	100.4	94.7	72.8
22. Unit Capacity Factor (Using DER Net)	95.9	90.4	70.2
23. Unit Forced Outage Rate	0.0	5.5	9.7
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:
1 037 937 KVA x 0.90 Pf=934 MW

UNIT SHUTDOWNS

DOCKET NO. 50-269UNIT NAME: Oconee 1DATE: November 15, 2000COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: October, 2000

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		
Summary:							

(1) Reason

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

(2) Method

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 1
2. Scheduled next refueling shutdown: November, 2000
3. Scheduled restart following refueling: December, 2000

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies (a) in the core: 177
 (b) in the spent fuel pool: 926*
 (c) in the ISFSI: 1368****
8. Present licensed fuel pool capacity: 1312
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present capacity: January 2005***

DUKE POWER COMPANY

DATE: November 15, 2000

Name of Contact:

R. A. Williams

Phone: (704) - 382-5346

- | | |
|------|---|
| * | Represents the combined total for Units 1 and 2 |
| ** | On March 29, 1990, received a license for ISFSI which will store 2112 assemblies |
| *** | We currently have 60 modules of which 49 modules are loaded.
Additional modules will be built on an as-needed basis. |
| **** | Represents the combined total for Units 1, 2, and 3 |

Operating Data Report

Docket No. 50-270
Date November 15, 2000
Completed By Roger Williams
Telephone 704-382-5346

Operating Status

1. Unit Name: Oconee 2
2. Reporting Period: October 1, 2000 - October 31, 2000
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason for Restrictions, If any: _____

	This Month	YTD	Cumulative
11. Hours in Reporting Period	745.0	7320.0	229201.0
12. Number of Hours Reactor was Critical	745.0	7320.0	183877.3
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	745.0	7320.0	181451.5
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1913057	36358567	464583373
17. Gross Electrical Energy Generated (MWH)	662553	6514448	153440791
18. Net Electrical Energy Generated (MWH)	633540	6239536	146171436
19. Unit Service Factor	100.0	100.0	79.2
20. Unit Availability Factor	100.0	100.0	79.2
21. Unit Capacity Factor (Using MDC Net)	100.5	100.8	74.7
22. Unit Capacity Factor (Using DER Net)	96.0	96.2	72.0
23. Unit Forced Outage Rate	0.0	0.0	9.3
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:

1 037 937 KVA x 0.90 Pf=934 MW

UNIT SHUTDOWNS

DOCKET NO. 50-270UNIT NAME: Oconee 2DATE: November 15, 2000COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: October, 2000

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		
Summary:							

(1) Reason

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

(2) Method

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 2
2. Scheduled next refueling shutdown: April, 2001
3. Scheduled restart following refueling: May, 2001

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies
 - (a) in the core: 177
 - (b) in the spent fuel pool: 926*
 - (c) in the ISFSI: See unit 1 ****
8. Present licensed fuel pool capacity: 1312
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present capacity: January 2005***

DUKE POWER COMPANY

DATE: November 15, 2000

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

* Represents the combined total for Units 1 and 2

** See footnote on Unit 1

*** We currently have 60 modules of which 49 modules are loaded.
Additional modules will be built on an as needed basis.

**** See footnote on Unit 1

Operating Data Report

Docket No.	50-287
Date	November 15, 2000
Completed By	Roger Williams
Telephone	704-382-5346

Operating Status

1. Unit Name: Oconee 3
2. Reporting Period: October 1, 2000 - October 31, 2000
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason for Restrictions, If any: _____

	This Month	YTD	Cumulative
11. Hours in Reporting Period	745.0	7320.0	226848.0
12. Number of Hours Reactor was Critical	745.0	6430.7	178482.8
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	745.0	6266.7	175897.9
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1912441	52330501	475393403
17. Gross Electrical Energy Generated (MWH)	665166	5567615	151784742
18. Net Electrical Energy Generated (MWH)	636361	5316971	144779162
19. Unit Service Factor	100.0	85.6	77.5
20. Unit Availability Factor	100.0	85.6	77.5
21. Unit Capacity Factor (Using MDC Net)	101.0	85.9	74.7
22. Unit Capacity Factor (Using DER Net)	96.4	82.0	72.0
23. Unit Forced Outage Rate	0.0	1.9	9.7
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:

1 037 937 KVA x 0.90 Pf=934 MW

UNIT SHUTDOWNS

DOCKET NO. 50-287UNIT NAME: Oconee 3DATE: November 15, 2000COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: October, 2000

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		

Summary:

(1) Reason

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

(2) Method

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 3
2. Scheduled next refueling shutdown: October 2001
3. Scheduled restart following refueling: November 2001

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies
(a) in the core: 177
(b) in the spent fuel pool: 552
(c) in the ISFSI: See Unit 1 ****
8. Present licensed fuel pool capacity: 825
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present capacity: January 2005***

DUKE POWER COMPANY

DATE: November 15, 2000

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

** See footnote of Unit 1

*** We currently have 60 modules of which 49 modules are loaded.
Additional modules will be built on an as needed basis.

**** See footnote on Unit 1

OCONEE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

SEPTEMBER 2000

1. Personnel Exposure -

The total station liquid release for SEPTEMBER has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for SEPTEMBER has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.