

DEC 22 1981

DISTRIBUTION

Docket

NRC PDR

L PDR

TERA

NSIC

ORB #1 Rdg

DEisenhut

OELD

IE-4

ACRS-10

GDeegan

LSnyder

DBrinkman

OPA

RDiggs

CParrish

JThoma

ASLAB

Gray File

Docket No. 50-247

*Correction ltr
to Amdt. 74*

Mr. John D. O'Toole, Vice President
Nuclear Engineering and Quality Assurance
Consolidated Edison Company
of New York, Inc.
4 Irving Place
New York, New York 10003

Dear Mr. O'Toole:

On December 10, 1981, the Commission issued Amendment No. 74 to Facility Operating License No. DPR-26 for the Indian Point Nuclear Generating Unit No. 2. The amendment modified your Technical Specifications to account for the effects that the degraded grid voltage may have on plant operations.

Through administrative oversight, certain parts of Table 4.1-1 were incorrectly modified by the amendment. Enclosed you will find the corrected Technical Specification pages for Table 4.1-1. Also enclosed is the first page of our Safety Evaluation for Amendment No. 74 which your staff indicated was not included with our package. We apologize for any inconvenience this administrative oversight may have caused.

Sincerely,

ORIGINAL SIGNED

John Thoma, Project Manager
Operating Reactors Branch #1
Division of Licensing


Enclosures:

As stated

cc w/enclosures:

See next page

8201190126 811222
PDR ADOCK 05000247
PDR



507

OFFICE	ORB #1: DL	ORB #1: DL					
SURNAME	JThoma:ds	SV:sa					
DATE	12/21/81	12/21/81					

Mr. John D. O'Toole
Consolidated Edison Company of New York, Inc.

cc: White Plains Public Library
100 Martine Avenue
White Plains, New York 10601

Joseph D. Block, Esquire
Executive Vice President
Administrative
Consolidated Edison Company
of New York, Inc.
4 Irving Place
New York, New York 10003

Lewis F. Liberatori
Nuclear Licensing Engineer
Consolidated Edison Company
of New York, Inc.
4 Irving Place
New York, New York 10003

Ms. Ellyn Weiss
Sheldon, Harmon and Weiss
1725 I Street, N.W., Suite 506
Washington, D. C. 20006

Dr. Lawrence R. Quarles
Apartment 51
Kendal at Longwood
Kennett Square, Pennsylvania 19348

Theodore A. Rebelowski
Resident Inspector
U. S. Nuclear Regulatory Commission
P. O. Box 38
Buchanan, New York 10511

Brent L. Brandenburg
Assistant General Counsel
Consolidated Edison Company
of New York, Inc.
4 Irving Place - 1822
New York, New York 10003

Carl R. D'Alvia, Esquire
Attorney for the Village of
Buchanan, New York
395 South Riverside Avenue
Croton-on-Hudson, New York 10520

Jeffrey C. Cohen, Esquire
New York State Energy Office
Swan Street Building
CORE 1 - Second Floor
Empire State Plaza
Albany, New York 12223

Director, Technical Development
Programs
State of New York Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Regional Radiation Representative
EPA Region II
26 Federal Plaza
New York, New York 10007

Thomas J. Farrelly, Esquire
Law Department
Consolidated Edison Company
of New York, Inc.
4 Irving Place
New York, New York 10003

Joan Holt, Project Director
New York Public Interest
Reserach Group, Inc.
5 Beekman Street
New York, New York 10038

Mr. John D. O'Toole
Consolidated Edison Company of New York, Inc.

cc: Mr. Charles W. Jackson
Vice President, Nuclear Power
Consolidated Edison Company
of New York, Inc.
Broadway and Bleakley Avenues
Buchanan, New York 10511

Mr. Kevin Burke
Director, Regulatory Affairs
Consolidated Edison Company
of New York, Inc.
Broadway and Bleakley Avenues
Buchanan, New York 10511

Mr. Frank Matra
Resident Construction Manager
Consolidated Edison Company
of New York, Inc.
Broadway and Bleakley Avenues
Buchanan, New York 10511

Ezra I. Bialik
Assistant Attorney General
Environmental Protection Bureau
New York State Department of Law
2 World Trade Center
New York, New York 10047

TABLE 4.1-1 (CONTINUED)

<u>Channel Description</u>	<u>Check</u>	<u>Calibrate</u>	<u>Test</u>	<u>Remarks</u>
22. Accumulator Level and Pressure	S	R	N.A.	
23. Steam Line Pressure	S	R	M	
24. Turbine First Stage Pressure	S	R	M	
25. Logic Channel Testing	N.A.	N.A.	M	
26. Turbine Overspeed Protection Trip Channel (Electrical)	N.A.	R	M	
27. Control Room Ventilation	N.A.	N.A.	R	Check damper operation for accident mode with isolation signal
28. Control Rod Protection (for use with IOPAR fuel)	N.A.	R	*	
29. Loss of Power				
a. 480v Emergency Bus Under-voltage (Loss of Voltage)	N.A.	R	R	
b. 480v Emergency Bus Under-voltage (Degraded Voltage)	N.A.	R	R	
c. 480v Emergency Bus Under-voltage (Alarm)	N.A.	R	M	
30. Auxiliary Feedwater:				
a. Steam Generator Water Level (Low-Low)	S	R	R	

* Within 31 days prior to entering a condition in which the Control Rod Protection System is required to be operable unless the reactor trip breakers are manually opened during RCS cooldown prior to T_{cold} decreasing below 350°F and the breakers are maintained open during T_{cold} cooldown when T_{cold} is less than 350°F.

TABLE 4.1-1 (Continued)

<u>CHANNEL DESCRIPTION</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>TEST</u>
b. Station Blackout (Undervoltage)	N.A.	R	R
c. Trip of Main Feed- water Pumps	N.A.	N.A.	R
31. Reactor Coolant System Subcooling Margin Monitor	M	R	N.A.
32. PORV Position Indicator (Limit Switch)	M	R	R
33. PORV Block Valve Position Indicator (Limit Switch)	M*	R	R
34. Safety Valve Position Indicator (Acoustic Monitor)	M	R	R
35. Auxiliary Feedwater Flow Rate	M	R	R
36. PORV Actuation/Reclosure Setpoints	N.A.	R	N.A.

* Except when valve operator is deenergized in accordance with specification 3.1.A.4.c



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 74 TO FACILITY OPERATING LICENSE NO. DPR-26

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.

INDIAN POINT NUCLEAR GENERATING UNIT NO. 2

DOCKET NO. 50-247

Introduction and Summary

A request for certain information on the effects that degraded grid voltage may have on plant operations was sent to Consolidated Edison Company (Con-Ed) by the NRC on August 12, 1976. General Design Criterion 17 (GDC 17), "Electric Power Systems," of Appendix A, "General Design Criteria for Nuclear Power Plants," of 10 CFR Part 50 requires that the safety function of each a.c. system shall be to provide sufficient capacity and capability to assure that: (a) specified acceptable fuel design limits and the design conditions for the reactor coolant pressure boundary are not exceeded as a result of anticipated operational occurrences; and (b) the core is cooled and containment integrity and other vital functions are maintained during any of the postulated accidents. GDC 17 further requires that provisions be included to minimize the probability of losing electric power from any one of the remaining supplies as a result of or coincident with the loss of power generated by the nuclear power unit, the loss of power from the transmission network, or the loss of power from the onsite electric power supplies. A sustained degradation of the offsite power system's voltage could result in the loss of capability of the redundant safety loads, their control circuitry, and the associated electrical components required for performing safety functions. Criteria, staff positions, and proposed technical specifications on degraded grid protection were sent to the licensee by a generic letter dated June 2, 1977. Conformance to the standard technical specifications should provide adequate protection for the degraded grid voltage condition.

Con-Ed's responses were dated September 24, 1976; March 31, 1977; August 29, 1977 (two letters); October 16, 1979; April 28, 1980; August 1, 1980; and April 27, 1981. During our review of their proposed technical specifications, we found that certain changes were necessary. The licensee agreed to these changes and they have been incorporated. The detailed reviews and technical evaluations of Con-Ed's proposed plant modifications and technical specifications changes were performed by EG&G under contract to the NRC with general supervision provided by the staff. EG&G's Technical Evaluation Report is provided as Attachment 1 to this Safety Evaluation Report. We have reviewed EG&G's Technical Evaluation

8201190134 811222
PDR ADDCK 05000247
P PDR