

July 13, 1987

Docket No. 50-286

Mr. John C. Brons
Executive Vice President - Nuclear Generation
Power Authority of the State of New York
123 Main Street
White Plains, New York 10601

DISTRIBUTION

<u>Docket File</u>	D. Hagan
NRC PDR	E. Jordan
Local PDR	J. Partlow
PDI-1 rdg.	T. Barnhart(4)
S. Varga	Wanda Jones
B. Boger	E. Butcher
C. Vogan	ACRS(10)
M. Slosson	GPA/PA
OGC	ARM/LFMB
J. Johnson	

Dear Mr. Brons:

The Commission has issued the enclosed Amendment No. 77 to Facility Operating License No. DPR-64 for the Indian Point Nuclear Generating Unit No. 3. The amendment consists of changes to the Technical Specifications in response to your application transmitted by letter dated May 21, 1987 (TAC 65393).

The amendment revises the Technical Specifications to allow an Integrated Leak Rate Test of less than 24 hours in accordance with the NRC approved methodology contained in BN-TOP-1, Revision 1.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular bi-weekly Federal Register notice.

Sincerely,

Marylee M. Slosson, Project Manager
Project Directorate I-1
Division of Reactor Projects, I/II

Enclosures:

1. Amendment No. 77 to DPR-64
2. Safety Evaluation

cc: w/enclosures
See next page

PDI-1 *CV*
CVogan
7/2/87

PDI-1 *MS*
MSlosson
7/2/87

OGC
J. Karman
7/17/87


RAC
PDI-1
RCapra
7/13/87

Mr. John C. Brons
Power Authority of the State
of New York

Indian Point Nuclear Generating
Unit No. 3

cc:
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Resident Inspector
Indian Point Nuclear Generating
U.S. Nuclear Regulatory Commission
Post Office Box 337
Buchanan, New York 10511

Mr. Gerald C. Goldstein
Assistant General Counsel
Power Authority of the State
of New York
10 Columbus Circle
New York, New York 10019

Mr. Robert L. Spring
Nuclear Licensing Engineer
Consolidated Edison Company
of New York, Inc.
4 Irving Place
New York, New York 10003

Ms. Ellyn Weiss
Harmon, Weiss and Jordan
2001 S Street, N.W., Suite 430
Washington, DC 20009

Mr. A. Klausmann, Vice President
Quality Assurance
Power Authority of the State
of New York
10 Columbus Circle
New York, New York 10019

Dr. Lawrence R. Ouarles
Apartment 51
Kendal at Longwood
Kennett Square, Pennsylvania 19348

Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, New York 10511

Mr. George M. Wilverding, Manager
Nuclear Safety Evaluation
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Mr. F. X. Pindar
Quality Assurance Superintendent
Indian Point 3 Nuclear Power Plant
Post Office Box 215
Buchanan, New York 10511

Director, Technical Development
Programs
State of New York Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Mr. R. Beedle, Vice President
Nuclear Support
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Mr. Leroy W. Sinclair
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Mr. William Josiger
Resident Manager
Indian Point 3 Nuclear Power Plant
Post Office Box 215
Buchanan, New York 10511

Power Authority of the State
of New York

- 2 -

Indian Point 3

cc

Ezra I. Bialik
Assistant Attorney General
Environmental Protection Bureau
New York State Department of Law
2 World Trade Center
New York, New York 10047

P. Kokolakis, Director
Nuclear Licensing
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Mr. Jay Dunkleberger
Division of Policy Analysis
and Planning
New York State Energy Office
Agency Building 2, Empire
State Plaza
Albany, New York 12223

Mr. S. S. Zulla, Vice President
Nuclear Engineering
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Mr. R. Burns, Vice President
Nuclear Operations
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

POWER AUTHORITY OF THE STATE OF NEW YORK

DOCKET NO. 50-286

INDIAN POINT NUCLEAR GENERATING UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 77
License No. DPR-64


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Power Authority of the State of New York (the licensee) dated May 21, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-64 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 77, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Capra, Acting Director
Project Directorate I-1
Division of Reactor Projects, I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: July 13, 1987



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ATTACHMENT TO LICENSE AMENDMENT NO. 77
FACILITY OPERATING LICENSE NO. DPR-64
DOCKET NO. 50-286

Revise Appendix A as follows:

<u>Remove Pages</u>	<u>Insert Pages</u>
4.4-1	4.4-1
4.4-8	4.4-8

4.4 CONTAINMENT TESTS

Applicability

Applies to containment leakage.

Objective

To verify that potential leakage from the containment is maintained within acceptable values.

Specification

A. Integrated Leakage Rate

1. Test

- a. A full pressure integrated leakage rate test shall be performed at intervals specified in A.3 at the peak accident pressure (P_a) of 40.6 psig minimum.
- b. A test duration of 24 hours, or an NRC approved reduced duration methodology, as described in BN-TOP-1, Revision 1, shall be used. The test shall be extended a sufficient period of time to verify, by superimposing a known leak rate on the containment, the validity and accuracy of the leakage rate results.
- c. A general inspection of the accessible interior and exterior surfaces of the containment structures and components shall be performed prior to performing an integrated leak test to uncover any evidence of structural deterioration which may affect either the containment structural integrity or leak tightness. If there is evidence of structural deterioration, integrated leakage rate tests shall not be performed until corrective action is taken. Such structural deterioration and corrective actions taken shall be reported as part of the test report.

The minimum duration of 24 hours for the integrated leakage rate test is established to attain the desired level of accuracy and to allow for daily cyclic variation in temperature and thermal radiation. If an ILRT of a duration less than 24 hours is attempted, the criteria of the Bechtel Topical Report, BN-TOP-1, Revision 1, will be met.

The frequency of the periodic integrated leakage rate test is keyed to the schedule for major shutdowns for inservice inspection and refueling. The specified frequency of periodic integrated leakage rate testing is based on the following major considerations.

First is the low probability of leaks in the liner, because of

- (a) the tests of the leak-tight integrity of the welds during erection;
- (b) conformance of the complete containment to a low leakage rate limit at 40.6 psig or higher during pre-operational testing, and
- (c) absence of any significant stresses in the liner during reactor operation.

Secondly, the Weld Channel and Penetration Pressurization System is in service continuously to monitor leakage from potential leak paths such as the containment personnel lock seals and weld channels, containment penetrations, containment liner weld channels, double-gasketed seals and spaces between certain containment isolation valves and personnel door locks. A leak would be expected to build up slowly and would, therefore, be noted before design limits are exceeded. Remedial action can be taken before the limit is reached.

During normal plant operation, containment personnel lock door seals are continuously pressurized after each closure by the Weld Channel and Penetration Pressurization System. Whenever containment integrity is required, verification is made that seals repressurize properly upon closure of an air lock door.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 77 TO FACILITY OPERATING LICENSE NO. DPR-64
POWER AUTHORITY OF THE STATE OF NEW YORK
INDIAN POINT NUCLEAR GENERATING UNIT NO. 3
DOCKET NO. 50-286

INTRODUCTION

By letter dated May 21, 1987, the Power Authority of the State of New York (the licensee) requested a change to plant Technical Specification (TS) Section 4.4 regarding the Containment Integrated Leakage Rate Test (ILRT) for Indian Point Nuclear Generating Unit No. 3. The proposed change will allow an ILRT duration as specified in TS Section 4.4 and its associated Basis to be less than 24 hours as described in Bechtel Power Corporation Topical Report, BN-TOP-1, Revision 1.

DISCUSSION AND EVALUATION

TS Section 4.4 currently specifies that the ILRT duration be at least 24 hours. The proposed change would permit reducing the test duration on the basis of compliance with a methodology which has been approved by the NRC staff. By letter dated February 1, 1973, the staff found BN-TOP-1, Revision 1 acceptable even though it provides for shorter duration testing criteria for ILRTs. Based on previous staff approval of BN-TOP-1, the staff concludes that the proposed TS change to permit ILRT in accordance with Bechtel Topical Report BN-TOP-1, Revision 1 is acceptable.

The licensee requested that the Technical Specifications be revised to accept other NRC approved methodologies. Currently, there are no other approved methodologies applicable to Indian Point 3. As a result the proposed Technical Specifications have been revised to delete the words concerning other approved methodologies. This change was discussed with the licensee and found to be acceptable.

ENVIRONMENTAL CONSIDERATION

This amendment involves a change in the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in

8707200273 870713
PDR ADOCK 05000206
P PDR

individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR Sec 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

CONCLUSION

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Dated: July 13, 1987

PRINCIPAL CONTRIBUTOR:

C. Y. Li