

September 11, 1990

Docket No. 50-286

Mr. John C. Brons
Executive Vice President - Nuclear Generation
Power Authority of the State of New York
123 Main Street
White Plains, New York 10601

DISTRIBUTION:

Docket File	DHagan
NRC/Local PDRs	EJordan
PDI-1 RF	GHill(4)
SVarga	Wanda Jones
RWessman	JCalvo
RCapra	ACRS(10)
CVogan	GPA/PA
DNeighbors	OC/LFMB
OGC	Plant File
JLinville	TRotella

Dear Mr. Brons:

SUBJECT: ISSUANCE OF AMENDMENT FOR INDIAN POINT 3 (TAC NO. 77004)

The Commission has issued the enclosed Amendment No. 103 to Facility Operating License No. DPR-64 for the Indian Point Nuclear Generating Unit No. 3. The amendment consists of changes to the Technical Specifications in response to your application transmitted by letter dated June 21, 1990, as supplemented July 27, 1990.

The amendment revises the Technical Specifications to remove cycle-specific parameter limits from the Technical Specifications and to reference a Core Operating Limits Report. These changes are in accordance with NRC Generic Letter 88-16.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular bi-weekly Federal Register notice.

Sincerely,

ORIGINAL SIGNED BY:

Joseph D. Neighbors, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No.103 to DPR-64
2. Safety Evaluation

cc: w/enclosures

See next page

PDI-1

CVogan

8/22/90 9/10/90

PDI-1 *DAB*
JNeighbors:rsc

8/22/90

OGC *off/mmtl to SE*
m/young
8/29/90

Roe
PDI-1
RACapra
9/11/90

DOCUMENT NAME: AMENDMENT 77004

9009200082 900911
PDR ADUCK 05000286
FDC

DF01



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

September 11, 1990

Docket No. 50-286

Mr. John C. Brons
Executive Vice President - Nuclear Generation
Power Authority of the State of New York
123 Main Street
White Plains, New York 10601

Dear Mr. Brons:

SUBJECT: ISSUANCE OF AMENDMENT FOR INDIAN POINT 3 (TAC NO. 77004)

The Commission has issued the enclosed Amendment No. 103 to Facility Operating License No. DPR-64 for the Indian Point Nuclear Generating Unit No. 3. The amendment consists of changes to the Technical Specifications in response to your application transmitted by letter dated June 21, 1990, as supplemented July 27, 1990.

The amendment revises the Technical Specifications to remove cycle-specific parameter limits from the Technical Specifications and to reference a Core Operating Limits Report. These changes are in accordance with NRC Generic Letter 88-16.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular bi-weekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script, reading "Joseph D. Neighbors", is positioned above the typed name.

Joseph D. Neighbors, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 103 to DPR-64
2. Safety Evaluation

cc: w/enclosures
See next page

Mr. John C. Brons
Power Authority of the State
of New York

Indian Point 3 Nuclear Power Plant

cc:

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Resident Inspector
Indian Point 3 Nuclear Power Plant
U.S. Nuclear Regulatory Commission
Post Office Box 337
Buchanan, New York 10511

Mr. Gerald C. Goldstein
Assistant General Counsel
Power Authority of the State
of New York
1633 Broadway
New York, New York 10019

Mr. Charles W. Jackson
Manager, Nuclear Safety and Licensing
Consolidated Edison Company
of New York, Inc.
Broadway and Bleakley Avenues
Buchanan, New York 10511

Mr. Phillip Bayne, President
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Mr. A. Klausmann, Vice President
Quality Assurance
Power Authority of the State of New York
1633 Broadway
New York, New York 10019

Mr. Joseph E. Russell
Resident Manager
Indian Point 3 Nuclear Power Plant
Post Office Box 215
Buchanan, New York 10511

Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, New York 10511

Mr. George M. Wilverding, Manager
Nuclear Safety Evaluation
Power Authority of the State of New York
123 Main Street
White Plains, New York 10601

Mr. F. X. Pindar
Quality Assurance Superintendent
Indian Point 3 Nuclear Power Plant
Post Office Box 215
Buchanan, New York 10511

Mr. Peter Kokolakis, Director
Nuclear Licensing
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Mr. R. Beedle, Vice President
Nuclear Support
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Ms. Donna Ross
New York State Energy Office
2 Empire State Plaza
16th Floor
Albany, New York 12223

Mr. S. S. Zulla, Vice President
Nuclear Engineering
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Mr. William Josiger, Vice President
Operations and Maintenance
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, New York 10271



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

POWER AUTHORITY OF THE STATE OF NEW YORK

DOCKET NO. 50-286

INDIAN POINT NUCLEAR GENERATING UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 103
License No. DPR-64

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Power Authority of the State of New York (the licensee) dated June 21, 1990, as supplemented July 27, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-64 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 103, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance and shall be implemented prior to startup of Cycle 8 operation.

FOR THE NUCLEAR REGULATORY COMMISSION

Robert A. Capra

Robert A. Capra, Director
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 11, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 103

FACILITY OPERATING LICENSE NO. DPR-64

DOCKET NO. 50-286

Revise Appendix A as follows:

Remove Pages

iv
List of Figures
1-6
2.1-2
2.1-3
3.10-1
3.10-2
3.10-3
3.10-4
3.10-5
3.10-6
3.10-7
3.10-8
3.10-8a
3.10-9
3.10-10
3.10-11
3.10-12
3.10-13
3.10-14
3.10-15
3.10-16
--
6-15
6-16
6-17
6-18
6-19
--
--

Insert Pages

iv
List of Figures
1-6
2.1-2
2.1-3
3.10-1
3.10-2
3.10-3
3.10-4
3.10-5
3.10-6
3.10-7
3.10-8
3.10-8a
3.10-9
3.10-10
3.10-11
3.10-12
3.10-13
3.10-14
3.10-15
3.10-16
3.10-17
6-15
6-16
6-17
6-18
6-19
6-20
6-21

<u>Section</u>	<u>Title</u>	<u>Page</u>
6.9	Reporting Requirements	6-13a
	Routine Reports	6-13a
	Special Reports	6-17
6.10	Record Retention	6-17
6.11	Radiation and Respiratory Protection Program	6-19
6.12	High Radiation Area	6-20
6.13	Environmental Qualification	6-21

LIST OF FIGURES

<u>Title</u>	<u>Figure No.</u>
Core Limits - Four Loop Operation	2.1-1
Maximum Permissible T_{cold} for First RCP Start (OPS Operable, Hottest SG Temp. $> T_{cold}$)	3.1.A-1
Maximum Permissible RCS Pressure for RCP Start(s) with OPS Inoperable (SG Temp. $> T_{cold}$ for additional pump starts, SG Temp. $< T_{cold}$ for all pump starts)	3.1.A-2
RCS Pressure Limits for Low Temperature Operation	3.1.A-3
Maximum Pressurizer Level for OPS Inoperable and First RCP Start (SG Temp. $> T_{cold}$)	3.1.A-4
Maximum Pressurizer Level with OPS Inoperable and One (1) Charging Pump Energized	3.1.A-5
Maximum Pressurizer Level with OPS Inoperable and One (1) Safety Injection Pump and/or Three (3) Charging Pumps Energized	3.1.A-6
Reactor Coolant System Heatup Limitations	3.1-1
Reactor Coolant System Cooldown Limitations	3.1-2
Primary Coolant Specific Activity Limit vs. Percent of Rated Thermal Power	3.1-3
Gross Electrical Output - 1" HG Backpressure	3.4-1
Gross Electrical Output - 1.5" HG Backpressure	3.4-2
Limiting Fuel Burnup vs. Initial Enrichment	3.8-1
Minimum Burnup for Storage of Fuel in Max Density Spent Fuel Pit Racks	3.8-2
Maximum Density Spent Fuel Pit (SFP) Racks, Regions and Indexing	3.8-3
Required Shutdown Margin	3.10-1
Steam Generator Primary Side Ultrasonic Test Sectors	4.2-1
Pressure/Temperature Limitations for Hydrostatic Leak Test	4.3-1

1.16 REPORTABLE EVENT

A REPORTABLE EVENT shall be any of those conditions specified in Section 50.73 to 10 CFR 50.

1.17 CORE OPERATING LIMITS REPORT

The CORE OPERATING LIMITS REPORT (COLR) is the unit-specific document that provides core operating limits for the current operating reload cycle. These cycle-specific core operating limits shall be determined for each reload cycle in accordance with Specification 6.9.1.6. Plant operation within these operating limits is addressed in individual specifications.

In meeting this design basis, uncertainties in plant operating parameters, nuclear and thermal parameters, and fuel fabrication parameters are considered statistically such that there is at least a 95% probability with 95% confidence level that the minimum DNBR for the limiting rod is greater than or equal to the applicable DNBR limit. The uncertainties in the above plant parameters are used to determine the plant DNBR uncertainty. The DNBR uncertainty combined with the correlation DNBR limit, establishes a design DNBR value which must be met in plant safety analyses using values of input parameters without uncertainties. In addition, margin is maintained by performing DNB design evaluations to a higher DNBR value, called the Safety Limit DNBR.

The curves of Figure 2.1-1 show the loci of points of thermal power, Reactor Coolant System pressure and vessel inlet temperature for which the calculated DNBR is no less than the Safety Limit DNBR value or the average enthalpy at the vessel exit is less than the enthalpy of saturated liquid.

The calculation of these limits includes:

1. $F_{\Delta H}^N = F_{\Delta H}^{RTP}$ limit at Rated Thermal Power (RTP) specified in the COLR.
2. an equivalent steam generator tube plugging level of up to 30% in any steam generator provided the equivalent average plugging level in all steam generators is less than or equal to 24%, ⁽²⁾
3. a reactor coolant system total flow rate of greater than or equal to 332,240 gpm as measured at the plant,
4. a reference cosine with a peak of 1.55 for axial power shape.

Figure 2.1-1 includes an allowance for an increase in the enthalpy rise hot channel factor at reduced power based on the expression:

$$F_{\Delta H}^N \leq F_{\Delta H}^{RTP} (1 + PF_{\Delta H} (1-P))$$

Where P is the fraction of Rated Thermal Power,

$F_{\Delta H}^N$ is the $F_{\Delta H}^{RTP}$ limit at Rated Thermal Power specified in the COLR, and $PF_{\Delta H}$ is the Power Factor Multiplier specified in the COLR.

When flow or $F_{\Delta H}$ is measured, no additional allowances are necessary prior to comparison with the limits presented. A 2.6% measurement uncertainty on Flow and a 4% measurement uncertainty of $F_{\Delta H}$ have already been included in the above limits.

These limiting heat flux conditions are higher than those calculated for the range of all control rods fully withdrawn to the maximum allowable control rod insertion limit (Figure 3.10-4) assuming the axial power imbalance is within the limits of the $f(\Delta I)$ function of the Overtemperature ΔT trip. When the axial power imbalance is not within the tolerance, the axial power imbalance effect on the Overtemperature ΔT trips will reduce the setpoints to provide protection consistent with core safety limits.

2.1-2

Amendment No. 27, 40, 48, 51, 55, 101, 103

References

1. FSAR Section 3.2.2
2. "Safety Evaluation for Indian Point Unit 3 with Asymmetric Tube Plugging Among Steam Generators", WCAP-10705 (Westinghouse Non-Proprietary), October 1984.

3.10 CONTROL ROD AND POWER DISTRIBUTION LIMITS

Applicability:

Applies to the limits on core fission power distribution and to limits on control rod operations.

Objectives:

To ensure:

1. Core subcriticality after reactor trip.
2. Acceptable core power distribution during power operation in order to maintain fuel integrity in normal operation and transients associated with faults of moderate frequency, supplemented by automatic protection and by administrative procedures, and to maintain the design basis initial conditions for limiting faults, and
3. Limit potential reactivity insertions caused by hypothetical control rod ejection.

Specifications:

3.10.1 Shutdown Reactivity

The shutdown margin shall be at least as great as shown in Figure 3.10-1.

3.10.2 Power Distribution Limits

- 3.10.2.1 At all times, except during low power physics tests, the hot channel factors defined in the basis must meet the following limits:

$$F_Q(Z) \leq (F_Q^{RTP}/P) \times K(Z) \text{ for } P > 0.5$$

$$F_Q(Z) \leq (F_Q^{RTP}/0.5) \times K(Z) \text{ for } P \leq 0.5$$

$$F_{\Delta H}^N \leq F_{\Delta H}^{RTP} (1 + PF_{\Delta H} (1-P))$$

Where P is the fraction of full power at which the core is operating, K(Z) is the fraction specified in the COLR, Z is the core height location of F_Q , F_Q^{RTP} is the F_Q limit at Rated Thermal Power (RTP) specified in the COLR, $F_{\Delta H}^{RTP}$ is the $F_{\Delta H}$ limit at Rated Thermal Power specified in the COLR, and $PF_{\Delta H}$ is the Power Factor Multiplier specified in the COLR.

- 3.10.2.2 Following initial core loading, subsequent reloading and at regular effective full power monthly intervals thereafter, power distribution maps, using the movable detector system, shall be made to confirm that the hot channel factor limits of this specification are satisfied. For the purpose of this comparison,
- 3.10.2.2.1 The measurement of total peaking factor F_Q^{Meas} , shall be increased by three percent to account for manufacturing tolerances and further increased by five percent to account for measurement error.
- 3.10.2.2.2 When $F_{\Delta H}^N$ is measured, no additional allowances are necessary prior to comparison with the limits of section 3.10.2. An error allowance of 4% has been included in the limits of section 3.10.2. If either measured hot channel factor exceeds its limit specified under Item 3.10.2.1, the reactor power and high neutron flux trip setpoint shall be reduced so as not to exceed a fraction of rated power equal to the ratio of the F_Q or $F_{\Delta H}^N$ limit to measured value, whichever is less. If subsequent incore mapping cannot, within a 24-hour period, demonstrate that the hot channel factors are met, the reactor shall be brought to a hot shutdown condition with return to power authorized only for the purpose of physics testing.
- 3.10.2.3 The reference equilibrium indicated axial flux difference for each excore channel as a function of power level (called the target flux difference) shall be measured at least once per equivalent full power quarter. The target flux differences must be updated each effective full power month by linear interpolation using the most recent measured value and a value of 0 percent at the end of the cycle life.
- 3.10.2.4 Except during physics tests, during excore calibration procedures and except as modified by Items 3.10.2.5 through 3.10.2.7 below, the indicated axial flux difference of all but one operable excore channel shall be maintained within the band specified in the COLR about the target flux difference.

- 3.10.2.5 At a power level greater than 90% of rated power,
- 3.10.2.5.1 If the indicated axial flux difference of more than one operable excore channel deviates from its target band, either such deviation shall be immediately eliminated or the reactor power shall be reduced to a level no greater than 90 percent of rated power.
- 3.10.2.6 At a power level no greater than 90 percent of rated power,
- 3.10.2.6.1 The indicated axial flux difference (AFD) may deviate from its target band specified in the COLR for a maximum of one hour (cumulative) in any 24 hour period provided the flux difference does not exceed an envelope bounded by that specified in the COLR at 90% power and increasing by the value specified in the COLR for each 2 percent of rated power below 90% power. A two hour deviation is permissible during tests performed as part of the augmented startup program. ⁽¹⁾
- 3.10.2.6.2 If Item 3.10.2.6.1 is violated by more than one operable excore channel, then the reactor power shall be reduced to no greater than 50% power and the high neutron flux setpoint reduced to no greater than 55 percent of rated values.
- 3.10.2.6.3 A power increase to a level greater than 90 percent of rated power is contingent upon the indicated axial flux difference of all but one operable excore channel being within their target band.
- 3.10.2.7 At a power level no greater than 50 percent of rated power,
- 3.10.2.7.1 The indicated axial flux difference may deviate from its target band.
- 3.10.2.7.2 A power increase to a level greater than 50 percent of rated power is contingent upon the indicated axial flux difference of all but one operable excore channel not being outside their target bands for more than two hours (cumulative) out of the preceding 24-hour period. One-half the time the indicated axial flux difference is out of its target band up to 50% of rated power is to be counted as contributing to the one-hour cumulative (two-hour cumulative during augmented startup tests) ⁽¹⁾ maximum the flux difference may deviate from its target band of a power level \leq 90% of rated power.

- 3.10.2.8 Alarms are provided to indicate non-conformance with the flux difference requirements of 3.10.2.5.1 and the flux difference-time requirements of 3.10.2.6.1. If the alarms are temporarily out of service, conformance with the applicable limit shall be demonstrated by logging the flux difference at hourly intervals for the first 24 hours and half-hourly thereafter.
- 3.10.2.9 If the core is operating above 75% power with one excore nuclear channel out of service, then core quadrant power balance shall be determined once a day using movable incore detectors (at least two thimbles per quadrant).

3.10.3 Quadrant Power Tilt Limits

- 3.10.3.1 When ever the indicated quadrant power tilt ratio exceeds 1.02, except for physics tests, within two hours the tilt condition shall be eliminated or the following actions shall be taken:

- a) Restrict core power level and reset the power range high flux setpoint three percent of rated value for every percent of indicated power tilt ratio exceeding 1.0,

and

- b) If the tilt condition is not eliminated after 24 hours, the power range nuclear instrumentation setpoint shall be reset to 55% of allowed power. Subsequent reactor operation is permitted up to 50% for the purpose of measurement, testing and corrective action.

- 3.10.3.2 Except for physics tests, if the indicated quadrant power tilt ratio exceeds 1.09 and there is simultaneous indication of a misaligned control rod, restrict core power level 3% of rated value for every percent of indicated power tilt ratio exceeding 1.0 and realign the rod within two hours. If the rod is not realigned within two hours or if there is no simultaneous indication of a misaligned rod, the reactor shall be brought to the hot shutdown condition within 4 hours. If the reactor is shut down, subsequent testing up to 50% of rated power shall be permitted to determine the cause of the tilt.

- 3.10.3.3 The rod position indicators shall be monitored and logged once each shift to verify rod position within each bank assignment.
- 3.10.3.4 The tilt deviation alarm shall be set to annunciate whenever the excore tilt ratio exceeds 1.02. If one or both of the quadrant power tilt monitors is inoperable, individual upper and lower excore detector calibrated outputs shall be logged once per shift and after a load change greater than 10 percent of rated power.
- 3.10.4 Rod Insertion Limits
- 3.10.4.1 The shutdown rods shall be fully withdrawn as specified in the COLR when the reactor is critical or approaching criticality (i.e., the reactor is no longer subcritical by an amount equal to or greater than the shutdown margin in Figure 3.10-1).
- 3.10.4.2 When the reactor is critical, the control banks shall be limited in physical insertion to the insertion limits specified in the COLR.
- 3.10.4.3 Control bank insertion shall be further restricted if:
- a) The measured control rod worth of all rods, less the worth of the most reactive rod (worst case stuck rod), is less than the reactivity required to provide the design value of available shutdown.
 - b) A rod is inoperable (Specification 3.10.7).
- 3.10.4.4 Control rod insertion limits do not apply during physics tests or during periodic exercise of individual rods. However, the shutdown margin indicated in Figure 3.10-1 must be maintained except for the low power physics test to measure control rod worth and shutdown margin. For this test, the reactor may be critical with all but one control rod inserted.

- 3.10.5 Rod Misalignment Limitations
- 3.10.5.1 If a control rod is misaligned from its bank demand position by more than 12 steps (indicated position), then realign the rod or determine the core peaking factors within 2 hours and apply Specification 3.10.2.
- 3.10.5.2 If the requirements of Specification 3.10.3 are determined not to apply and the core peaking factors have not been determined within two hours and the rod remains misaligned, the high reactor flux setpoint shall be reduced to 85% of its rated value.
- 3.10.5.3 If the misaligned control rod is not realigned within 8 hours the rod shall be declared inoperable.
- 3.10.6 Inoperable Rod Position Indicator Channels
- 3.10.6.1 If a rod position indicator channel is out of service then:
- a. For operation between 50 percent and 100 percent of rating, the position of the control rod shall be checked indirectly by core instrumentation (excore detectors and/or movable incore detectors) every shift, or subsequent to rod motion exceeding 24 steps, whichever occurs first.
 - b. During operation below 50 percent of rating, no special monitoring is required.
- 3.10.6.2 Not more than one rod position indicator channel per group nor two rod position indicator channels per bank shall be permitted to be inoperable at any time.
- 3.10.6.3 If a control rod having a rod position indicator channel out of service, is found to be misaligned from 3.10.6.1a above, then Specification 3.10.5 will be applied.

- 3.10.7 Inoperable Rod Limitations
- 3.10.7.1 An inoperable rod is a rod which does not trip or which is declared inoperable under Specification 3.10.5 or fails to meet the requirements of 3.10.8.
- 3.10.7.2 Not more than one inoperable control rod shall be allowed any time the reactor is critical except during physics tests requiring intentional rod misalignment. Otherwise, the plant shall be brought to the hot shutdown condition.
- 3.10.7.3 If any rod has been declared inoperable, then the potential ejected rod worth, associated transient power distribution peaking factors and the accident listed in Table 3.10-1 shall be analyzed within 5 days, or the reactor brought to the hot shutdown condition using normal operating procedures. The analysis shall include due allowance for non-uniform fuel depletion in the neighborhood of the inoperable rod. If the analysis results in a more limiting hypothetical transient than the cases reported in the safety analysis, the plant power level shall be reduced to an analytically determined part power level which is consistent with the safety analysis.
- 3.10.8 Rod Drop Time
- At operating temperature and full flow, the drop time to each control rod shall be no greater than 2.4 seconds from loss of stationary gripper coil voltage to dashpot entry.

3.10-7

3.10.9 Rod Position Monitor

If the rod position deviation monitor is inoperable, individual rod positions shall be logged once per shift and after a load change greater than 10 percent of rated power.

3.10.10 Reactivity Balance

The overall core reactivity balance shall be compared to predicted values to demonstrate agreement within $\pm 1\% \Delta k/k$ at least once per 31 Effective Fuel Power Days (EFPD). This comparison shall, at least consider reactor coolant system boron concentration, control rod position, reactor coolant system average temperature, fuel burnup based on gross thermal energy generation, xenon concentration, and samarium concentration. The predicted reactivity values shall be adjusted (normalized) to correspond to the actual core condition prior to exceeding a fuel burnup of 60 EFPD after each fuel loading.

3.10.11 Notification

Any event requiring plant shutdown on trip setpoint reduction because of Specification 3.10 shall be reported to the Nuclear Regulatory Commission within 30 days.

Basis

Design criteria have been chosen for normal operations, operational transients and those events analyzed in FSAR Section 14.1 which are consistent with the fuel integrity analysis. These relate to fission gas release, pellet temperature and cladding mechanical properties. Also, the minimum DNBR in the core must not be less than the applicable safety limit DNBR in normal operation or in short term transients.

In addition to the above conditions, the peak linear power density must not exceed the limiting Kw/ft values which result from the large break loss of coolant

accident analysis based on the ECCS acceptance criteria limit of 2200°F. This is required to meet the initial conditions assumed for loss of coolant accident analyses. To aid in specifying the limits on power distribution, the following hot channel factors are defined.

$F_Q(Z)$, Height Dependent Heat Flux Hot Channel Factor, is defined as the maximum local heat flux on the surface of a fuel rod at core elevation Z divided by the average fuel rod heat flux, allowing for manufacturing tolerances on fuel pellets and rods.

3.10-8a

Amendment No. 28, 103

F_Q^E Engineering Heat Flux Hot Channel Factor, is defined as the allowance on heat flux required for manufacturing tolerances. The engineering factor allows for local variations in enrichment, pellet density and diameter, surface area of the fuel rod and eccentricity of the gap between pellet and clad. Combined statistically the net effect is a factor of 1.03 to be applied to fuel rod surface heat flux.

$F_{\Delta H}^N$ Nuclear Enthalpy Rise Hot Channel Factor, is defined as the ratio of the integral of linear power along the rod with the highest integrated power to the average rod power.

It should be noted that $F_{\Delta H}^N$ is based on an integral and is used as such in the DNB calculations. Local heat fluxes are obtained by using hot channel and adjacent channel explicit power shapes which take into account variations in horizontal (x-y) power shapes throughout the core. Thus the horizontal power shape at the point of maximum heat flux is not necessarily directly related to $F_{\Delta H}^N$.

An upper bound envelope of F_Q^{RTP} specified in the COLR times the normalized peaking factor axial dependence of $K(Z)$ specified in the COLR has been determined consistent with Appendix K criteria and is satisfied for OFA transition mixed cores ⁽³⁾ by all operating maneuvers consistent with the technical specifications on power distribution control as given in Section 3.10. The results of the loss of coolant accident analysis based on this upper bound normalized envelope, $K(Z)$, specified in the COLR demonstrates a peak clad temperature not greater than 2049°F, which is below peak clad temperature limit of 2200°F. ⁽²⁾

When an F_Q measurement is taken, both experimental error and manufacturing tolerance must be allowed for. Five percent is the appropriate allowance for a full core map taken with the movable incore detector flux mapping system and three percent is the appropriate allowance for manufacturing tolerance.

In the specified limit of $F_{\Delta H}^N$ there is an 8 percent allowance for uncertainties which means that normal operation of the core is expected to result in $F_{\Delta H}^N \leq F_{\Delta H}^{RTP}/1.04$, where $F_{\Delta H}^{RTP}$ is the $F_{\Delta H}^N$ limit at Rated Thermal Power specified in the COLR. The logic behind the larger uncertainty in this case is that (a) normal perturbations in the radial power shape

(e.g. rod misalignment) affect $F_{\Delta H}^N$, in most cases without necessarily affecting F_Q , (b) the operator has a direct influence on F_Q through movement of rods, and can limit it to the desired value, he has no direct control over $F_{\Delta H}^N$ and (c) an error in the predictions for radial power shape, which may be detected during startup physics tests can be compensated for in F_Q by tighter axial control, but compensation for is less readily available. When a measurement of $F_{\Delta H}^N$ is taken, no additional allowances are necessary prior to comparison with the limit of section 3.10.2. A measurement uncertainty of 4% has been allowed for in determination of the design DNBR value.

Measurements of the hot channel factors are required as part of startup physics tests, at least each effective full power month of operation, and whenever abnormal power distribution conditions require a reduction of core power to a level based on measured hot channel factors. The incore map taken following initial loading provides confirmation of the basic nuclear design basis including proper fuel loading patterns. The periodic monthly incore mapping provides additional assurance that the nuclear design bases remain inviolate and identify operational anomalies which would, otherwise, affect these bases.

For normal operation, it is not necessary to measure these quantities. Instead it has been determined that, provided certain conditions are observed, the hot channel factor limits will be met; these conditions are as follows:

1. Control rods in a single bank move together with no individual rod insertion differing by more than 15 inches from the bank demand position. An indicated misalignment limit of 12 steps precludes a rod misalignment no greater than 15 inches with consideration of maximum instrumentation error.
2. Control Rod banks are sequenced with overlapping banks as described in Technical Specification 3.10.4.
3. The control rod bank insertion limits are not violated.

4. Axial Power Distribution Control Procedures, which are given in terms of flux difference control and control bank insertion limits are observed. Flux difference refers to the difference in signals between the top and bottom halves of two-section excore neutron detectors. The flux difference is a measure of the axial offset which is defined as the difference in normalized power between the top and bottom halves of the core.

The permitted relaxation in $F_{\Delta H}^N$ allows radial power shape changes with rod insertion to the insertion limits. It has been determined that provided the above conditions 1 through 4 are observed, these hot channel factors limits are met. In Specification 3.10.2, F_Q is arbitrarily limited for $P \leq 0.5$ (except for low power physics tests).

The procedures for axial power distribution control referred to above are designed to minimize the effects of xenon redistribution on the axial power distribution during load-follow maneuvers. Basically, control of flux difference is required to limit the difference between the current value of Flux Difference (ΔI) and a reference value which corresponds to the full power equilibrium value of Axial Offset (Axial Offset = ΔI /fractional power). The referenced value of flux difference varies with power level and burnup but expressed as axial offset it varies only with burnup.

The technical specifications on power distribution control assure that F_Q upper bound envelope of F_Q^{RTP} times $K(Z)$ (specified in the COLR) is not exceeded and xenon distributions are not developed which at a later time, would cause greater local power peaking even though the flux difference is then within the limits specified by the procedure.

The target (or reference) value of flux difference is determined as follows. At any time that equilibrium xenon conditions have been established, the indicated flux difference is noted with the control rod bank more than 190 steps withdrawn (i.e. normal full power operating position appropriate for the time in life, usually withdrawn farther as burnup

proceeds). This value, divided by the fraction of full power at which the core was operating is the full power value of the target flux difference. Values for all other core power levels are obtained by multiplying the full power value by the fractional power. Since the indicated equilibrium value was noted, no allowances for excore detector error are necessary and the AFD deviation specified in the COLR is permitted from the indicated reference value. During periods where extensive load following is required, it may be impractical to establish the required core conditions for measuring the target flux difference every month. For this reason, the specification provides two methods for updating the target flux difference.

Strict control of the flux difference (and rod position) is not as necessary during part power operation. This is because xenon distribution control at part power is not as significant as the control at full power and allowance has been made in predicting the heat flux peaking factors for less strict control at part power. Strict control of the flux difference is not possible during certain physics tests or during required, periodic, excore calibrations which require larger flux differences than permitted. Therefore, the specifications on power distribution control are not applied during physics tests or excore calibrations; this is acceptable due to the low probability of a significant accident occurring during these operations.

In some instances of rapid plant power reduction, automatic rod motion will cause the flux difference to deviate from the target band when the reduced power level is reached. This does not necessarily affect the xenon distribution sufficiently to change the envelope of peaking factors which can be reached on a subsequent return to full power within the target band. However, to simplify the specification, a limitation of one hour in any period of 24 hours is placed on operation outside the band. This ensures that the resulting xenon distributions are not significantly different from those resulting from operation within the target band. The instantaneous consequences of being outside the band, provided rod insertion limits are observed, is not worse than a 10 percent increment in peaking factor for flux difference in the AFD range specified in the COLR.

If, for any reason, flux difference is not controlled within the AFD limit specified in the COLR for as long a period as one hour, then xenon distributions may be significantly changed and operation at 50 percent is required to protect against potentially more severe consequences of some accidents.

As discussed above, the essence of the procedure is to maintain the xenon distribution in the core as close to the equilibrium full power condition as possible. This is accomplished by using the boron system to position the control rods to produce the required indicated flux difference.

For FSAR Section 14.1 events, the core is protected from overpower and a minimum DNBR of the applicable safety limit DNBR by an automatic protection system. Compliance with operating procedures is assumed as a precondition for FSAR Section 14.1 events. However, operator error and equipment malfunctions are separately assumed to lead to the cause of the transients considered.

Quadrant power tilt limits are based on the following considerations. Frequent power tilts are not anticipated during normal operation, as this phenomenon is caused by some asymmetric perturbation, e.g., rod misalignment, or inlet temperature mismatch. A dropped or misaligned rod will easily be detected by the Rod Position Indication System or core instrumentation per Specification 3.10.6, and core limits are protected per Specification 3.10.5. A quadrant tilt by some other means would not appear instantaneously, but would build up over several hours and the quadrant tilt limits are met to protect against this situation. They also serve as a backup protection against the dropped or misaligned rod. Operational experience shows that normal power tilts are less than 1.01. Thus, sufficient time is available to recognize the presence of a tilt and correct the cause before a severe tilt could build up. During startup and power escalation, however, a large tilt could be initiated. Therefore, the Technical Specification has been written so as to prevent escalation above 50 percent power if a large tilt is present. The numerical limits are set to be commensurate with design and safety limits for DNB protection and linear heat generation rate as

described below.

The radial power distribution within the core must satisfy the design values assumed for calculation of power capability. Radial power distributions are measured as part of the startup physics testing and are periodically measured at a monthly or greater frequency. These measurements are taken to assure that the radial power distribution with any quarter core radial power asymmetry conditions are consistent with the assumptions used in power capability analyses. It is not intended that reactor operation would continue with a power tilt condition which exceeds the radial power asymmetry considered in the power capability analysis.

The quadrant tilt power deviation alarm is used to indicate a sudden or unexpected change from the radial power distribution mentioned above. The two percent tilt alarm setpoint represents a minimum practical value consistent with instrumentation errors and operating procedures. This asymmetry level is sufficient to detect significant misalignment of control rods. Misalignment of control rods is considered to be the most likely cause of radial power asymmetry. The requirement for verifying rod position once each shift is imposed to preclude rod misalignment which would cause a tilt condition less than the 2% alarm level.

The two hour time interval in this specification is considered ample to identify a dropped or misaligned rod and complete realignment procedures to eliminate the tilt. In the event that the tilt condition cannot be eliminated within the two hour time allowance, additional time would be needed to investigate the cause of the tilt condition. The measurements would include a full core physics map utilizing the moveable detector system. For a tilt condition ≤ 1.09 , an additional 22 hours time interval is authorized to accomplish these measurements. However, to assure that the peak core power is maintained below limiting values, a reduction of reactor power of three percent for each one percent of indicated tilt is required. Physics measurements have indicated that the core radial power peaking would not exceed a two to one relationship with the indicated tilt from the excore nuclear detector system for the worst rod misalignment.

In the event a tilt condition of ≤ 1.09 cannot be eliminated after 24 hours, the reactor power level will be reduced to the range required for low power physics testing. To avoid reset of a large number of protection setpoints, the power range nuclear instrumentation would be reset to cause an automatic reactor trip at 55% of allowed power. A reactor trip at this power has been selected to prevent, with margin, exceeding core safety limits even with a nine percent tilt condition.

If tilt ratio greater than 1.09 occurs which is not due to a misaligned rod, the reactor shall be brought to a hot shutdown condition for investigation. However, if the tilt condition can be identified as due to rod misalignment, operation can continue at a reduced power (3% for each one percent the tilt ratio exceeds 1.0) for two hours to correct the rod misalignment.

Trip shutdown reactivity is provided consistent with plant safety analysis assumptions. One percent shutdown is adequate except for steam break analysis, which requires more shutdown if the boron concentration is low. Figure 3.10-1 is drawn accordingly.

Rod insertion limits are used to assure adequate trip reactivity, to assure meeting power distribution limits, and to limit the consequence of a hypothetical rod ejection accident. The available control rod reactivity, or excess beyond needs, decreases with decreasing boron concentration because the negative reactivity required to reduce the core power level from full power to zero is largest when the boron concentration is low.

The intent of the test to measure control rod worth and shutdown margin (Specification 3.10.4) is to measure the worth of all rods less the worth of the worst case for an assumed stuck rod, that is, the most reactive rod. The measurement would be anticipated as part of the initial startup program and infrequency over the life of the plant, to be associated primarily with determinations of special interest such as end of life cooldown, or startup of fuel cycles which deviate from normal equilibrium conditions in terms of fuel loading patterns and anticipated control bank worth. These measurements will augment the normal fuel cycle design calculations and place the knowledge of shutdown capability on a firm experimental as well as analytical basis.

The rod position indicator channel is sufficiently accurate to detect a rod ± 7 inches away from its demand position. An indicated misalignment less than 12 steps does not exceed the power peaking factor limits. If the rod position indicator channel is not operable, the operator will be fully aware of the inoperability of the channel, and special surveillance of core power tilt indications, using established procedures and relying on excore nuclear detectors, and/or moveable incore detectors, will be used to verify power distribution symmetry. These indirect measurements do not have the same resolution if the bank is near either end of the core, because a 12 step misalignment would have no effect on power distribution. Therefore, it is necessary to apply the indirect checks following significant rod motion.

3.10-15

Amendment No. 34, 103

One inoperable control rod is acceptable provided that the power distribution limits are met, trip shutdown capability is available, and provided the potential hypothetical ejection of the inoperable rod is not worse than the cases analyzed in the safety analysis report. The rod ejection accident for an isolated fully inserted rod will be worse if the residence time of the rod is long enough to cause significant non-uniform fuel depletion. The 5 day period is short compared with the time interval required to achieve a significant, non-uniform fuel depletion.

The required drop time to dashpot entry is consistent with safety analysis.

REFERENCE

1. WCAP-8576, "Augmented Startup and Cycle 1 Physics Program:", August 1975
2. FSAR Appendix 14C
3. Letter from J.P. Bayne to S.A. Varga dated April 23, 1985, entitled "Proposed Technical Specifications Regarding the Cycle 4/5 Refueling".

TABLE 3.10-1

ACCIDENT ANALYSES REQUIRING REEVALUATION
IN THE EVENT OF AN INOPERABLE FULL
LENGTH ROD

Rod Cluster Control Assembly Insertion Characteristics

Rod Cluster Control Assembly Misalignment

Loss of Reactor Coolant From Small Ruptured Pipes Or From Cracks In Large Pipes Which Actuates The Emergency Core Cooling System

Single Rod Cluster Control Assembly Withdrawal At Full Power

Major Reactor Coolant System Pipe Ruptures (Loss of Coolant Accident)

Major Secondary System Pipe Rupture

Rupture of a Control Rod Drive Mechanism Housing (Rod Cluster Control Assembly Ejection)

ANNUAL REPORTS

6.9.1.5 A report of specific activity analysis results in which the primary coolant exceeded the limits of Specification 3.1.D. The following information shall be included: (1) Reactor power history starting 48 hours prior to the first sample in which the limit was exceeded; (2) Results of the last isotopic analysis for radioiodine performed prior to exceeding the limit, results of analysis while activity was reduced to less than limit. Each result should include date and time of sampling and the radioiodine concentrations; (3) Clean-up system flow history starting 48 hours prior to the first sample in which the limit was exceeded; (4) Data providing the I-131 concentration and one other radioiodine isotope concentration in microcuries per gram as a function of time for the duration of the specific activity above the steady-state level; and (5) The time duration when the specific activity of the primary coolant exceeded the radioiodine limit.

6.9.1.6 CORE OPERATING LIMITS REPORT

6.9.1.6.a Core operating limits shall be established and documented in the CORE OPERATING LIMITS REPORT before each reload cycle or any remaining part of a reload cycle for the following:

1. Axial Flux Difference limits for Specification 3.10.2.
2. Heat Flux Hot Channel Factor and K(2) for Specification 3.10.2.
3. Nuclear Enthalpy Rise Hot Channel Factor and Power Factor Multiplier for Specification 3.10.2.
4. Shutdown Bank Insertion Limit for Specification 3.10.4.
5. Control Bank Insertion Limits for Specification 3.10.4.

6.9.1.6.b The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by NRC in:

1. WCAP-9272-P-A, "WESTINGHOUSE RELOAD SAFETY EVALUATION METHODOLOGY," July 1985 (W Proprietary).
(Methodology for Specification 3.10.4 - Shutdown Bank Insertion Limit, Control Bank Insertion Limits and 3.10.2 - Nuclear Enthalpy Rise Hot Channel Factor.

- 2a. WCAP-8385, "POWER DISTRIBUTION CONTROL AND LOAD FOLLOWING PROCEDURES - TOPICAL REPORT", September 1974 (W Proprietary).
(Methodology for Specification 3.10.2 - Axial Flux Difference (Constant Axial Offset Control).)
- 2b. T. M. Anderson to K. Kneil (Chief of Core Performance Branch, NRC) January 31, 1980 -- Attachment: Operation and Safety Analysis Aspects of an Improved Load Follow Package.
(Methodology for Specification 3.10.2 - Axial Flux Difference (Constant Axial Offset Control).)
- 2c. NUREG-0800, Standard Review Plan, U.S. Nuclear Regulatory Commission, Section 4.3, Nuclear Design, July 1981. Branch Technical Position CPB 4.3-1, Westinghouse Constant Axial Offset Control (CAOC), Rev. 2, July 1981.
(Methodology for Specification 3.10.2 - Axial Flux Difference (Constant Axial Offset Control).)
- 3a. WCAP-9220-P-A, Rev. 1, "WESTINGHOUSE ECCS EVALUATION MODEL-1981 VERSION", February 1982 (W Proprietary).
(Methodology for Specification 3.10.2 - Heat Flux Hot Channel Factor.)
- 3b. WCAP-9561-P-A ADD. 3, Rev. 1, "BART A-1: A COMPUTER CODE FOR THE BEST ESTIMATE ANALYSIS OF REFLOOD TRANSIENTS - SPECIAL REPORT: THIMBLE MODELING W ECCS EVALUATION MODEL," July 1986, (W Proprietary).
(Methodology for Specification 3.10.2 - Heat Flux Hot Channel Factor.)
- 3c. WCAP-10266-P-A Rev. 2, "THE 1981 VERSION OF WESTINGHOUSE EVALUATION MODEL USING BASH CODE", March 1987, (W Proprietary).
(Methodology for Specification 3.10.2 - Heat Flux Hot Channel Factor.)

6.9.1.6.c The core operating limits shall be determined so that all applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and accident analysis limits) of the safety limits are met.

6.9.1.6.d The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance, for each reload cycle, to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.

SPECIAL REPORTS

6.9.2 Special reports shall be submitted to the Regional Administrator-Region 1 within the time period specified for each report. These reports shall be submitted covering the activities identified below pursuant to the requirements of the applicable reference specification;

- a. Sealed source leakage on excess of limits (Specification 3.9)
- b. Inoperable Seismic Monitoring Instrumentation (Specification 4.10)
- c. Seismic event analysis (Specification 4.10)
- d. Inoperable plant vent sampling, main steam line radiation monitoring or effluent monitoring capability (Table 3.5-4, items 5, 6 and 7)
- e. The complete results of the steam generator tube inservice inspection (Specification 4.9.C)
- f. Inoperable fire protection and detection equipment (Specification 3.14)
- g. Release of radioactive effluents in excess of limits (Appendix B Specifications 2.3, 2.4, 2.5, 2.6)
- h. Inoperable containment high-range radiation monitors (Table 3.5-5, Item 24)
- i. Radioactive environmental sampling results in excess of reporting levels (Appendix B Specification 2.7, 2.8, 2.9)
- j. Operation of Overpressure Protection System (Specification 3.1.A.8.c.)

6.10 RECORD RETENTION

6.10.1 The following records shall be retained for at least five years:

- a. Records and logs of facility operation covering time interval at each power level.
- b. Records and logs of principal maintenance activities, inspection, repair and replacements of principal items of equipment related to nuclear safety.
- c. All REPORTABLE EVENTS submitted to the Commission.

- d. Records of surveillance activities, inspections and calibrations required by these Technical Specifications.
- e. Records of changes made to Operating Procedures.
- f. Records of radioactive shipments.
- g. Records of sealed source and fission detector leak tests and results.
- h. Records of annual physical inventory of all source material of record.
- i. Records of reactor tests and experiments.

6.10.2 The following records shall be retained for the duration of the Facility Operating License:

- a. Records of any drawing changes reflecting facility design modifications made to systems and equipment described in the Final Safety Analysis Report.
- b. Records of new and irradiated fuel inventory, fuel transfers and assembly burnup histories.
- c. Records of facility radiation and contamination surveys.
- d. Records of radiation exposure for all individuals entering radiation control areas.
- e. Records of gaseous and liquid radioactive material released to the environs.
- f. Records of transient or operational cycles for those facility components designed for a limited number of transient cycles.
- g. Records of training and qualifications for current members of the plant staff.
- h. Records of in-service inspections performed pursuant to these Technical Specifications.
- i. Records of Quality Assurance activities required by the QA manual.
- j. Records of reviews performed for changes made to procedures or equipment or reviews of tests and experiments pursuant to 10 CFR 50.59.

- k. Records of meetings of the PORC and the SRC.
- l. Records for Environmental Qualification which are covered under the provisions of paragraph 6.13.
- m. Records of secondary water sampling and water quality.
- n. Records of analyses required by the radiological environmental monitoring program that would permit evaluation of the accuracy of the analysis at a later date. This should include procedures effective at specified times and records showing that these procedures were followed.
- o. Records of service lives of all safety-related hydraulic snubbers including the date at which the service life commences and associated installation and maintenance records.

6.11 RADIATION AND RESPIRATORY PROTECTION PROGRAM

6.11.1 Procedures for personnel radiation protection shall be prepared consistent with the requirements of 10 CFR Part 20 and shall be approved maintained and adhered to for all operations involving personnel radiation exposure as to maintain exposures as far below the limits specified in 10 CFR Part 20 as reasonable achievable. Pursuant to 10 CFR 20.103 allowance shall be made for the use of respiratory protective equipment in conjunction with activities authorized by the operating license for this plant in determining whether individuals in restricted areas are exposed to concentrations in excess of the limits specified in Appendix B, Table I, Column 1 of 10 CFR 20.

6.12 HIGH RADIATION AREA

6.12.1 In lieu of the "control device" or "alarm signal" required by paragraph 20.203 (c) (2) of 10-CFR 20, each high radiation area in which the intensity of radiation is 1000 mrem/hr or less and 100 mrem/hr or greater shall be barricaded and conspicuously posted as a high radiation area and entrance thereto shall be controlled by requiring issuance of a Radiation Work Permit*. Any individual or group of individuals permitted to enter such areas shall be provided or accompanied by one or more of the following:

- a. A radiation monitoring device which continuously indicates the radiation dose rate in the area.
- b. A radiation monitoring device which continuously integrates the radiation dose rate in the area and alarms when a preset integrated dose is received. Entry into such areas with this monitoring device may be made after the dose rate level in the area has been established and personnel have been made knowledgeable of them.
- c. An individual qualified in radiation protection procedure who is equipped with a radiation dose rate monitoring device. This individual shall be responsible for providing positive control over the activities within the area and shall perform periodic radiation surveillance at the frequency specified by the facility Health Physicist in the Radiation Work Permit.

6.12.2 The requirements of 6.12.1, above, shall also apply to each high radiation area in which the intensity of radiation is greater than 1000 mrem/hr. In addition, locked doors shall be provided to prevent unauthorized entry into such areas and the keys shall be maintained under the administrative control of the Shift Supervisor on duty and/or the plant Radiological and Environmental Superintendent or his designee.

*Health Physics Personnel shall be exempt from the RWP issuance requirements for entries into high radiation areas during the performances of their assigned radiation protection duties, provided they comply with approved radiation protection procedures for entry into high radiation areas.

6.13 ENVIRONMENTAL QUALIFICATION

6.13.1 Environmental qualification of electric equipment important to safety shall be in accordance with the provisions of 10CFR 50.49. Pursuant to 10 CFR 50.49, Section 50.49 (d), the EQ Master List identifies electrical equipment requiring environmental qualification.

6.13.2 Complete and auditable records which describe the environmental qualification method used, for all electrical equipment identified in the EQ Master List, in sufficient detail to document the degree of compliance with the appropriate requirements of 10 CFR 50.49 shall be available and maintained at a central location. Such records shall be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 103 TO FACILITY OPERATING LICENSE NO. DPR-64
POWER AUTHORITY OF THE STATE OF NEW YORK
INDIAN POINT NUCLEAR GENERATING UNIT NO. 3
DOCKET NO. 50-286

INTRODUCTION

By letter dated June 21, 1990 (Ref. 1), as supplemented July 27, 1990 (Ref. 2), the Power Authority of the State of New York (the licensee) proposed changes to the Technical Specifications (TS) for the Indian Point Nuclear Generating Unit No. 3. The proposed changes would modify TS having cycle-specific parameter limits by replacing the values of those limits with a reference to a Core Operating Limits Report (COLR) for the values of those limits. The proposed changes also include the addition of the COLR to the Definitions section and to the reporting requirements of the Administrative Controls section of the TS. Guidance on the proposed changes was developed by the NRC on the basis of the review of a lead-plant proposal submitted on the Oconee plant docket by Duke Power Company. This guidance was provided to all power reactor licensees and applicants by Generic Letter 88-16, dated October 4, 1988 (Ref. 3).

The licensee's letter dated July 27, 1990, provided a TS page on which a referenced figure was replaced by a reference to the COLR. This change is within the scope of the action noted and did not affect the initial no significant hazards determination published in the Federal Register on July 25, 1990.

EVALUATION

The licensee's proposed changes to the TS are in accordance with the guidance provided by Generic Letter 88-16 and are addressed below.

- (1) The Definition section of the TS was modified to include a definition of the COLR that requires cycle/reload-specific parameter limits to be established on a unit-specific basis in accordance with NRC-approved methodologies that maintain the limits of the safety analysis. The definition notes that plant operation within these limits is addressed by individual specifications.

- (2) The following specifications were revised to replace the values of cycle-specific parameter limits with a reference to the COLR that provides these limits.

(a) Specification 2.1

The nuclear enthalpy rise hot channel factor (F-delta-H) limit at rated thermal power and the power factor multiplier (PF-delta-H) for this specification are specified in the COLR.

(b) Specification 3.10.2.1

The total peaking factor (F_0) limit at rated thermal power, the K(Z) fraction, the nuclear enthalpy rise hot channel factor (F-delta-H) limit at rated thermal power, and the power factor multiplier for this specification are specified in the COLR.

(c) Specifications 3.10.2.4 and 3.10.2.6.1

The axial flux difference limits and target band for these specifications are specified in the COLR.

(d) Specification 3.10.4.1

The shutdown bank insertion limit for this specification is specified in the COLR.

(e) Specification 3.10.4.2

The control bank insertion limits for this specification are specified in the COLR.

The Bases of affected specifications have been modified by the licensee to include appropriate reference to the COLR. Based on our review, the staff concludes that the changes to these Bases are acceptable.

- (3) Specification 6.9.1.6, COLR, has been added as additional reporting requirements of the Administrative Controls section of the TS. This specification requires that the COLR be documented before each reload cycle or any remaining part of a reload cycle if specified parameters change, and, upon issuance, submitted to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector. The report provides the values of cycle-specific parameter limits that are applicable for the current fuel cycle. Furthermore, these specifications require that the values of these limits be established using NRC-approved methodologies.

The approved methodologies are the following:

- (a) WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985 (W Proprietary).

(Methodology for Specification 3.10.4 - Shutdown Bank Insertion Limit, Control Bank Insertion Limits and Specification 3.10.2 - Nuclear Enthalpy Rise Hot Channel Factor.)

- (b) WCAP-8385, "Power Distribution Control and Load Following Procedures - Topical Report," September 1974 (W Proprietary).

(Methodology for Specification 3.10.2 - Axial Flux Difference [Constant Axial Offset Control].)

- (c) T.M. Anderson to K. Kniel (Chief of Core Performance Branch, NRC) January 31, 1980 -- Attachment: Operation and Safety Analysis Aspects of an Improved Load Follow Package.

(Methodology for Specification 3.10.2 - Axial Flux Difference [Constant Axial Offset Control].)

- (d) NUREG-0800, Standard Review Plan, U.S. Nuclear Regulatory Commission, Section 4.3, Nuclear Design, July 1981. Branch Technical Position CPB 4.3-1, Westinghouse Constant Axial Offset Control (CAOC), Rev. 2, July 1981.

(Methodology for Specification 3.10.2 - Axial Flux Difference [Constant Axial Offset Control].)

- (e) WCAP-9220-P-A, Rev. 1, "Westinghouse ECCS Evaluation Model - 1981 - Version," February 1982 (W Proprietary).

(Methodology for Specification 3.10.2 - Heat Flux Hot Channel Factor.)

- (f) WCAP-9561-P-A Add. 3, Rev. 1, "BART A-1: Computer Code for the Best Estimate Analysis of Reflood Transients - Special Report: Thimble Modeling W ECCS Evaluation Model," July 1986 (W Proprietary).

(Methodology for Specification 3.10.2 - Heat Flux Hot Channel Factor.)

- (g) WCAP-10266-P-A, Rev. 2, "The 1981 Version of Westinghouse Evaluation Model Using BASH Code," March 1987, (W Proprietary).

(Methodology for Specification 3.10.2 - Heat Flux Hot Channel Factor.)

On the basis of a review of the above items, the NRC staff concludes that the licensee provided an acceptable response to those items addressed in the NRC guidance provided in Generic Letter 88-16 for modifying cycle-specific parameter limits in the TS. Because plant operation continues to be limited in accordance with the values of cycle-specific parameter limits that are established using NRC-approved methodologies, the NRC staff concludes that this change is administrative in nature and there is no impact on plant safety as a consequence. Accordingly, the staff finds that the proposed changes are acceptable.

As part of the implementation of Generic Letter 88-16, the staff has also reviewed a sample COLR which was provided by the licensee. On the basis of this review, the staff concludes that the format and content of the sample COLR are acceptable.

The Table of Contents, page iv, and List of Figures page were also modified to reflect the replacement of cycle specific parameters with references to the COLR. These changes are purely administrative and are, therefore, found to be acceptable.

SUMMARY

The staff has reviewed the request by the licensee to modify the TS of the Indian Point Nuclear Generating Unit No. 3 that would remove the specific values of certain cycle-specific parameters and place the values in a Core Operating Limits Report that would be referenced by the TS. Based on the above, the staff concludes that these TS modifications are acceptable.

ENVIRONMENTAL CONSIDERATION

This amendment involves a change to a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes to reporting or recordkeeping requirements. The staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9) and (c)(10). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

CONCLUSION

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Dated: September 11, 1990

PRINCIPAL CONTRIBUTOR:

Tom Rotella, Reactor Systems Branch

REFERENCES

1. Letter (IPN-90-034) from J. C. Brons (NYPA) to U.S. NRC, dated June 21, 1990.
2. Letter (IPN-90-042) from J. C. Brons (NYPA) to U.S. NRC, dated July 27, 1990.
3. Generic Letter 88-16, "Removal of Cycle-Specific Parameter Limits from Technical Specifications," dated October 4, 1988.