

December 22, 2000

Mr. David A. Christian
Sr. Vice President and
Chief Nuclear Officer
Innsbrook Technical Center-2SW
5000 Dominion Blvd.
Glen Allen, Virginia 23060-6711

SUBJECT: NORTH ANNA POWER STATION, UNITS 1 AND 2: REQUEST FOR
ADDITIONAL INFORMATION RELATED TO THE PROPOSED TECHNICAL
SPECIFICATION CHANGES FOR THE ELIMINATION OF SEISMIC EFFECTS
FROM CONTROL ROD DROP TIMES (TAC NOS. MA9357 AND MA9358)

Dear Mr. Christian:

The purpose of this letter is to request additional information so the staff may continue to review your license amendment dated June 22, 2000, regarding the elimination of seismic effects from the control rod drop times.

Our questions are provided in the Enclosure. This inquiry was discussed with Mr. Tom Shaub of your licensing staff on December 12, 2000, and he agreed to provide a response within 30 days of the date of this letter.

Sincerely,

/RA/

Stephen R. Monarque, Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-338 and 50-339

Enclosure: Request for Additional Information

cc w/encl: See next page

December 22, 2000

Mr. David A. Christian
Sr. Vice President and
Chief Nuclear Officer
Innsbrook Technical Center-2SW
5000 Dominion Blvd.
Glen Allen, Virginia 23060-6711

SUBJECT: NORTH ANNA POWER STATION, UNITS 1 AND 2: REQUEST FOR
ADDITIONAL INFORMATION RELATED TO THE PROPOSED TECHNICAL
SPECIFICATION CHANGES FOR THE ELIMINATION OF SEISMIC EFFECTS
FROM CONTROL ROD DROP TIMES (TAC NOS. MA9357 AND MA9358)

Dear Mr. Christian:

The purpose of this letter is to request additional information so the staff may continue to review your license amendment dated June 22, 2000, regarding the elimination of seismic effects from the control rod drop times.

Our questions are provided in the Enclosure. This inquiry was discussed with Mr. Tom Shaub of your licensing staff on December 12, 2000, and he agreed to provide a response within 30 days of the date of this letter.

Sincerely,

/RA/

Stephen R. Monarque, Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-338 and 50-339

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION:

YOrechwa	PDII-1 Rdg. (paper copy)	RidsOgcRp
FAkstulewicz	RidsNrrDlpmLpdii-1 (paper copy)	RidsAcrrAcnwMailCenter
DO'Neal	EDunnington (paper copy)	RidsRgn2MailCenter
PUBLIC	SMonarque (paper copy)	MChatterton

Accession Number ML003780122

OFFICE	PM:PDII/S1	C	LA :PDII/S2		SC:PDII/S1	
NAME	SMonarque:cn		EDunnington		REmch	
DATE	12/21/00		12/20/00		12/21/00	

OFFICIAL RECORD COPY

Mr. David A. Christian
Virginia Electric and Power Company

North Anna Power Station
Units 1 and 2

cc:

Mr. C. Lee Lintecum
County Administrator
Louisa County
P.O. Box 160
Louisa, Virginia 23093

Mr. W. R. Matthews
Site Vice President
North Anna Power Station
P.O. Box 402
Mineral, Virginia 23117

Mr. Donald P. Irwin, Esquire
Hunton and Williams
Riverfront Plaza, East Tower
951 E. Byrd Street
Richmond, Virginia 23219

Mr. E. S. Grecheck
Site Vice President
Surry Power Station
Virginia Electric and Power Company
5570 Hog Island Road
Surry, Virginia 23883

Dr. W. T. Lough
Virginia State Corporation
Commission
Division of Energy Regulation
P.O. Box 1197
Richmond, Virginia 23209

Robert B. Strobe, M.D., M.P.H.
State Health Commissioner
Office of the Commissioner
Virginia Department of Health
P. O. Box 2448
Richmond, Virginia 23218

Old Dominion Electric Cooperative
4201 Dominion Blvd.
Glen Allen, Virginia 23060

Mr. J. H. McCarthy, Manager
Nuclear Licensing & Operations Support
Virginia Electric and Power Company
Innsbrook Technical Center
5000 Dominion Blvd.
Glen Allen, Virginia 23060

Office of the Attorney General
Commonwealth of Virginia
900 East Main Street
Richmond, Virginia 23219

Senior Resident Inspector
North Anna Power Station
U.S. Nuclear Regulatory Commission
1024 Haley Drive
Mineral, Virginia 23117

REQUEST FOR ADDITIONAL INFORMATION
NORTH ANNA POWER STATION, UNITS 1 AND 2
PROPOSED TECHNICAL SPECIFICATION CHANGES TO ELIMINATE
SEISMIC EFFECTS FROM CONTROL ROD DROP TIMES

	Initial Operation with drop time restriction <u>≤ 2.2 (sec.)</u>	Current Operation with drop time restriction <u>≤ 2.7 (sec.)</u>	Operation with <u>new fuel design</u>
Nominal measured <u>drop time (sec.)</u>			
Uncertainty in nominal measured <u>drop time (sec.)</u>			
Component nominal measured drop time due to the new <u>design (sec.)</u>	NA	NA	
Component of the uncertainty in the nominal measured drop time due to the <u>new design (sec.)</u>	NA	NA	
Seismic allowance <u>(sec.)</u>			
Drop time used in <u>surveillance (sec.)</u>			
Drop time used in the safety analysis <u>(sec.)</u>			
Give the bounding transient for the <u>safety analysis</u>			

Please fill in the table and give the algorithm for computing the numerical value for each of the components of the rod drop time identified in the first column. For historical data (i.e., drop times limited by 2.2 and 2.7 sec.) choose a representative reload. Where the values are assumed, provide a justification.