

February 3, 2012

NG-12-0054 10 CFR 50.90

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555-0001

Duane Arnold Energy Center Docket No. 50-331 Renewed Op. License No. DPR-49

Supplement to an Application to Adopt Technical Specifications Task Force
Traveler TSTF-425, Revision 3, to Relocate Specific Surveillance Frequencies to
a Licensee Controlled Program

References:

- License Amendment Request (TSCR-120): Application for Technical Specification Change Regarding Risk-Informed Justification for the Relocation of Specific Surveillance Frequency Requirements to a Licensee Controlled Program (TSTF-425, Rev. 3), NG-11-0037, dated February 23, 2011
- 2) Response to Request for Additional Information Related to an Amendment to Adopt Technical Specifications Task Force Traveler TSTF-425, Revision 3, to Relocate Specific Surveillance Frequencies to a Licensee Controlled Program, NG-11-0299, dated August 15, 2011
- 3) Supplemental Information to an Application to Adopt Technical Specifications Task Force Traveler TSTF-425, Revision 3, to Relocate Specific Surveillance Frequencies to a Licensee Controlled Program, NG-12-0034, January 19, 2012

In the Reference 1 letter, as modified by Reference 2, NextEra Energy Duane Arnold, LLC (hereafter NextEra Energy Duane Arnold) requested a revision to the Technical Specifications (TS) for the Duane Arnold Energy Center (DAEC) pursuant to 10 CFR 50.90. In the referenced correspondence, NextEra Energy Duane Arnold provided marked-up pages from the current DAEC TS indicating the requested changes. It has subsequently been discovered that one TS page was inadvertently omitted from those marked-up pages in the original application. Attached is the missing marked-up page. The requested change to this TS page was intended to be included in the original application, as noted by the



Document Control Desk February 3, 2012 Page 2 of 2

corresponding revised Bases page being in Attachment 4 of Reference 1, as well as the requested change being included in the Table in Attachment 5.

The corresponding clean, typed page was included with those submitted by Reference 3.

This letter makes no new commitments or changes to any existing commitments.

If you have any questions or require additional information, please contact Steve Catron at 319-851-7234.

I declare under penalty of perjury that the foregoing is true and correct. Executed on February 3, 2012

Pe**le**r Wells

Vice President, Duane Arnold Energy Center NextEra Energy Duane Arnold, LLC

Attachment: Proposed Technical Specification Change (Marked-up Page)

cc: NRC Regional Administrator

NRC Resident Inspector NRC Project Manager

M. Rasmusson (State of Iowa)

PROPOSED TECHNICAL SPECIFICATION CHANGE (MARK-UPS)

ACTIONS (continued)

	CONDITION	F	REQUIRED ACTION	COMPLETION TIME
C.	No RHR shutdown cooling subsystem in operation with reactor coolant temperature ≥ 150°F.	C.1	Verify reactor coolant circulation by an alternate method.	1 hour from discovery of no reactor coolant circulation AND
		AND		Once per 12 hours thereafter
		C.2	Monitor reactor coolant temperature.	Once per hour

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.9.7.1	Verify one RHR shutdown cooling subsystem is operating when reactor coolant temperature is ≥ 150 °F.	12-hours-INSERT 1

INSERT 1 (from Reference 1 to NG-12-0054):

In accordance with the Surveillance Frequency Control Program

TSCR-120

DAEC 3.9-12 Amendment 223-