

PUBLIC SUBMISSION

As of: February 08, 2012
 Received: February 07, 2012
 Status: Pending_Post
 Tracking No. 80faffee
 Comments Due: March 01, 2012
 Submission Type: Web

Docket: NRC-2012-0022
 State-of-the-Art Reactor Consequence Analyses Reports

Comment On: NRC-2012-0022-0005
 State-of-the-Art Reactor Consequence Analyses Reports

Document: NRC-2012-0022-DRAFT-0013
 Comment on FR Doc # 2012-02313

77 FR 5281

(8)

2/2/12

RECEIVED

2012 FEB - 8 AM 9:24

FILES AND ETCIMES

Submitter Information

Name: Thomas Gurdziel

General Comment

Item 13

On page 52 of 133 is a comment that portable generators also provide electrical power needed to operate safety relief valves. My understanding is that portable generators provide Alternating Current; our Electromatic relief valve pilot valves needed Direct Current.

Item 14

On page 54 of 133 is a comment about using portable air bottles to open air operated valves. How dependable is this method considering the Fukushima Daiichi experience while attempting to vent their primary containments? (Ref. INPO Report 11-005, p. 77,78,83,88, and especially p. 89 for 15 Mar 0002 hr,)

SUNSI Review Complete

Template = ADM-013

E-RIDS = ADM-03

Add = P. Santiago (PAS2)

J. Barr (JXB7)