

PUBLIC SUBMISSION

As of: February 10, 2012
Received: February 09, 2012
Status: Pending_Post
Tracking No. 80fb1be1
Comments Due: March 01, 2012
Submission Type: Web

Docket: NRC-2012-0022
State-of-the-Art Reactor Consequence Analyses Reports

Comment On: NRC-2012-0022-0005
State-of-the-Art Reactor Consequence Analyses Reports

Document: NRC-2012-0022-DRAFT-0014
Comment on FR Doc # 2012-02313

RECEIVED

2012 FEB 10 AM 9:10

RULES AND DIRECTIVES
PART 1
1/1/12

Submitter Information

Name: Thomas Gurdziel

2/2/2012

77 FR 5281

General Comment

9

Item 15

How confident are you that the blackrun of RCIC after station battery exhaustion (in a Station Blackout) can continue to cool the core? (Ref. p. 53 of 133) Considering the eventual condition that you are taking a suction from the torus water, how long can this be done before the higher torus water temperature disables the RCIC pump or its ability to pump due to inadequate net positive suction head (or NPSH)?

*SUNSF Review Complete
Template = ADM-013*

*E-RIDS = ADM-03
Cdd = P. Santiago (p952)
J. Barr (5x67)*