

42

## Boyle, Patrick

---

**From:** Martin, Robert *MR*  
**Sent:** Thursday, August 25, 2011 7:14 AM  
**To:** Kulesa, Gloria; Lund, Louise; Boyle, Patrick  
**Subject:** FW: NAPS Thurs morning status

From the NRC Senior Resident

---

**From:** Kolcum, Gregory  
**Sent:** Thursday, August 25, 2011 4:29 AM  
**To:** Martin, Robert  
**Subject:** NAPS Thurs morning status

Unit 1:

- containment open, shutdown cooling with RHR, PT 39.7 recovery from seismic event

Unit 2:

- AFW maintaining S/G level, PT 39.7 recovery from seismic event

Earthquake of 4.5 magnitude was experienced at North Anna this morning at 0108. Site entered a NOUE (HU1.1) for the aftershock felt in the control room as confirmed by USGS. Residents responded to the site. The licensee is continuing with their seismic response procedure (AP-36). Walkdowns in process. No equipment problems identified.

In addition, the licensee is monitoring the storm track of hurricane Irene and is evaluating the storm preps required.

M. Speck onsite for EP inspection. Joe Brady onsite for support.

HQ personnel with seismic and civil engineering to be onsite today at noon thru Friday.

*Gregory Kolcum  
Senior Resident Inspector  
Region II, Division of Reactor Projects  
U.S. Nuclear Regulatory Commission*

---

*North Anna Power Station      Office: 540-894-5421  
P. O. Box 490                      Fax: 540-894-5650  
Mineral VA 23117*

*D/41*