

Bozin, Sunny

From: Bowman, Gregory - EDO
Sent: Tuesday, August 30, 2011 11:54 AM
To: Hipschman, Thomas; Marshall, Michael; Castleman, Patrick; Sosa, Belkys; Gilles, Nanette; Orders, William; Nieh, Ho; Franovich, Mike
Subject: FYI - Revised Slides on North Anna/GI-199
Attachments: GI 199.pptx; North Anna Earthquake.pptx

Subsequent to my sending the slides on North Anna this morning, the staff decided to make some changes to both presentations. The attached two presentations represent what they'll be using for the briefings. Sorry for the multiple e-mails on this.

Greg

From: Bowman, Gregory
Sent: Tuesday, August 30, 2011 10:17 AM
To: Hipschman, Thomas; Marshall, Michael; Castleman, Patrick; Gilles, Nanette; Orders, William; Franovich, Mike
Subject: FYI - Slides on North Anna/GI-199

The attached slide presentations will be used for upcoming briefings for individual Commissioners on GI-199 and earthquake impacts at North Anna. I'm passing these along for information only. If you have any questions, please let me know.

Greg



Generic Safety Issue 199 Briefing

Presentation to the Commissioners
August 30 and September 1, 2011

NRK


Generic Issues Program Stages

1. Identification
2. Acceptance
3. Screening
4. Safety/Risk Assessment
 - Issue Analyzed
 - Paneled, Report Issued
 - Recommendations Endorsed
5. Regulatory Assessment

Genesis of GI-199

- **During reviews of COL and ESP applications, NRC staff identified increased seismic hazard estimates that may result in a greater likelihood of exceeding the safe shutdown earthquake (SSE) at operating nuclear power plants in the CEUS.**

What is GI-199 About?



GI-199 Safety/Risk Assessment

Safety/Risk Assessment Stage Goals:

- Determine, if risk associated with GI-199 warrants further investigation for potential imposition of cost-justified backfits.
- Provide recommendation for the next step, i.e. continue to the Reg. Assessment stage for identification of potential, cost-justified backfits, be dropped due to low risk, or have other actions taken outside the GIP.


GI-199 Safety/Risk Assessment

Performed Two Tasks:

1. Compared updated seismic hazard estimates (USGS and ESP/COL) to design (SSE) and previous review levels (IPEEE-RLE).
2. Evaluated changes in seismic risk metric (SCDF) consistent with MD 6.4.

Performed for all 96 NPPs in CEUS


Task 2: Evaluated Changes in SCDF



Do We Need to Consider Backfits?

Cost-Justified Backfits That Provide Substantial Safety Enhancements Safety Goal Evaluation Screening Criteria (NUREG/BR-0058)

Distribution of GI-199
Safety/Risk
Assessment Results



Change in CDF From Proposed Backfit	1E-3	Proceed to value/impact portion of regulatory analysis	Proceed to value/impact portion of regulatory analysis (priority)
	1E-4	Management decision whether to proceed with value/impact portion of regulatory analysis	Proceed to value/impact portion of regulatory analysis
	1E-5	No action taken	Management decision whether to proceed with value/impact portion of regulatory analysis
	1E-6		
		1E-1	
		Conditional Containment Failure Probability	

Staff Developing Generic Letter

- Individual Plant Examination for External Events (IPEEE) provided initial basis for current assessment
- GI-199 Safety/Risk assessment provided the basis to proceed with the GL in accordance with GIP


Regulatory Insight

- No imminent seismic safety concern
- Current data indicates the probability for ground shaking above the seismic design basis in CEUS has increased
- GI-199 Safety/Risk assessment indicated changes in SCDF estimates for some plants lie in the 10^{-5} to 10^{-4} per year; meets risk criteria to continue to regulatory assessment stage of the GIP
- Approach to estimate SCDF in GI-199 extrapolated from IPEEE submittals, but lacked insight which SSC important to seismic risk
- Information needed as basis for considering potential plant backfits commensurate with reduction of seismic risk

Expected Information from Generic Letter

Requested Response:

- Within 90 days, provide results of action taken to eliminate or reduce plant seismic vulnerabilities (anomalies, outliers & other findings) identified by IPEEE
- Within 180 days, provide seismic hazard curves over a range of spectral frequencies, and site specific GMRS and SSE
- Within 1 year (SMA), provide description of methodology to quantify seismic margin HCLPF capabilities of SSC, detailed list of SSC seismic margin values, bases for screening SSCs, description of the SMA and its logic models,..etc.
- Within 2 years (SPRA), provide significant contributors to SCDF, methodologies to estimate SCDF (e.g. seismic fragilities of SSC, dominant failure modes, location of components), findings from walk-downs



North Anna Nuclear Power Plant Seismic Event

Presentation to the Commissioners
August 30 and September 1, 2011

North Anna Design Basis

- North Anna Nuclear Power Plant (NANPP) has two Design Basis Earthquake (DBE)* values
- Structures, systems, and components (SSCs) founded on top of rock anchored at 0.12 g and SSCs founded on top of soil anchored at 0.18 g
- NANPP has two corresponding Operating Basis Earthquake (OBE) values, anchored at 0.06 g for rock and 0.09 g for soil (OBE is $\frac{1}{2}$ of the DBE)

* Design Basis Earthquake means the same as Safe Shutdown Earthquake

Sequence of Events

- On August 23, 2011, North Anna Power Station declared an Alert due to significant seismic activity onsite from an earthquake which had a measured magnitude of 5.8.
- The licensee conducted the 1st general walkdown of the plant as required by the North Anna Power Station abnormal procedure for seismic event.
- The licensee conducted the 2nd walkdown after the magnitude 4.5 aftershock.
- Seismic Response Spectrum Recorder (scratch plate) readings identified that the Design Basis Earthquake had been exceeded at certain frequencies.
- On August 26, the licensee declared all safety-related SSCs of Units 1 and 2 inoperable and issued a 10 CFR 72 Notification


History Of Seismic Events

- Exceedance of the DBE is an unprecedented event at an operating unit
- While Perry Unit was under construction, an earthquake occurred that exceeded SSE at high frequency (15hz)
 - A special safety inspection was conducted by the NRC's Region III Staff on February 5-7, 1986. See Inspection Reports 50-440/86005 and 50-440/86006. This included a post-earthquake walkdown and visual inspection of an extensive list of safety-related systems and components.

Regulatory Requirements

- Appendix A to Part 100—Paragraph V(a)(2) states, *"If vibratory ground motion exceeding that of the Operating Basis Earthquake occurs, shutdown of the nuclear power plant will be required."*
 - *Prior to resuming operations, the licensee will be required to demonstrate to the Commission that no functional damage occurred to those features necessary for continued operation without undue risk to the health and safety of the public."*
- *10 CFR 50.54 (ff) contains similar language for Appendix S plants. (Appendix S applies to Part 52 applicants and operating reactor construction permits submitted on or after Jan. 10, 1997)*
- Director of NRR will authorize restart

Staff Initial Assessment



Licensee Initial Assessments

- Licensee's evaluation of seismic instruments indicate that the SSE was exceeded at some frequencies
- Information from NANPP's seismic recordings will be utilized by the staff to assist in the assessment of the licensee's operability determination

Augmented Inspection Team

- AIT was dispatched today, which will be conducted in accordance with MD 8.3, "NRC Incident Investigation Program."
- Objectives of the AIT include:
 - Collect, analyze and document factual information and evidence
 - Assess licensee's actions and plant equipment response during the earthquake and aftershocks
 - Conduct independent extent of condition review
 - Collect information to support final determination of risk significance of event
 - Identify generic issues associated with the event

Other Potentially Affected Plants

- The list below provides the plants and the associated distance from the Epicenter:
 - North Anna is 18 km from the Epicenter
 - Surry is 139 km from the Epicenter
 - Calvert Cliffs is 141 km from the Epicenter
- NRR will confirm that the OBE was not exceeded at Surry and Calvert Cliffs.