

Boyle, Patrick

71

**From:** Boyle, Patrick *mm*  
**Sent:** Friday, September 02, 2011 7:03 AM  
**To:** Martin, Robert  
**Subject:** RE: FYI: NA status Sept 1 from RII PITA

Do I remember correctly that the 1H EDG is a swing diesel?

**From:** Martin, Robert *mm*  
**Sent:** Thursday, September 01, 2011 3:38 PM  
**To:** Glitter, Joseph; Kulesa, Gloria; Boyle, Patrick  
**Cc:** Wilson, George  
**Subject:** FYI: NA status Sept 1 from RII PITA

**North Anna**

**Unit 1 Status:** Mode 5 - Yellow - 150deg - 125#

**Unit 2 Status:** Mode 5 - Yellow - 150deg - 125#

**Risk Significant / Emergent Activities:** Common: - NOUE event declared 0518, 9/1. Licensee entered appropriate AP, residents are following licensee's activities. - Seismic walkdowns in progress, systems U1 - 48% complete, U2 - 32% complete, structures 52% complete

Unit 1: - Yellow for Containment Closure - Repairs continue on Unit 1 main transformers - 1H EDG scheduled for coolant gasket inspection today

Unit 2: - Yellow for Containment Closure - RFO prep activities

**Site Visits:** - AIT activities continue

**Other:** - Licensee hosting media tour tomorrow, 9/2 (Reuters and Bloomberg) - EP baseline exit scheduled for 1430 today (phone).

*D*  
*70*