

**Martin, Robert**

---

85/84

**From:** Clifford, Paul *NRK*  
**Sent:** Wednesday, September 07, 2011 9:42 AM  
**To:** Martin, Robert  
**Cc:** Mendiola, Anthony  
**Subject:** Restart of North Anna Units

DSS has serious reservations concerning the future use of fuel assemblies which experienced the seismic event at North Anna. If the ground motion and lateral acceleration of the seismic event exceeded the OBE, then the fuel assemblies would be in an unanalyzed condition. We need to be involved in any decisions regarding re-starting those units with re-inserted fuel bundles.

Paul M. Clifford  
Sr. Technical Advisor for Reactor Fuel  
U.S. Nuclear Regulatory Commission  
NRR/ADES/DSS  
Email: [Paul.Clifford@nrc.gov](mailto:Paul.Clifford@nrc.gov)  
Phone: (301) 415 - 4043

D/84