PMComanchePeakPEm Resource

From: Monarque, Stephen

Sent: Tuesday, February 14, 2012 1:30 PM

To: Bird, Bobby; John.Conly@luminant.com; joseph tapia; Woodlan, Don

Cc: Otto, Ngola; ComanchePeakCOL Resource

Subject: Comanche Peak COL - Chapter 8 - ACRS Questions

ACRS sent us this list of questions from the ACRS subcommittee meeting on Chapter 8. Please tak

FSAR

Chapters Issue / Question

Section 8.2.1.2 in DCD Revision 3 states: "The MT, UATs and RATs, are located in the area of MT and UAT FSAR Revision 1 indicates that 3-hour fire barriers are located between the normal and alternate preferred particles."

- 8 this a departure from the DCD?
- 8 How effectively will a one-hour rated fire barrier protect adjacent transformers against flame or heat damage
- Could a fire in control house #1 cause spurious protection signals to open the circuit breakers for the DeCor house #1?
- Does each 345 kV circuit breaker have only one closing coil? What is the rated life of the plant switching station circuit breakers are open?
- What is the rated life of the unit switchyard batteries? Does each unit switchyard circuit breaker have only of breakers are open?

Thanks,

Stephen Monarque Project Manager Comanche Peak COL NRO/DNRL/NMIP 301-415-1544 **Hearing Identifier:** ComanchePeak_COL_Public

Email Number: 1618

Mail Envelope Properties (9C2386A0C0BC584684916F7A0482B6CA58746203AC)

Subject: Comanche Peak COL - Chapter 8 - ACRS Questions

 Sent Date:
 2/14/2012 1:29:34 PM

 Received Date:
 2/14/2012 1:29:35 PM

 From:
 Monarque, Stephen

Created By: Stephen.Monarque@nrc.gov

Recipients:

"Otto, Ngola" < Ngola. Otto@nrc.gov>

Tracking Status: None

"ComanchePeakCOL Resource" < ComanchePeakCOL.Resource@nrc.gov>

Tracking Status: None

"Bird, Bobby" <Robert.Bird@luminant.com>

Tracking Status: None

"John.Conly@luminant.com" < John.Conly@luminant.com>

Tracking Status: None

"joseph tapia" <joseph_tapia@mnes-us.com>

Tracking Status: None

"Woodlan, Don" <Donald.Woodlan@luminant.com>

Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files Size Date & Time

MESSAGE 2333 2/14/2012 1:29:35 PM

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal

Expiration Date: Recipients Received: