

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 T N S N P 1 200-00000-0034111145
7 8 9 14 15 25 26 30 37 CAT No
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CONT
01 REPORT SOURCE L605000327706268080813809
7 8 60 61 68 69 74 75 80
 DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 Review of SI 137.1 test data revealed that surveillance requirement 4.4.6.2.b was
03 not performed within prescribed interval on 6/26/80. Unit 1 was in mode 3, RCS at
04 2235 psig and 547 degrees F, with preop testing in progress. Reportable per
05 6.9.1.13.c. Previous occurrence - 1, ref. LER No. 80127. Probable consequences -
06 RCS unidentified leakage limit could have been exceeded. However, the surveillance
07 was completed and found acceptable on 6/26/80 at 1720. There was no effect upon
08 public health or safety.
7 8 9 80

09 SYSTEM CODE ZZ11 CAUSE CODE A12 CAUSE SUBCODE A13 COMPONENT CODE ZZZZZZ14 COMP SUBCODE Z15 VALVE SUBCODE Z16
7 8 9 10 11 12 13 18 19 20
17 LER/SRO REPORT NUMBER 80 EVENT YEAR 131 SEQUENTIAL REPORT NO. 03 OCCURRENCE CODE L REPORT TYPE 0 REVISION NO.
21 22 23 24 26 27 28 29 30 31 32
 ACTION TAKEN X18 FUTURE ACTION Z19 EFFECT ON PLANT Z20 SHUTDOWN METHOD Z21 HOURS 000022 ATTACHMENT SUBMITTED N23 NRC 4 FORM SUB N24 PRIME COMP SUPPLIER Z25 COMPONENT MANUFACTURER Z999
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 RO and SRO did not perform SI 137.1 because of other urgent tasks. They have been
11 instructed to call in additional personnel as necessary to keep the surveillance
12 program up to date.
13
14
7 8 9 80

15 FACILITY STATUS B28 % POWER 00029 OTHER STATUS N/A30 METHOD OF DISCOVERY B31 DISCOVERY DESCRIPTION STA review of SI's32
7 8 9 10 12 13 44 45 46 80
 ACTIVITY CONTENT RELEASED OF RELEASE Z33 AMOUNT OF ACTIVITY N/A35 LOCATION OF RELEASE N/A36
7 8 9 10 11 44 45 80
 PERSONNEL EXPOSURES NUMBER 00037 TYPE Z38 DESCRIPTION N/A39
7 8 9 11 12 13 80
 PERSONNEL INJURIES NUMBER 00040 DESCRIPTION N/A41
7 8 9 11 12 80
 LOSS OF OR DAMAGE TO FACILITY TYPE Z42 DESCRIPTION N/A43
7 8 9 10 80
 PUBLICITY ISSUED DESCRIPTION N44 N/A45
7 8 9 10 80
 NRC USE ONLY
 8008190 520
 Name of Person Phone 615 842-8317