



Fire Protection Session Review

**Regulatory Information Conference
Fire Protection – Session C4
March 9, 2005**

**John Hannon, Chief
Plant Systems Branch
Plant Chair**

**U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001**

Fire Protection Session Review

Key Presenter Points on NFPA 805:

- More clearly establishes licensing basis
- Improves safety by focusing on risk significant issues
- Reduces need for exemptions
- Specific enforcement discretion applies
- Modified Triennial with separate observation visits
- Post-transition Triennials continue at same level of effort
- Plant specific cost benefit centers around modifications
- Fire risk dictates response to technical issues