



RIC 2006 Session T1BC

Fuels – Cladding Behavior for Regulatory Applications

Industry Perspective on Reactivity Initiated Accidents (RIA) Criteria


**Rosa Yang
Electric Power Research Institute**

March 7, 2006

Limits On fuel behavior During An RIA

- Current regulations have separate limits for fuel rod failure and reactor safety
 - Fuel rod failure threshold for dose consequence assessment
 - Maintain reactor vessel integrity and core coolability
- Experimental data suggests fuel failure threshold becomes lower for high burnup rods
- Low probability of the event allows for more realistic approach
 - Collapsing the two limits as proposed in RIL 0401 is overly conservative and not consistent with experimental data
 - ACRS is supportive of retaining two separate limits

Current US RIA Acceptance Criteria




Assessment Of Low Enthalpy Failures In High Burnup Fuel



- Conclusions from regulatory and industry evaluations
 - No significant impact on public health and safety: low probability of occurrence and low power of high burnup fuel
 - Increase in fuel damage fraction and radiological consequences are possible
- While there is no immediate safety significance, RIA criteria need to be revised at high burnup to reflect current understanding and experimental data

Revised RIA Acceptance Criteria

Industry Proposal – June 2002




Industry Proposal is Technically Sound



- Based on integral experiments and separate effects tests
- Consistent with experiments performed using applicable samples and test conditions
- Consistent with criteria developed in other countries using mechanistic approach (Sweden, Switzerland, France, Japan, etc.)

Application Of Revised Acceptance Criteria

- Collapsing Coolability limit to failure threshold will restrain/restrict flexibility of core reload designs



Conclusions

- The industry proposed criteria is based on experimental data and analytical approach which are widely used by technical experts and regulators worldwide
- RIA is a low probability event
 - Rod ejection is a localized event – consequences are limited
 - High burnup rods have limited reactivity – less impact on safety concerns
- Overly conservative criteria will limit core designs
 - Economic penalty without commensurate increase in safety benefit