

RIC 2006

Session W4E

ROP Assessment Program

Update

Bruce Boger, Session Chair
Associate Director for Operating Reactor Oversight and
Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
March 8, 2006



RIC 2006

Session W4E

ROP Assessment Program

Update

SDP Timeliness

Russell Gibbs, Chief

Reactor Inspection Branch

Division of Inspection & Regional Support

March 8, 2006



SDP Objectives

- Characterize the significance of inspection findings in the ROP (safety)
- Provide a basis for assessment and enforcement actions associated with inspection findings (effectiveness)
- Provide stakeholders an objective framework for communicating the safety significance of inspection findings (openness)



SDP Timeliness Background

- Commission directed SDP timeliness goal of 90 days in 2001 (SRM M010720A)
- Metric established in 2002 to directly reflect goal (SECY-02-062)
 - 100% within 90 days
- Metric revised in 2003 recognizing need to improve SDP evaluation tools (SECY-03-062)
 - FY03 (75%), FY04 (80%), FY05 (85%), FY06 (90%)
- Metric not met since inception



SDP Timeliness

Actions Taken

- Numerous assessment tools developed to evaluate findings related to at-power and shutdown conditions, containment performance (LERF), fire, and steam generator tube integrity
- Significantly increased management awareness
 - SDP Active Issues Summary, counterpart meetings and briefings
- Revised SDP guidance (November 2005)
 - engage management earlier (planning SERP)
 - Use of best available information
 - Simplified vs. detailed Phase 3 analysis
 - Define assessment time for licensee in Choice Letter
 - No new information once final decision is made



SDP Timeliness Ongoing Actions

- Best Practice initiative
 - Determine most effective approaches to better manage resolution of SDP findings
- Develop new guidance for NRC Management Review
 - Meant for findings with high uncertainty and those beyond limitations of PRA
- Develop new metric to better reflect performance (90-day goal remains unchanged)
 - Use of average with a backstop time period



SDP Timeliness Summary

- Corrective actions are improving performance and continued improvement expected
- New metric will better reflect overall performance
- Need to better align SDP process and stakeholders on overall purpose of process



RIC 2006

Session W4E

ROP Assessment Program

Update

ROP Assessment Program Update

Ronald A. Jones, Senior Vice President

Nuclear Operations

Duke Energy

March 8, 2006



ROP Program Update

- Improved Inspection Program
 - Reflects Role of Mature Corrective Action Programs
 - Introduced Performance Indicator Concept



ROP Program Update

- Opportunities for Refinement Exist
 - Public Interface – NRC press releases can lead to exaggerated public/media concern when actual risk is low
 - Impact of White Findings – Licensees and NRC may expend considerable effort in addressing white findings which is not necessarily consistent with safety significance
 - New ROP “Expectations” – Licensees may expend significant effort performing extent of cause/condition assessments which is not necessarily consistent with safety significance



ROP Program Update

- Public Interface

- Difficult to internalize 1E-6 risk
- Annual Assessment Meetings need refinement
- Ensure descriptions of performance deficiencies align with actual risk significance. For example;
 - “Licensee operated during the previous year with a degraded mitigation cornerstone”
- Members of the public may perceive this statement in a manner not consistent with the calculated risk values



ROP Program Update

- Impact of White Findings
 - Licensee awareness of potential findings sometimes does not occur prior to formal action being taken by NRC
 - Licensee reactions driven by prospect of aggregating 2 findings within 12 months
 - Scope of follow-up NRC 95002 inspections varies and is difficult to predict
 - Licensee resource reallocation to prepare for and manage supplemental inspection often not commensurate with safety significance



ROP Program Update

- New ROP “Expectations”
 - Prevent or promptly resolve all issues $> 1E-6$, regardless of existing licensing requirements
 - Conduct comprehensive root cause evaluations for all issues determined to be $> 1E-6$
 - Conduct integrated extent of condition and extent of cause assessment after second greater than green issue has been identified



ROP Program Update

- Conclusions
 - ROP represents an overall improvement
 - Continued refinement is needed to further remove subjectivity and effectively communicate issues to media/public



RIC 2006

Session W4E

ROP Assessment Program

Update

ROP / Cross-Cutting Issues

Anton Vogel, Deputy Division Director
Division of Reactor Projects,
Region IV
U.S. Nuclear Regulatory Commission
March 8, 2006



Importance of Cross-Cutting Issues

- Identify and highlight negative performance trends before the performance deficiencies manifest themselves as significant findings or events



RIV Identification and Review of Cross-Cutting Findings

- Inspector identification of issue.
- Branch Chief review.
- Inspection report debrief with regional management.
- Mid-cycle and End-of-Cycle reviews.



End-of-Cycle/Mid-Cycle Review

Defining Threshold for Identifying Substantive Cross-Cutting Issues

- Three (3) criteria needed to identify a Substantial Cross-Cutting Issue:
 1. Multiple findings - more than 3
 2. Causal factors have common theme
 3. Concern with the licensee's scope of efforts or progress in addressing the cross-cutting area performance deficiency



Cross-Cutting Issues – Changes being considered

- Integration Safety Culture Attributes

Human Performance

- Decision Making, Resources, Work Control, Work Practices.

Problem Identification and Resolution

- Correction Action Program, Operating Experience, Self-and independent assessments.

Safety Conscious Work Environment

- Preventing and detecting retaliation, willingness to raise concerns.



Conclusion

- Substantive Cross-Cutting Issues are important to the implementation of the ROP
- Post-EOC critique will be performed to assess the changes to the Assessment Process
- Continue efforts to improve consistency in the implementation of cross-cutting issue guidance and integrate Safety Culture aspects



RIC 2006

Session W4E

ROP Assessment Program

Update

**Cross Cutting Issues Process:
Need for Better Definition and Improved
Consistency**

Steve Floyd

Vice President Nuclear Affairs

Nuclear Energy Institute

March 8, 2006



Concerns

- Industry has noted significant increase in number of cross cutting aspects
 - From 60/year through 2002 to 392 in 2004
- Cross cutting issues average around 15
- Many sites reporting significant percentage of findings with cross cutting aspects – 60 to 90%
- Safety culture modifications to process will increase subjectivity and raise potential consequences



Needed Actions

- Define a minimum threshold or criteria establishing a cross cutting aspect
- Ensure modifications from safety culture elements are clear and concise
- Better define the exit criteria for a cross cutting issue

Conclusions

- The defining principles of the ROP include safety focus, objectivity, predictability and transparency
- The cross cutting issue process needs to reflect each of these principles



RIC 2006

Session W4E

ROP Assessment Program

Update

Security/EP Issues

Daniel Dorman, Deputy Director

Division of Nuclear Safety

Office of Nuclear Security and Incident
Response

U.S. Nuclear Regulatory Commission

March 8, 2006



Physical Protection Oversight Revisions

- Inspections (Increased Focus Areas)
- Performance Indicators
- Significance Determination Process
(revised July 2005)



New Physical Protection SDP

- **Baseline Findings**
 - Alignment for clarity and consistency
 - Avoid duplication of assessment
- **Force on Force Evaluated Exercises**
 - Assess protective strategy performance
 - Risk-informed methods
- **Industry proposed alternative**



Security - Emergency Plan Interface

- Evaluate security impacts on E-Plan
- Examples
 - Site access points
 - Emergency classifications
 - Protective action recommendations
- IN 2005-19, “Effect of Plant Configuration Changes on the Emergency Plan”

