



State-of-the-Art Reactor Consequence Analyses (SOARCA)

Regulatory Information Conference
March 11, 2008

Agenda

- Opening Remarks and Overview
- Sequence Selection
- Accident Mitigation
- Accident Analysis
- Emergency Preparedness
- Comments

OPENING REMARKS

Dr. Farouk Eltawila, Director
Division of System Analysis
Office of Nuclear Regulatory Research

Overview

- State-of-the-art more realistic evaluation of severe accident progression, radiological releases and offsite consequences
- Integrated and consistent analysis of pilot plants (Peach Bottom, Surry) for important sequences (e.g., SBO, ISLOCA) subject to probabilistic considerations
- Account for plant design and operational improvements, credit existing and newly developed mitigative measures and site specific emergency plans


4

Motivation

	Plant Design and Operations	Severe Accident Phenomenology	Emergency Planning
1982 Sandia Siting Study	Total CDF: $1 \times 10^{-4}/\text{yr}$ to $1 \times 10^{-5}/\text{yr}$	Alpha Mode Failure Direct Containment Heating Conservative Accident Progression - Large and fast radiological release	Generic (including bounding) EP modeling
2008 SOARCA	Improved Plant Performance Total CDF: $1 \times 10^{-5}/\text{yr}$ to $1 \times 10^{-6}/\text{yr}$ Additional Mitigative Measures	Alpha Mode Failure is remote & speculative DCH resolved Realistic accident progression analysis	Improved Site Specific EP Modeling

5

SOARCA PROCESS



6

SEQUENCE SELECTION

Richard Sherry, Senior Risk Analyst
Division of Risk Analysis
Office of Nuclear Regulatory Research

7

Sequence Selection Process

- Full Power Operation

- Internal Initiated Events
 - SPAR model results
 - Comparison with licensee PRA
 - Discussions with licensee staff

- External Initiated Events
 - Review of prior analyses
 - IPEEE
 - NUREG-1150
 - Discussions with licensee staff

8

Sequence Groups

- Group core damage sequences that have similar initiating events, Sequence timing and equipment unavailability
- Initial Screening
 - CDF Initiating Events $CDF \geq 1E-7$
 - Sequences with $CDF \geq 1E-8$
- Sequences Evolution – Identify and evaluate dominant cutsets (~90% of CDF)
- Scenario grouping
- Sequences refined by external events and mitigative measures

9

Final Sequence Groups

- Screen in sequence groups with group CDF $\geq 10^{-6}/RY$
- or -
- Containment bypass sequence groups with group CDF $\geq 10^{-7}/RY$

10

Containment Systems Availability

- Availability of engineered systems that can impact post-core damage containment accident progression, containment failure and radionuclide release and not considered in Level 1 core damage SPAR model
- Surry and Peach Bottom
 - Availability of containment systems based on support system status
- Sequoyah
 - Availability of containment systems determined using extended Level 1 SPAR model

11

Sequence Groups Peach Bottom Atomic Power Station

- Peach Bottom Internal Events
 - None (Dominant below the screening threshold was SBO)
- Peach Bottom External Events (Seismic)
 - Long Term SBO (RCIC available early) (1×10^{-6} to $5 \times 10^{-6}/yr$)

12

Sequence Groups Surry Power Station

- Surry Internal Events
 - ISLOCA ($7 \times 10^{-7}/\text{yr}$)
 - SGTR ($5 \times 10^{-7}/\text{yr}$)
- Surry External Events (Seismic)
 - Long-term SBO (TD-AFW available early) (1×10^{-5} to $2 \times 10^{-5}/\text{yr}$)
 - Short-term SBO (TD-AFW failed) (1×10^{-6} to $2 \times 10^{-6}/\text{yr}$)

13

MITIGATIVE MEASURES

Robert Prato, Senior Program Manager
Division of System Analysis
Office of Nuclear Regulatory Research

14

Mitigative Measures Analysis

- Qualitative, sequence-specific systems and operational analyses
 - Licensee identified mitigative measures from EOPs, SAMGs
 - Other applicable severe accident guidelines
- Input into the MELCOR analyses

15

Mitigative Measures Analysis Process

- Consider all mitigative measures
- Conduct sensitivity analyses to assess the effectiveness of different mitigative measures


Mitigative Measures Analysis Process

- For each sequence grouping, identify the potential failure mechanisms and determine available mitigative measures
- Perform a system and an operational analysis based on the initial conditions and anticipated subsequent failures
- Determine the anticipated availability, capability and the time to implementation (e.g., TSC activation)
- MELCOR used to determine the effectiveness of the mitigative measures based on capability and estimated time of implementation


Structural Analyses

Evaluate the behavior of containment structures under unmitigated severe accident conditions to predict the following performance criteria at the selected sites:

- Functional Failure Pressure - Leakage
- Structural Failure Pressure - Rupture
- Develop Leakage Rate and/or Leakage Area as a Function of Internal Pressure



Peach Bottom "Mark I - Steel Containment"



Surry "Reinforced Concrete Containment"

Peach Bottom LTSBO

- Effectiveness of Mitigative Measures
 - Batteries were available for ~ 4 hours
 - RCIC automatically started and prevented loss of RCS inventory
 - Operator, by procedure, depressurizes at ~ 1 hr
 - Portable power supply ensures long-term DC to hold SRV open and provide level indication (allow management of RCIC)

Surry LTSBO

- Dominant containment dominant failure mode is leakage from cracking around the Equipment and/or Personnel Hatches
- Effectiveness of Mitigative Measures
 - Batteries were available for ~ 8 hours
 - TDAFW Pump automatically starts to makeup to the SGs
 - SG PORVs operable on DC power for 100 F/hr RCS cooldown
 - Portable power supply ensures long-term DC to provide level indication (allow management of TDAFW)
 - Portable pump provided make up for RCP seal cooling

Surry STSBO

- Dominant containment dominant failure mode is leakage from cracking (9 in²) around the Equipment and/or Personnel Hatches
- Effectiveness of Mitigative Measures
 - AC and DC power are unavailable
 - Mechanical failure of TDAFW Pump, fails to start
 - No instrumentation or RCS makeup
 - Portable pump provided containment spray within 8 hours (spray operation terminated @ 15 hours)

Surry SGTR

- Effectiveness of Mitigative Measures
 - All ac and dc power supplies were available
 - All instrumentation was available
 - Plant response
 - HPI, AFW initiate
 - Turbine stop valves close
 - Steam dump valves throttle and close

22

SEQUENCE ANALYSIS

Randall Gauntt, Project Manager
Sandia National Laboratories

23

EMERGENCY PREPAREDNESS

Randolph Sullivan, CHP
Office of Nuclear Security and Incident Response

24

Objective

- Realistically model emergency response during a severe accident
- Evolutionary improvement over past EP modeling

Assumptions

- Emergency plans will be implemented
- The public will largely obey direction from officials
- Emergency workers will implement plans

Technical Basis

- Site, State and local emergency plans
- Site emergency classification procedures
 - Aligned with accident progression from MELCOR
- State/local protective action procedures
 - Precautionary protective actions modeled
- Evacuation Time Estimate (ETE)
- Oak Ridge Evacuation Modeling System for evacuation beyond EPZ (if necessary)

Identify Cohorts

- ETE data:
 - General public
 - "Tail" of public
 - Special needs
- Precautionary protective actions:
 - Schools
 - Parks, beaches, etc.

Identify Cohorts

- Non-evacuating (0.5%)
- Shadow evacuation (10%)

Speed of Travel

- Determined from ETE and OREMS
- Modified in space and time
 - "Bottle necks" identified
 - Free flowing areas identified
 - Road loading timing

Example ETE

Region	Population	Non-Evacuating	Evacuated	Number of Vehicles
0-10	71,400	400	71,000	41,000

EPZ Evacuation Times
- 6.5 hours (from ETE)

Speed of Travel

- MACCS2 does not allow input of road loading function
- Median speed of cohort assumed
 - Speeds adjusted for areas of free flow or congestion
- Distance travelled assumed 50% more than radial
- Median speed equals dist/time to clear

Example Accident

- Long Term Station Blackout scenario
- General Emergency is declared about 2 hours after loss of all A/C power
 - Evacuation starts at General Emergency
 - No precautionary evacuation of schools (Site specific decision)

Comments and Questions
