



Licensing Best Practices and Initiatives

Harold K. Chernoff
Chief, Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation



Overview

- What works well?
- What doesn't work well?
- What can prevent a clean start?

2



What Works Well

- Describing the change including current licensing basis and current licensing basis acceptance criteria
- Demonstrate adequate level of safety for the change
 - Analytical methods
 - Input parameters
 - Same method as the current licensing basis or NRC approved method
 - Provide results
 - Safety impact evaluation for administrative changes

3



What Works Well

- Provide level of detail so that NRC staff can make an independent assessment
- Fleet submittals for Improved Standard Technical Specification plants (ISTS)
- Submittals using Electronic Information Exchange
- Clearly identifying and justifying *required* plant specific deviations from CLIIPs and TSTFs

4



What Does Not Work Well

- Requested approvals in less than 1 year
- Unidentified or Undocumented deviations from CLIIPs and TSTFs
- Fleet submittals including both ISTS and non-ISTS plants
- Approved CLIIPs and TSTFs that have subsequently engendered NRC staff concerns

5



What Does Not Work Well

- Not evaluating the impact of all changes
- Not ensuring that all assumptions and limitations of CLIIPs, TSTFs, and Topical Reports are met
- Reliance on commitments where regulatory requirements are warranted
- Not establishing and meeting scheduled dates including implementation dates

6



What Can Prevent a Clean Start

- No Significant Hazards Consideration Determinations that do not address all changes
- Proprietary determination issues
- ADAMS acceptance issues
- Communication issues
- Precedent issues
- Evolving NRC staff positions

7



Comments and Questions

8
