

Status Update: Flooding Issues

Jim Riley, NEI
March 14, 2013



Content

- Flooding Walkdowns
- Flooding Reevaluations
- Integrated Assessment
- FAQ Process



Walkdown Status

- NEI guideline (NEI 12-07) endorsed by the NRC on May 31, 2012
- Walkdown reports submitted by November 27, 2012
- Supplements to the report or RAIs may be necessary to address missing information



Walkdown Observations To-Date

- Walkdowns performed well
- Most plants reported few deficiencies
- No significant generic issues identified
- General findings
 - ★ Degraded or missing seals
 - Control of yard and storm drain systems
 - PM program improvements
 - Procedural changes



Flood Hazard Reevaluations

- Guided by
 - NUREG/CR 7046
 - JLD-ISG 2012-06 on Tsunami – Storm Surge
- Dam failure ISG in process
 - Developing FAQs to supplement guidance
 - Obtaining information on dams owned by others may be a challenge



Flood Hazard Reevaluations

- First year plant submittals due on March 12, 2013
- FFTF white paper describes reportability and operability considerations for reevaluation results
- Interim actions needed as part of reevaluation reports



Integrated Assessment

- Guided by JLD-ISG-2012-05
- Oconee is working through the process as a lead plant
- FFTF developing an example of a of a scenario based evaluation of mitigation capability
 - NRC endorsement is sought



FAQ Process

- Flooding Task Force is using a “Frequently Asked Question” process to clarify and supplement guidance
- Contact NEI for information or questions


