



PSEG Nuclear Operating Experience (OE)

Hope Creek
Salem
PSEG Nuclear Corporate
Utilities Services Alliance (USA)



Salem and Hope Creek



PSEG Nuclear OE Program

Incoming

- INPO IERs - INPO OE Program
- INPO Daily OE
- NRC Information Notices and Summaries
- NRC Daily Report
- Nuclear OEM and Contractors
- PSEG station reports
- Utilities Services Alliance (USA) utility and station reports
- Industry activities – meetings, benchmarking, self assessments
- USA "Jump Calls"
- PSEG and USA peer group calls and meetings

Outgoing

- OE submissions to INPO
- OE to USA
- USA "Jump Calls"
- PSEG and USA peer group calls and meetings



Reactive Use of OE

OE Search is institutionalized in event response and troubleshooting processes

1. Hope Creek Safety Relief Valves (SRVs)

- Problem – chronic valve seat leakage and setpoint drift on 2-stage SRV
- OE search for Root Cause Evaluation
- Benchmarking
- New design in engineering and construction stage – due for testing 12/13

2. Salem Tagging Issue

- Problem – low voltage found during circulating water modification
- Immediate action - USA "Jump" call - identifies immediate actions
- Follow-up face-to-face meeting - identifies extent of gap to industry standards



Proactive Use of OE

Main Turbine


- Seabrook issued OE 32328 in Nov 2010
- Main turbine couplings found out of alignment in previous outage
- Correcting the misalignment was significant effort and added 14 days to the outage
- Causes – driven by sectionalized HP/LP maintenance
 - > aligning couplings by misaligning adjacent bearings or
 - > comparing "as found" to "as left" rotor position without referring to last rotor position when the couplings were aligned
- Photogrammetric alignment technology to be used in Salem-1 outage April-May 2013
 - > Methodical approach to measuring bearing alignment at different phases of turbine assembly



Proactive Use of OE

Salem transformer bushing clamp

- Metal piece found on pavement during operator rounds
- Where did the piece come from?
- Immediate actions taken to monitor the bushing
- OE shared with Hope Creek and USA



Other Examples of Application of OE

- Hope Creek Scram Header
 - Trend in instrument air soldered joint separations OE in 2007-08
 - Hope Creek joints tested in Sep 2008
 - Data transcription error to maintenance work order results in missing the largest leak
 - Hope Creek trip due to rods drifting in in May 2009
- Hurricane Sandy – Salem Trip
 - OE overconfidence – muscle memory
 - Monitor for deviations to previous OE



Present and Future Challenges

- Nuclear Professionalism
 - Desire and ability to find and use OE is a fundamental
 - Personnel Turnover – Retiring to Replacements
 - Learning that there are few original problems
- Volume of Information
 - Compartmentalizing OE
 - Delivery and access to maintenance supervisors and workers
- OEM and Contractor Input
 - Effectively sharing OE may not be well developed
 - Avenues for processing may not be not well established
- Inspections and Evaluations
 - Sending an unintended message that every OE report must receive follow-up