
U.S.NRC
United States Nuclear Regulatory Commission
Protecting People and the Environment


Regulatory Information Conference 2014
W20 Future Vision of Spent Fuel Storage Regulations

Spent Fuel Storage Renewal Strategy Development

Kristina Banovac
Office of Nuclear Material Safety and Safeguards

March 12, 2014


1


U.S.NRC
United States Nuclear Regulatory Commission
Protecting People and the Environment

Background
Spent Fuel Storage Renewal Requirements

- Renewal of Independent Spent Fuel Storage Installation (ISFSI) licenses and storage cask designs for a period not to exceed 40 years (10 CFR §72.42 and §72.240)
- Time-limited aging analyses
- Description of the Aging Management Program (AMP)
- Design bases information as documented in the most recently updated final safety analysis report
- Guidance located in NUREG-1927 (Standard Review Plan for storage renewal)

2


U.S.NRC
United States Nuclear Regulatory Commission
Protecting People and the Environment

Current Challenges
Current Renewals & Guidance

- 2 ISFSI license and 1 storage cask design Certificate of Compliance (CoC) renewal applications currently under staff review
- Multiple year reviews & request for additional information cycles
- Experience indicates that guidance in NUREG-1927 may need enhancement in several areas

3

Current Challenges

Modes of Materials Degradation



- Storage and reactor operating experience indicates potential degradation of structures, systems, and components
 - IN 2013-07: Premature degradation of cask structures and components from environmental moisture
 - IN 2012-20: Chloride-Induced Stress Corrosion Cracking (CISCC)
- Known vs. unknown degradation mechanisms, besides CISCC
- Difficult to define and assess all operable degradation modes for all potential chemistries for all locations

4

Path Forward

Storage Renewal Strategy Team



- Established Storage Renewal Strategy Team with members from across NRC
 - Assess current storage renewal regulatory framework to determine if changes (e.g., guidance updates) are needed
 - Reflect on storage operating experience, staff's storage renewal review experience, and reactor renewal experience
 - Develop learning, proactive, and responsive approach to renewals

5

Path Forward

Operations-Focused Approach



- Operational methodologies – condition based monitoring and/or in-service inspections
- Assessment of monitoring and in-service inspection findings and data
- Criteria for actions/decisions (e.g., prevention, repair, replacement, other mitigation measures)
- Learning AMPs that consider and respond to operating experience and incorporate results of long term confirmatory research

6

Path Forward

Storage Renewal Strategy Team Targets



- January 2014 – June 2014
 - Strategy Development
 - Engage Stakeholders and Consider Feedback
 - Public Meetings
 - Industry Research and Guidance Development
- June 2014 – May 2015
 - Engage Stakeholders on Guidance
 - Publish Draft Guidance for Public Comment
 - Publish Final Guidance

7

References



- 10 CFR Part 72
<http://www.nrc.gov/reading-rm/doc-collections/cfr/part072/>
- NUREG-1927
<http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr1927/>
- IN 2013-07
<http://pbadupws.nrc.gov/docs/ML1232/ML12320A697.pdf>
- IN 2012-20
<http://pbadupws.nrc.gov/docs/ML1231/ML12319A440.pdf>

8

Acronyms



- AMP – Aging Management Program
- CFR – Code of Federal Regulations
- CISC – Chloride-Induced Stress Corrosion Cracking
- CoC – Certificate of Compliance
- IN – Information Notice
- ISFSI – Independent Spent Fuel Storage Installation

9
