



RIC 2015

MELCOR ANALYSIS IN SUPPORT OF CPRR RULEMAKING

Hossein Esmaili
Office of Nuclear Regulatory Research
Division of Systems Analysis

March 10, 2015



OVERVIEW

- **Background**
 - In SECY-12-0157, staff recommended the requirement of severe accident capable hardened vents and external filters for BWRs with Mark I and II containments
 - Commission directed staff to prepare and issue Order EA-13-109 for severe accident capable vents and prepare a regulatory basis for rulemaking
- **Technical Approach**
 - Development of accident progression event trees and core damage states
 - MELCOR accident progression analysis for representative BWR Mark I and Mark II plants
 - o fission product release characteristics
 - o effectiveness of mitigation (RPV pressure control, containment venting, and core/containment water injection strategies including severe accident water addition [SAWA] and severe accident water management [SAWM]).
 - SOARCA Mark I model converted to MELCOR 2.1
 - MACCS2 offsite consequence analysis (land contamination and health effects)
 - Risk integration and regulatory analysis


2





MELCOR Run Matrix for Mark I





Case	Description	Pre Core Damage					Post Core Damage			
		RPV Pressure Control	BEIC Operation	Anti Gravity Venting	Filter Operation	SRV Operation	Venting	Containment	Offsite	Health
1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100


3














Conclusions

- A combination of venting and water addition is required to prevent containment failure and is a beneficial strategy for mitigating radiological releases. Containment venting generally results in a puff release to the environment which can occur shortly after core damage and before water addition.
- Anticipatory venting (before core damage) is beneficial to reduce the containment pressure and delay the radionuclide release to the environment.
- Containment venting is efficient in purging hydrogen and non-condensables. Water injection is also helpful in maintaining a steam-inerted atmosphere which can preclude an energetic hydrogen combustion.
- The highest calculated releases to the environment result from a main steam line creep rupture scenario, which is one of the least likely variations.
- The releases to the environment for the Mark II analysis are generally comparable to or lower than those in the Mark I analysis.
- For the Mark II analysis, scoping analyses were performed to investigate different lower cavity configurations. The environmental releases are within the range of source terms predicted based on the variations in the scenario boundary conditions.

12



Acronyms

- BWR Boiling water reactor
- DCV Downcomer vent
- DW Drywell
- MCCI Molten core concrete interaction
- MSCLR Main steam line creep rupture
- PCPL Primary containment pressure limit
- PSP Pressure suppression pressure
- RCIC Reactor core isolation cooling
- RPV Reactor pressure vessel
- SAWA Severe accident water addition
- SAWM Severe accident water management
- SOARCA State-of-the-art reactor consequence analysis
- SP Suppression pool
- SRV Safety/Relief valve
- WW Wetwell
