


USNRC
Nuclear Regulatory Commission
RIIC 2015



Personnel Performance during Challenging Events: Lessons from Operating Experience

John W. Stetkar
Stetkar & Associates

USNRC
Nuclear Regulatory Commission
RIIC 2015



Event #1 – Electrical Fire

- Circuit breaker failed to open
- Consequential transformer fault
- Loss of power at two 4kV buses, three 480V buses, nine motor control centers

2

USNRC
Nuclear Regulatory Commission
RIIC 2015



Event #1 – Additional Complications

Air-operated valve closed during power transfer

- Unexpected equipment response
- Isolated cooling water to RCPs

Secondary plant heater drain valves failed open

- Design response to loss of power
- Excessive cooldown and safeguards actuation

Charging suction did not transfer to RWST

- Error during prior control circuit modification
- Loss of RCP seal injection flow if VCT drained

3

USNRC **RIC 2015**

Event #1 – Personnel Performance

Control room team focused on response to fire and AC power recovery

- BOP operator dedicated to fire procedures for ~30 minutes
- RO partially distracted by fire response
- Supervisors distracted by Emergency Action Level reviews
- Frequent crew updates diverted attention from plant status

Operators quickly started two charging pumps per EOPs

- Did not monitor VCT level
- Did not recognize failure of suction transfer to RWST

4

USNRC **RIC 2015**

Event #1 – Personnel Performance

Crew did not recognize loss of RCP cooling

- RCP bearing high temperature alarms at ~35 minutes
- Reopened cooling water valve at ~40 minutes
- VCT drained, loss of all charging and RCP seal injection at ~45 minutes
- Aligned charging pumps suction to RWST at ~60 minutes

Crew did not recognize cause for overcooling

- Overcooling stopped after ~35 minutes
- Local operator investigating power failures bumped DC circuit breaker
- Momentary loss of instrument bus power caused MSIVs to close

5

USNRC **RIC 2015**

Event #1 – Personnel Performance

Attempt to AC restore power

- Reset generator lockout relay at ~3-1/2 hours per procedure
- Did not confirm cause for lockout
- Reconnection of power to faulted transformer caused second fire in another location
- Second fire caused ground faults on both DC power trains

6

USNRC **RIC 2015**

What Have We Learned?

Personnel actions depend on overall plant response context

- Often focus on correction of initial condition
- Complications from support system failures
- Personnel often not familiar with subtle effects
- Unexpected plant behavior differs from experience and training
- Non-safety systems and functions can divert attention
- Conflicting priorities
- Procedures do not always address actual plant conditions
- Confusing conditions can persist for extended time
- Problems can occur during recovery

7

USNRC **RIC 2015**

Event #2 – Loss of Offsite Power

- Diesel generators started
- Safety buses reenergized
- Standby instrument air compressor failed to start (not safety-related, but powered from safety bus)
- Loss of instrument air

8

USNRC **RIC 2015**

Event #2 – Additional Complications

Charging valve open fully, normal letdown isolated

- Design response to loss of instrument air
- Increasing pressurizer level

Loss of plant process computer

- Unexpected response
- Loss of alarms and trend information

Several fire alarms actuated

- Unexpected response

9

USNRC **RIC 2015**

Event #2 – Personnel Performance

Control room team partially preoccupied with fire alarms

- Concern that power failure was caused by a fire
- Coordination with local plant operators checking alarm locations

Loss of process computer

- Power panels deenergized automatically at 30 minutes
- STA left control room often to locally check required indications

Crew recognized mismatch between charging and letdown

- Reduced charging flow to minimum for RCP seals, pressurizer continued to fill
- PORV opened automatically at ~50 minutes (6 times)
- PORV opened manually at ~60 minutes (5 times)

10

USNRC **RIC 2015**

Event #2 – Personnel Performance

Alternate letdown alignment

- Aligned alternate letdown to VCT through reactor vessel head vent valves at ~1-1/2 hours, per procedure
- VCT level did not increase, due to closed air-operated valve
- Operators concluded that flow path was blocked (it wasn't)
- Realigned head vent flow to pressurizer relief tank at ~2 hours
- Pressurizer relief tank filled, rupture disc opened at ~2-1/2 hours

11

USNRC **RIC 2015**

Event #2 – Personnel Performance

Restored instrument air at ~2-1/2 hours

- Air compressor starting relay contacts degraded
- Delay due to concerns about cooling water flowing onto floor

Aligned letdown to VCT at ~3 hours

- Recovery of instrument air reopens hydrogen supply to VCT
- VCT pressure sensor remains deenergized, control valve fails, full hydrogen pressure supplied to VCT
- Letdown relief valve opens, release of water into Auxiliary Building from drain tank
- Manually diverted letdown to reduce VCT pressure
- Normal charging and letdown established at ~6-1/2 hours

12

USNRC
RIIC 2015

What Have We Learned?

Personnel actions depend on overall plant response context

- Often focus on correction of initial condition
- Complications from support system failures
- Personnel often not familiar with subtle effects
- Unexpected plant behavior differs from experience and training
- Non-safety systems and functions can divert attention
- Conflicting priorities
- Procedures do not always address actual plant conditions
- Confusing conditions can persist for extended time
- Problems can occur during recovery

13

USNRC
RIIC 2015

The Goals of Human Reliability Analysis (HRA)

Evaluating human performance in a PRA

- How will personnel respond during an evolving event scenario?
- What is the likelihood that personnel will perform the desired actions?
- What are the consequences of alternate personnel responses?

14

USNRC
RIIC 2015


What Have We Learned?

PRA models and HRA are often myopic

- Focus on modeled systems, functions, and personnel actions
- Overlook response of non-safety systems, secondary plant, and ancillary functions

15

USNRC
REGULATORY INQUIRY CONFERENCE
RIC 2015




What Can We Do To Improve HRA?

Scenario narratives are crucial

- Understand how personnel may respond
- Possible distractions or conflicting priorities
- Deviations from procedural expectations

16

USNRC
REGULATORY INQUIRY CONFERENCE
RIC 2015




What Can We Do To Improve HRA?

Characteristics of a good scenario narrative

- Understanding of integrated plant response
- Developed from the operators' perspective
- Not focused only on systems and desired personnel actions in the PRA model
- Not a summary of expected procedural compliance
- Not tailored to perceived needs of specific HRA model

17

USNRC
REGULATORY INQUIRY CONFERENCE
RIC 2015



Is This A Panacea?

No....

- We can never predict everything that might occur
- We can never precisely predict how personnel will respond, even if we know what will occur

But....

- We can identify those scenario contexts when personnel are more likely and are less likely to perform the specific actions that are modeled in the PRA
- That is essential for a rational assessment of human performance

18

USNRC
Nuclear Regulatory Commission

RIC 2015



Acronyms

BOP	Balance of Plant
EOPs	Emergency Operating Procedures
HRA	Human Reliability Analysis
MSIVs	Main Steam Isolation Valves
PORV	Power-Operated Relief Valve
PRA	Probabilistic Risk Assessment
RCP	Reactor Coolant Pump
RO	Reactor Operator
RWST	Refueling Water Storage Tank
STA	Shift Technical Advisor
VCT	Volume Control Tank

19
