

eVinci™ Micro Reactor Licensing Modernization Program Pilot

32nd Annual Regulatory Information Conference

March 2020

Andrea Maioli

Fellow Engineer, Risk Analysis

Westinghouse Electric Company LLC

eVinci is a trademark or registered trademark of Westinghouse Electric Company LLC, its affiliates and/or its subsidiaries in the United States of America and may be registered in other countries throughout the world. All rights reserved. Unauthorized use is strictly prohibited. Other names may be trademarks of their respective owners.



Acknowledgement & Disclaimer

ACKNOWLEDGEMENT

This material is based upon work supported by the Department of Energy under Award Number DE-NE0008853.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.




eVinci Micro Reactor Attributes



Attributes

- 1-2 MWe transportable energy generator
- Fully factory built, fueled and assembled in CONEX containers
- Passive heat pipe technology
- 40 year design life with 3+ years continuous power
- No operator action
- Capable of providing high temperature process heat
- Near zero emergency planning zone (EPZ)
- Greenfield decommissioning
- Small installation footprint

Heat Pipe Design





Reactor in CONEX Container



eVinci Micro Reactor Safety Functions

- **Reactivity Control**
 - Inherent feedback
 - Neutron absorption/reflection drum control and passive shutdown
 - Shutdown rod passive shutdown
- **Heat Removal**
 - Power conversion system for normal operation
 - Inherent self-regulation using heat pipes
 - Air passive heat removal
- **Containment**
 - Fuel
 - Core block
 - Canister



eVinci Micro Reactor Probabilistic Risk Assessment


- First iteration of the PRA for internal events completed
 - Support to Licensing Modernization Program tabletop pilot activities
 - Justification for minimization of safety related classified components and I&C
 - Following ANS/ASME Non LWR PRA Standard as possible by design stage
 - Basic design evolution support
- PRA team involved with initial design requirements
 - More interactive role in LMP
- PRA team supported initial FMEA/fault schedule
 - Maintain appropriate balance in FMEA level of details (commensurate with design details level)
 - FMEA entries are directly linked with PRA elements (e.g., initiators, component failures, expected sequence behavior)
- Tracking of changing assumptions critical in PRA interaction
 - “As-being-designed” conditions
 - PRA assumptions database constantly reviewed/validated by design team

eVinci Micro Reactor Probabilistic Risk Assessment

- Little expected relevance of internal events and internal hazards
 - Also, no internal fire/internal flood PRA expected
 - No human reliability analysis involved
- Success criteria mostly based on conservative assumptions associated with safety functions
 - Conservative Core Damage definition (will likely need to be more refined)
 - Isothermal core monolith may require localized core damage sequences
 - Single event tree due to design simplicity
 - Completely passive safety systems (no active actuation of any component)
 - Probabilistic success criteria being defined for future PRA iterations
- Minimal system analysis
 - Completely passive safety systems
 - Active systems captured mostly for initiating events frequency (IEFT analysis) and for ATWS considerations
 - High uncertainty associated with passive failure modes reliability data


eVinci Micro Reactor Probabilistic Risk Assessment

- Success and core damage sequences retained in the analysis
- Dose estimates to the machine boundary estimated (<1m)
 - Peak temperature reached in success sequences drives different expected release cases




eVinci Micro Reactor Uncertainties

- Uncertainty in reliability data is significant, but epistemic uncertainties associated with design alternatives are dominating the current assessment



eVinci Micro Reactor DBE/BDBE Definition

- Minimal sequences in the region of interest for DBE and BDBE



eVinci Micro Reactor Safety Classification

- Minimal set of Safety Class equipment identified by tracking how failure of individual systems makes sequences jumping across DBE/BDBE thresholds.



eVinci Micro Reactor LMP Feedback and challenges

- LMP process feasibility has been tested for the initial phase of the design with good success and some feedback provided on the process
 - Emphasis may need to be added on epistemic uncertainties associated with design alternatives in the first iterations of the process
- Simplicity of eVinci micro reactor design possibly reduces the benefits of the methodology for DBE/BDBE and safety classification
- Challenges envisioned for external hazard assessment in absence of site information
 - Margin approach for seismic may be applicable but target HCLPF need to be increased and considerations on spectral shape may be needed to capture component specific classification
 - Margin approach does not exist for high winds and external flooding (admittedly with easier bounding fragility considerations)
- Site information is needed for a quantitative evaluation of external hazard that can feed the F/C diagram

References

- NRC Draft Regulatory Guide DG-1353, "Guidance for a Technology-Inclusive, Risk-Informed, and Performance-Based Methodology to Inform the Licensing Basis and Content of Applications for Licenses, Certifications, and Approvals for Non-Light-Water Reactors," April 2019.
- American Society of Mechanical Engineers and American Nuclear Society, "Probabilistic Risk Assessment Standard for Advanced Non-LWR Nuclear Power Plants," ASME/ANS RA-S-1.4-2013, December 2013.
- Southern Company Document Number SC-29980-202, Modernization of Technical Requirements for Licensing of Advanced Non-Light Water Reactors. Westinghouse eVinci™ Micro-Reactor Licensing Modernization Project Demonstration (ML19227A322)

Westinghouse Non-Proprietary Class 3 EMR LTR 190019
 Page 3 of 52



**Southern
Company**

Modernization of Technical Requirements
for Licensing of Advanced Non-Light Water Reactors

Westinghouse eVinci™ Micro-Reactor
Licensing Modernization Project Demonstration

Authors: Andrea Maioli, Heather L. Detar, Richard L. Haessler, Bryan N. Friedman,
Carly A. Belovesick, James H. Scobel, Sean T. Kinnas, Matthew C. Smith,
Jurie van Wyk, Karl Fleming

Document Number
SC-29980-202




August 2019

Prepared for:
U.S. Department of Energy (DOE)
Office of Nuclear Energy
Under DOE Idaho Operations Office
Contract DE-AC07-05ID14517

Issued final by: 

08/12/2019

Amir Afzali, Next Generation Licensing and Policy Director
Southern Company Services Date



westinghousenuclear.com

This page was added to the quality record by the PRIME system upon its validation and shall not be considered in the page numbering of this document.

Approval Information

Author Approval Maioli Andrea Feb-04-2020 16:01:51

Manager Approval Davis Stacy A Feb-04-2020 22:21:33

Files approved on Feb-04-2020

*** This record was final approved on 2/4/2020 10:21:33 PM. (This statement was added by the PRIME system upon its validation)