



Public Meeting

Between USNRC Davis-Besse Oversight
Panel and FirstEnergy Nuclear Operating
Company **December 10, 2002**



Purposes of This Meeting

- Inform the Public of the NRC's Oversight Panel Activities
- Discuss Licensee's Progress on Implementing the Return to Service Plan



Davis-Besse Oversight Panel - Public Meeting December 2002

AGENDA

- Introduction and Opening Remarks
- Summary of November 13th Public Meetings
- Discussion of NRC's Restart Checklist and Status of NRC Inspections
- Licensee Presentation on the Status of Their Return to Service Plan
- Adjourn NRC meeting with FENOC

<break>

- Public Comments and Questions of NRC
- Adjourn Meeting



Davis-Besse Oversight Panel - Public Meeting December 2002

***SUMMARY OF NOV. 13, 2002 PUBLIC MEETING**

- Topics Discussed
 - **Quality Assessment Value-Added**
 - **Reactor Vessel Bottom Head Plan**
 - **System Health Assurance**
 - **Design Issues Resolution**
 - **Management and Human Performance Actions**
 - **Operations Leadership Plan**

***Transcripts of the Nov. 13, 2002, meetings
will be available on our web site.**



Restart Checklist

- Adequacy of Root Cause Determination
 - Penetration cracking and reactor pressure vessel corrosion
 - Organizational, programmatic and human performance issues



Davis-Besse Oversight Panel - Public Meeting December 2002

Restart Checklist

- Adequacy of Safety Significant Structures, Systems, and Components
 - Reactor pressure vessel head replacement
 - Containment vessel restoration
 - Structures, systems and components inside containment
 - Emergency core cooling system and containment spray system sump
 - Systems outside containment



Restart Checklist

- Adequacy of Safety Significant Programs
 - Corrective action
 - Operating experience
 - Quality audits and self-assessments
 - Boric acid corrosion management
 - Reactor coolant system unidentified leakage monitoring
 - In-service inspection
 - Modification control
 - Radiation protection



Davis-Besse Oversight Panel - Public Meeting December 2002

Restart Checklist

- Adequacy of Organizational Effectiveness and Human Performance
 - Adequacy of root causes
 - Adequacy of corrective actions
 - Effectiveness of corrective actions



Restart Checklist

- Readiness for Restart
 - Systems readiness for restart
 - Operations readiness for restart
 - Test program development and implementation



Restart Checklist

- Licensing Issue and Confirmatory Action Letter Resolution
 - Resolve three limited ASME code relief requests
 - Meet with the NRC to obtain restart approval



Davis-Besse Oversight Panel - Public Meeting December 2002

CONTINUING NRC INSPECTIONS

- **Organizational Effectiveness and Human Performance**
- **Safety Significant Program Effectiveness**
- **Resident Inspection**