

Turkey Point 3

4Q/2001 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs



Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/00	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01
Unplanned scrams	0	0	0	0	0	0	1.0	0
Critical hours	1542.3	2183.0	2208.0	2209.0	2160.0	2183.0	2092.7	1584.2
Indicator value	0.9	0	0	0	0	0	0.8	0.9

Licensee Comments: none

Scrams with Loss of Normal Heat Removal




Thresholds: White > 2.0 Yellow > 10.0 Red > 20.0

Notes

Scrams with Loss of Normal Heat Removal	1Q/00	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01
Scrams	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/00	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01
Unplanned power changes	0	1.0	0	0	0	0	3.0	0
Critical hours	1542.3	2183.0	2208.0	2209.0	2160.0	2183.0	2092.7	1584.2
Indicator value	0	0.9	0.9	0.9	0.8	0	2.4	2.6

Licensee Comments: none

Safety System Unavailability, Emergency AC Power




Thresholds: White > 2.5% Yellow > 5.0% Red > 10.0%

Notes

Safety System Unavailability, Emergency AC Power	1Q/00	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01
Train 1								
Planned unavailable hours	0	2.50	2.80	4.00	4.00	34.50	3.40	8.50
Unplanned unavailable hours	17.00	0	51.10	0	4.00	8.20	0.80	1.60
Fault exposure hours	0	0	0	0	0	26.30	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	1894.00	2183.00	2208.00	2209.00	2160.00	2183.00	2201.00	1923.00
Train 2								
Planned unavailable hours	0	3.60	2.40	3.20	27.20	2.40	4.60	1.60
Unplanned unavailable hours	0	0	34.20	0	0	12.70	0.80	32.50
Fault exposure hours	0	0	268.70	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	1894.00	2183.00	2208.00	2209.00	2160.00	2183.00	2201.00	1923.00
Indicator value	1.3%	1.2%	1.8%	1.7%	1.8%	1.9%	1.9%	1.2%

Licensee Comments: none

Safety System Unavailability, High Pressure Injection System (HPSI)




Thresholds: White > 1.5% Yellow > 5.0% Red > 10.0%

Notes

Safety System Unavailability, High Pressure Injection System (HPSI)	1Q/00	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01
Train 1								
Planned unavailable hours	1.30	0	0	0	0	9.25	0.30	10.50
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	1581.40	2183.00	2208.00	2209.00	2160.00	2183.00	2188.00	1617.40
Train 2								
Planned unavailable hours	1.30	0	0	0	0	0	0.30	13.50
Unplanned unavailable hours	0	0	0	0	0	0	0	7.00
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	1581.40	2183.00	2208.00	2209.00	2160.00	2183.00	2188.00	1617.40
Indicator value	0.1%	0.1%	0%	0%	0%	0.1%	0%	0.1%

Licensee Comments: none

Safety System Unavailability, Heat Removal System (AFW)




Thresholds: White > 2.0% Yellow > 6.0% Red > 12.0%

Notes

Safety System Unavailability, Heat Removal System (AFW)	1Q/00	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01
Train 1								
Planned unavailable hours	19.20	5.60	0.40	0	0.50	3.80	0.40	0.90
Unplanned unavailable hours	0	10.40	1.30	0	0	0	0	0.50
Fault exposure hours	0	0	82.00	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	1581.40	2183.00	2208.00	2209.00	2160.00	2183.00	2188.00	1617.20
Train 2								
Planned unavailable hours	12.20	0	0.50	0	7.30	0.30	0.10	0.90
Unplanned unavailable hours	12.25	10.90	0	3.50	0	0	0	0
Fault exposure hours	0.25	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	1581.40	2183.00	2208.00	2209.00	2160.00	2183.00	2188.00	1617.20
Indicator value	0.6%	0.6%	0.6%	0.6%	0.5%	0.5%	0.5%	0.5%

Licensee Comments: none

Safety System Unavailability, Residual Heat Removal System




Thresholds: White > 1.5% Yellow > 5.0% Red > 10.0%

Notes

Safety System Unavailability, Residual Heat Removal System	1Q/00	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01
Train 1								
Planned unavailable hours	0.50	15.00	3.40	1.92	4.40	2.64	0.50	4.30
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	1932.40	2183.00	2208.00	2209.00	2160.00	2183.00	2208.00	1994.20
Train 2								
Planned unavailable hours	0.50	0.40	17.90	1.75	32.80	0.52	20.50	1.40
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	1932.40	2183.00	2208.00	2209.00	2160.00	2183.00	2208.00	1994.20
Indicator value	0.2%	0.1%	0.1%	0.1%	0.2%	0.2%	0.2%	0.2%

Licensee Comments: none

Safety System Functional Failures (PWR)



Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	1Q/00	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01
Safety System Functional Failures	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	1/00	2/00	3/00	4/00	5/00	6/00	7/00	8/00	9/00	10/00	11/00	12/00
Maximum activity	0.003800	0.006490	0.000448	0.000987	0.000968	0.001060	0.001150	0.001150	0.001260	0.001500	0.001250	0.001550
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.4	0.6	0	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.1	0.2

Reactor Coolant System Activity	1/01	2/01	3/01	4/01	5/01	6/01	7/01	8/01	9/01	10/01	11/01	12/01
Maximum activity	0.001400	0.001490	0.001620	0.001520	0.001610	0.001640	0.001630	0.001630	0.001840	0.000565	0.000772	0.000910
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.1

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	1/00	2/00	3/00	4/00	5/00	6/00	7/00	8/00	9/00	10/00	11/00	12/00
Maximum leakage	0.370	0.660	0.610	0.120	0.160	0.210	0.080	0.100	0.180	0.080	0.180	0.190
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	3.7	6.6	6.1	1.2	1.6	2.1	0.8	1.0	1.8	0.8	1.8	1.9

Reactor Coolant System Leakage	1/01	2/01	3/01	4/01	5/01	6/01	7/01	8/01	9/01	10/01	11/01	12/01
Maximum leakage	0.110	0.100	0.130	0.130	0.120	0.070	0.130	0.180	0.160	0.090	0.220	0.150
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.1	1.0	1.3	1.3	1.2	0.7	1.3	1.8	1.6	0.9	2.2	1.5

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	1Q/00	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01
Successful opportunities	58.0	58.0	51.0	10.0	71.0	56.0	41.0	40.0
Total opportunities	63.0	58.0	51.0	10.0	72.0	57.0	42.0	40.0
Indicator value	97.8%	97.9%	98.1%	97.9%	98.2%	97.9%	97.8%	98.0%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	1Q/00	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01
Participating Key personnel	70.0	70.0	66.0	66.0	67.0	69.0	67.0	67.0
Total Key personnel	70.0	70.0	67.0	66.0	67.0	69.0	67.0	69.0
Indicator value	100.0%	100.0%	98.5%	100.0%	100.0%	100.0%	100.0%	97.1%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	1Q/00	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01
Successful siren-tests	328	327	328	327	327	329	281	376
Total sirens-tests	329	329	329	329	329	329	282	376
Indicator value	99.7%	99.6%	99.6%	99.5%	99.5%	99.6%	99.6%	99.8%

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	1Q/00	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent




Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	1Q/00	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Protected Area Security Performance Index



Thresholds: White > 0.080

Notes

Protected Area Security Performance Index	1Q/00	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01
IDS compensatory hours	169.50	34.20	82.50	79.90	13.40	311.80	108.60	148.00
CCTV compensatory hours	0	0	5.4	28.9	0	0	0	0
IDS normalization factor	1.95	1.95	1.95	1.95	1.95	1.95	1.95	1.95
CCTV normalization factor	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2
Index Value	0.052	0.022	0.011	0.012	0.007	0.015	0.016	0.017

Licensee Comments: none

Personnel Screening Program



Thresholds: White > 2.0 Yellow > 5.0

Notes

Personnel Screening Program	1Q/00	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01
Program failures	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

FFD/Personnel Reliability



Thresholds: White > 2.0 Yellow > 5.0

Notes

FFD/Personnel Reliability	1Q/00	2Q/00	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01
Program Failures	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[PI Summary](#) | [Inspection Findings Summary](#) | [Action Matrix Summary](#) | [Reactor Oversight Process](#)

Last Modified: March 15, 2002