


Point Beach 1

2Q/2002 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02
Unplanned scrams	0	1.0	0	0	0	0	0	0
Critical hours	2208.0	2193.0	2160.0	1349.8	1961.6	2209.0	2160.0	2183.0
Indicator value	1.0	1.7	0.8	0.9	0.9	0	0	0

Licensee Comments: none

Scrams with Loss of Normal Heat Removal




Thresholds: White > 2.0 Yellow > 10.0 Red > 20.0

Notes

Scrams with Loss of Normal Heat Removal	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02
Scrams	0	1.0	0	0	0	0	0	0
Indicator value	2.0	3.0	3.0	3.0	3.0	3.0	3.0	2.0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02
Unplanned power changes	0	0	0	0	2.0	1.0	0	0
Critical hours	2208.0	2193.0	2160.0	1349.8	1961.6	2209.0	2160.0	2183.0
Indicator value	2.0	1.7	0.8	0	1.8	2.7	2.7	2.5

Licensee Comments: none

Safety System Unavailability, Emergency AC Power




Thresholds: White > 2.5% Yellow > 5.0% Red > 10.0%

Notes

Safety System Unavailability, Emergency AC Power	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02
Train 1								
Planned unavailable hours	62.87	54.45	31.75	10.83	12.37	21.07	18.39	27.53
Unplanned unavailable hours	4.37	0.37	0	0	0	0	0	2.60
Fault exposure hours	585.47	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2208.00	2209.00	2160.00	2183.00	2208.00	2209.00	2160.00	2183.00
Train 2								
Planned unavailable hours	17.82	29.68	49.82	24.47	22.59	24.60	13.76	16.02
Unplanned unavailable hours	0	0	0	0	0	0	1.98	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2208.00	2209.00	2160.00	2183.00	2208.00	2209.00	2160.00	2183.00
Indicator value	2.3%	2.4%	2.4%	2.2%	2.1%	2.1%	2.2%	2.2%

Licensee Comments: none

Safety System Unavailability, High Pressure Injection System (HPSI)




Thresholds: White > 1.5% Yellow > 5.0% Red > 10.0%

Notes

Safety System Unavailability, High Pressure Injection System (HPSI)	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02
Train 1								
Planned unavailable hours	6.87	1.53	7.42	1.09	3.92	23.18	9.91	24.65
Unplanned unavailable hours	0	0	0	1.00	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2208.00	2209.00	2160.00	1344.60	1961.60	2209.00	2160.00	2183.00
Train 2								
Planned unavailable hours	8.50	3.45	6.53	0.30	2.34	12.57	11.27	24.08
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2208.00	2209.00	2160.00	1344.60	1961.60	2209.00	2160.00	2183.00
Indicator value	0.2%	0.2%	0.2%	0.2%	0.2%	0.3%	0.2%	0.3%

Licensee Comments: none

Safety System Unavailability, Heat Removal System (AFW)




Thresholds: White > 2.0% Yellow > 6.0% Red > 12.0%

Notes

Safety System Unavailability, Heat Removal System (AFW)	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02
Train 1								
Planned unavailable hours	4.27	0.77	8.14	3.75	25.30	4.26	25.46	8.11
Unplanned unavailable hours	0	3.06	0	15.88	0	27.53	0	0
Fault exposure hours	0	0	0	0	0	13.23	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2208.00	2209.00	2160.00	1478.95	2016.00	2209.00	2160.00	2183.00
Train 2								
Planned unavailable hours	6.05	29.48	23.50	2.50	6.60	3.23	12.90	12.80
Unplanned unavailable hours	0	0.50	16.20	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2208.00	2209.00	2160.00	1478.95	2016.00	2209.00	2160.00	2183.00
Train 3								
Planned unavailable hours	34.55	107.56	5.80	2.33	13.69	2.62	13.95	63.72
Unplanned unavailable hours	0	0	0.07	0	0	0	8.47	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2208.00	2209.00	2160.00	1478.95	2016.00	2209.00	2160.00	2183.00
Indicator value	1.1%	1.2%	1.1%	1.0%	1.0%	0.9%	0.9%	0.9%

Licensee Comments: none

Safety System Unavailability, Residual Heat Removal System




Thresholds: White > 1.5% Yellow > 5.0% Red > 10.0%

Notes

Safety System Unavailability, Residual Heat Removal System	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02
Train 1								
Planned unavailable hours	7.99	1.20	19.00	8.60	28.22	3.24	27.81	0.85
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2208.00	2209.00	2160.00	1968.90	2208.00	2209.00	2160.00	2183.00
Train 2								
Planned unavailable hours	1.02	0.56	16.67	6.54	7.80	2.36	0.45	0.57
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2208.00	2209.00	2160.00	1968.90	2208.00	2209.00	2160.00	2183.00
Indicator value	0.2%	0.2%	0.2%	0.2%	0.3%	0.2%	0.3%	0.3%

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02
Safety System Functional Failures	0	0	0	1	0	0	2	0
Indicator value	0	0	0	1	1	1	3	2

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	7/00	8/00	9/00	10/00	11/00	12/00	1/01	2/01	3/01	4/01	5/01	6/01
Maximum activity	0.001790	0.001920	0.002000	0.001920	0.002030	0.002110	0.002210	0.002250	0.002320	0.002310	0.001100	0.001200
Technical specification limit	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8
Indicator value	0.2	0.2	0.3	0.2	0.3	0.3	0.3	0.3	0.3	0.3	0.1	0.2

Reactor Coolant System Activity	7/01	8/01	9/01	10/01	11/01	12/01	1/02	2/02	3/02	4/02	5/02	6/02
Maximum activity	0.001260	0.001370	0.001250	0.001350	0.001420	0.001500	0.001530	0.001610	0.001650	0.001630	0.001720	0.001750
Technical specification limit	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8
Indicator value	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	7/00	8/00	9/00	10/00	11/00	12/00	1/01	2/01	3/01	4/01	5/01	6/01
Maximum leakage	0.146	0.170	0.163	0.180	0.230	0.416	0.167	0.200	0.220	0.090	0.336	0.270
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.5	1.7	1.6	1.8	2.3	4.2	1.7	2.0	2.2	0.9	3.4	2.7
Reactor Coolant System Leakage	7/01	8/01	9/01	10/01	11/01	12/01	1/02	2/02	3/02	4/02	5/02	6/02
Maximum leakage	0.420	0.786	0.800	0.096	0.140	0.186	0.100	0.460	0.150	0.180	0.180	0.120
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	4.2	7.9	8.0	1.0	1.4	1.9	1.0	4.6	1.5	1.8	1.8	1.2

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02
Successful opportunities	14.0	30.0	4.0	2.0	4.0	15.0	12.0	0
Total opportunities	14.0	30.0	4.0	2.0	4.0	16.0	12.0	0
Indicator value	96.0%	96.2%	96.0%	96.6%	97.7%	98.8%	99.0%	98.8%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02
Participating Key personnel	36.0	34.0	35.0	34.0	35.0	45.0	46.0	44.0
Total Key personnel	37.0	35.0	35.0	35.0	38.0	49.0	49.0	47.0
Indicator value	97.3%	97.1%	100.0%	97.1%	92.1%	91.8%	93.9%	93.6%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02
Successful siren-tests	84	83	83	83	83	84	82	83
Total sirens-tests	84	84	84	84	84	84	84	84
Indicator value	94.0%	94.3%	97.6%	99.1%	98.8%	99.1%	98.8%	98.8%

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02
High radiation area occurrences	0	0	0	1	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	1	1	1	1	0

Licensee Comments: none

RETS/ODCM Radiological Effluent




Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Protected Area Security Performance Index



Thresholds: White > 0.080

Notes

Protected Area Security Performance Index	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02
IDS compensatory hours	0	0	19.50	0	109.90	71.30	187.20	51.30
CCTV compensatory hours	3.8	30.4	7.6	0	58.0	0	19.8	0.1
IDS normalization factor	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20
CCTV normalization factor	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Index Value	0.001	0.002	0.003	0.003	0.012	0.013	0.022	0.024

Licensee Comments:


2Q/02: On 6/13/02, it was decided to discontinue use of the exemption and begin reporting compensatory hours for out of service security equipment. Data for the past three quarters has been revised via change reports to include the compensatory hours previously unreported. No change to color.

1Q/02: On 6/13/02, it was decided to discontinue use of the exemption and begin reporting compensatory hours for out of service security equipment. Data for the past three quarters has been revised via change reports to include the compensatory hours previously unreported. No change to color.

4Q/01: On 6/13/02, it was decided to discontinue use of the exemption and begin reporting compensatory hours for out of service security equipment. Data for the past three quarters has been revised via change reports to include the compensatory hours previously unreported. No change to color.

3Q/01: On 6/13/02, it was decided to discontinue use of the exemption and begin reporting compensatory hours for out of service security equipment. Data for the past three quarters has been revised via change reports to include the compensatory hours previously unreported. No change to color.

Personnel Screening Program



Thresholds: White > 2.0 Yellow > 5.0

Notes

Personnel Screening Program	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02
Program failures	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

FFD/Personnel Reliability



Thresholds: White > 2.0 Yellow > 5.0

Notes

FFD/Personnel Reliability	3Q/00	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02
Program Failures	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

▲ [PI Summary](#) | [Inspection Findings Summary](#) | [Reactor Oversight Process](#)

Last Modified: July 31, 2002