


Beaver Valley 1

3Q/2002 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs



Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Unplanned scrams	0	0	1.0	0	2.0	0	0	0
Critical hours	2209.0	2160.0	1905.1	1488.9	1908.5	2160.0	2183.0	2208.0
Indicator value	1.9	1.6	1.7	0.9	2.8	2.8	1.8	1.7

Licensee Comments:

3Q/01: Corrected September 2001 data to indicate 0.9 critical hours rather than zero.

Scrams with Loss of Normal Heat Removal




Thresholds: White > 2.0 Yellow > 10.0 Red > 20.0

Notes

Scrams with Loss of Normal Heat Removal	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Scrams	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0


Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Unplanned power changes	1.0	0	0	0	0	1.0	0	0
Critical hours	2209.0	2160.0	1905.1	1488.9	1908.5	2160.0	2183.0	2208.0
Indicator value	2.8	2.5	1.7	0.9	0	0.9	0.9	0.8

Licensee Comments:

3Q/01: Corrected September 2001 data to indicate 0.9 critical hours rather than zero.

Safety System Unavailability, Emergency AC Power




Thresholds: White > 2.5% Yellow > 5.0% Red > 10.0%

Notes

Safety System Unavailability, Emergency AC Power	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Train 1								
Planned unavailable hours	8.80	5.20	26.80	4.10	10.40	4.40	7.00	31.10
Unplanned unavailable hours	0	0	0	0	0	0	0	12.10
Fault exposure hours	0	0	0	102.50	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2209.00	2160.00	2183.00	2208.00	2209.00	2160.00	2183.00	2208.00
Train 2								
Planned unavailable hours	5.60	43.80	6.20	3.70	7.00	11.70	5.50	19.50
Unplanned unavailable hours	0	0.10	0	0	22.60	25.50	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2209.00	2160.00	2183.00	2208.00	2209.00	2160.00	2183.00	2208.00
Indicator value	0.9%	0.8%	0.9%	1.0%	1.1%	1.2%	1.2%	1.3%

Licensee Comments: none

Safety System Unavailability, High Pressure Injection System (HPSI)




Thresholds: White > 1.5% Yellow > 5.0% Red > 10.0%

Notes

Safety System Unavailability, High Pressure Injection System (HPSI)	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Train 1								
Planned unavailable hours	6.37	13.32	9.04	0.98	2.59	1.27	3.73	10.09
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2209.00	2160.00	2001.70	1494.77	2124.48	2160.00	2183.00	2208.00
Train 2								
Planned unavailable hours	1.86	2.28	2.09	4.07	4.29	3.07	2.79	1.35
Unplanned unavailable hours	0	0	0	0	0	0	0.40	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2209.00	2160.00	2001.70	1494.77	2124.48	2160.00	2183.00	2208.00
Indicator value	0.9%	0.8%	0.8%	0.8%	0.7%	0.6%	0.5%	0.5%

Licensee Comments: none

Safety System Unavailability, Heat Removal System (AFW)




Thresholds: White > 2.0% Yellow > 6.0% Red > 12.0%

Notes

Safety System Unavailability, Heat Removal System (AFW)	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Train 1								
Planned unavailable hours	14.02	0	1.50	0.12	1.00	2.27	3.82	29.88
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2209.00	2160.00	2001.70	1494.77	2124.48	2160.00	2183.00	2208.00
Train 2								
Planned unavailable hours	17.72	0	12.87	0	4.77	0	0	0.98
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2209.00	2160.00	2001.70	1494.77	2124.48	2160.00	2183.00	2208.00
Train 3								
Planned unavailable hours	16.90	2.28	11.80	0.55	68.30	0	1.38	1.50
Unplanned unavailable hours	33.30	10.08	0	0	0	0	5.20	0
Fault exposure hours	0.42	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2209.00	2160.00	2001.70	1494.77	2107.08	2160.00	2183.00	2208.00
Indicator value	0.4%	0.4%	0.4%	0.4%	0.4%	0.4%	0.4%	0.4%

Licensee Comments: none

Safety System Unavailability, Residual Heat Removal System




Thresholds: White > 1.5% Yellow > 5.0% Red > 10.0%

Notes

Safety System Unavailability, Residual Heat Removal System	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Train 1								
Planned unavailable hours	18.70	1.72	10.63	0.98	1.75	8.33	17.25	1.21
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2209.00	2160.00	2001.70	1494.77	2124.48	2160.00	2183.00	2208.00
Train 2								
Planned unavailable hours	41.30	0.65	0.33	1.02	12.11	2.14	1.10	1.35
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2209.00	2160.00	2001.70	1494.77	2124.48	2160.00	2183.00	2208.00
Train 3								
Planned unavailable hours	0	0	0	0	0.52	0	0	0
Unplanned unavailable hours	0	0	0.60	0	0	0	0	0
Fault exposure hours	0	0	0.80	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	0	0	194.12	606.32	75.11	0	0	0
Train 4								
Planned unavailable hours	0	0	0	0	0	0	0	0
Unplanned unavailable hours	0	0	0.60	0	0	0	0	0
Fault exposure hours	0	0	0.80	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	0	0	194.12	606.32	76.56	0	0	0
Indicator value	1.1%	1.2%	1.3%	1.3%	1.1%	1.1%	0.9%	0.7%

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Safety System Functional Failures	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	10/00	11/00	12/00	1/01	2/01	3/01	4/01	5/01	6/01	7/01	8/01	9/01
Maximum activity	0.000743	0.000654	0.000793	0.000874	0.000739	0.000982	0.000779	0.000917	0.000854	0.000918	0.000914	N/A
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1
Indicator value	0.4	0.3	0.4	0.4	0.4	0.5	0.4	0.9	0.9	0.9	0.9	N/A

Reactor Coolant System Activity	10/01	11/01	12/01	1/02	2/02	3/02	4/02	5/02	6/02	7/02	8/02	9/02
Maximum activity	0.000360	0.000389	0.000376	0.000515	0.000448	0.000433	0.000540	0.000540	0.000570	0.000539	0.000650	0.000606
Technical specification limit	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Indicator value	0.4	0.4	0.4	0.5	0.4	0.4	0.5	0.5	0.6	0.5	0.7	0.6

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	10/00	11/00	12/00	1/01	2/01	3/01	4/01	5/01	6/01	7/01	8/01	9/01
Maximum leakage	0.040	0.040	0.040	0.030	0.030	0.030	0.020	0.050	0.030	0.030	0.110	N/A
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.4	0.4	0.4	0.3	0.3	0.3	0.2	0.5	0.3	0.3	1.1	N/A

Reactor Coolant System Leakage	10/01	11/01	12/01	1/02	2/02	3/02	4/02	5/02	6/02	7/02	8/02	9/02
Maximum leakage	0.050	0.030	0.050	0.060	0.040	0.050	0.040	0.050	0.050	0.140	0.060	0.060
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.5	0.3	0.5	0.6	0.4	0.5	0.4	0.5	0.5	1.4	0.6	0.6

Licensee Comments: none

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%


Notes

Drill/Exercise Performance	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Successful opportunities	46.0	8.0	71.0	38.0	39.0	5.0	25.0	46.0
Total opportunities	47.0	8.0	75.0	39.0	39.0	5.0	30.0	48.0
Indicator value	97.9%	97.9%	97.1%	97.0%	97.2%	97.1%	95.6%	95.5%

Licensee Comments:

2Q/02: Corrected May 2002 data (from 15 of 18) to 11 of 14.

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Participating Key personnel	85.0	85.0	91.0	102.0	104.0	104.0	105.0	120.0
Total Key personnel	85.0	85.0	91.0	102.0	104.0	104.0	105.0	120.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Successful siren-tests	110	110	110	109	218	109	117	117
Total sirens-tests	110	110	110	110	220	110	117	117
Indicator value	99.5%	99.6%	99.6%	99.8%	99.5%	99.3%	99.3%	99.5%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent




Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Protected Area Security Performance Index




Thresholds: White > 0.080

Notes

Protected Area Security Performance Index	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
IDS compensatory hours	373.33	155.00	584.02	108.39	119.85	287.09	420.56	196.75
CCTV compensatory hours	0	1.6	0	0	7.1	0	6.4	0
IDS normalization factor	2.85	2.85	2.82	2.75	2.75	2.75	2.75	2.75
CCTV normalization factor	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5
Index Value	0.020	0.020	0.030	0.025	0.020	0.023	0.020	0.022

Licensee Comments: none

Personnel Screening Program




Thresholds: White > 2.0 Yellow > 5.0

Notes

Personnel Screening Program	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Program failures	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

FFD/Personnel Reliability



Thresholds: White > 2.0 Yellow > 5.0

Notes

FFD/Personnel Reliability	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Program Failures	0	0	0	0	0	0	1	0
Indicator value	0	0	0	0	0	0	1	1

Licensee Comments: none

▲ [PI Summary](#) | [Inspection Findings Summary](#) | [Reactor Oversight Process](#)

Last Modified: October 22, 2002