


Wolf Creek 1

3Q/2002 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs



Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Unplanned scrams	0	0	0	0	0	0	1.0	0
Critical hours	1340.7	2160.0	2183.0	2208.0	2209.0	1946.2	1408.1	2208.0
Indicator value	0.9	0.9	0.9	0	0	0	0.9	0.9

Licensee Comments: none

Scrams with Loss of Normal Heat Removal




Thresholds: White > 2.0 Yellow > 10.0 Red > 20.0

Notes

Scrams with Loss of Normal Heat Removal	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Scrams	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Unplanned power changes	0	0	0	0	0	0	1.0	0
Critical hours	1340.7	2160.0	2183.0	2208.0	2209.0	1946.2	1408.1	2208.0
Indicator value	0	0	0	0	0	0	0.9	0.9

Licensee Comments: none

Safety System Unavailability, Emergency AC Power




Thresholds: White > 2.5% Yellow > 5.0% Red > 10.0%

Notes

Safety System Unavailability, Emergency AC Power	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Train 1								
Planned unavailable hours	15.72	2.72	31.00	0.70	42.84	1.12	35.53	20.48
Unplanned unavailable hours	0	0	14.08	0	0	15.73	5.68	0.08
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2209.00	2160.00	2183.00	2208.00	2209.00	1956.70	1863.00	2208.00
Train 2								
Planned unavailable hours	0.95	9.27	0.98	18.10	16.03	44.00	0.70	21.11
Unplanned unavailable hours	7.43	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2209.00	2160.00	2183.00	2208.00	2209.00	2160.00	1841.40	2208.00
Indicator value	1.4%	1.3%	1.3%	1.2%	1.2%	1.1%	1.1%	1.1%

Licensee Comments: none

Safety System Unavailability, High Pressure Injection System (HPSI)




Thresholds: White > 1.5% Yellow > 5.0% Red > 10.0%

Notes

Safety System Unavailability, High Pressure Injection System (HPSI)	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Train 1								
Planned unavailable hours	8.32	8.13	6.73	0.17	40.81	7.60	11.67	2.04
Unplanned unavailable hours	0	0	0	0	0	0	0	4.28
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	1421.00	2160.00	2183.00	2208.00	2209.00	1952.90	1512.60	2208.00
Train 2								
Planned unavailable hours	0.74	5.59	19.73	15.80	6.55	6.57	10.17	8.76
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	1385.00	2160.00	2183.00	2208.00	2209.00	1956.70	1499.90	2208.00
Train 3								
Planned unavailable hours	8.30	16.45	0.16	7.07	30.73	0.51	9.71	5.53
Unplanned unavailable hours	0	0	0	0	4.00	0	0	0.08
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	1385.00	2160.00	2183.00	2208.00	2209.00	1952.90	1491.10	2208.00
Train 4								
Planned unavailable hours	0	13.74	0	23.58	0.70	6.42	2.34	14.01
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	1385.00	2160.00	2183.00	2208.00	2209.00	1952.90	1491.10	2208.00
Indicator value	0.9%	0.9%	0.9%	0.9%	0.9%	0.8%	0.8%	0.8%

Licensee Comments: none

Safety System Unavailability, Heat Removal System (AFW)




Thresholds: White > 2.0% Yellow > 6.0% Red > 12.0%

Notes

Safety System Unavailability, Heat Removal System (AFW)	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Train 1								
Planned unavailable hours	9.25	5.68	0.10	20.65	31.80	9.55	10.08	1.65
Unplanned unavailable hours	0	0	0	0	0	0	0	0.08
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	1385.00	2160.00	2183.00	2208.00	2209.00	1952.90	1491.10	2208.00
Train 2								
Planned unavailable hours	1.78	17.66	0	30.61	2.45	11.30	1.42	13.98
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	1385.00	2160.00	2183.00	2208.00	2209.00	1952.90	1491.10	2208.00
Train 3								
Planned unavailable hours	2.04	9.03	0.25	11.52	1.31	5.81	0.10	4.38
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	1385.00	2160.00	2183.00	2208.00	2209.00	1952.90	1491.10	2208.00
Indicator value	1.0%	0.9%	0.9%	0.9%	0.9%	0.7%	0.7%	0.6%

Licensee Comments: none

Safety System Unavailability, Residual Heat Removal System




Thresholds: White > 1.5% Yellow > 5.0% Red > 10.0%

Notes

Safety System Unavailability, Residual Heat Removal System	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Train 1								
Planned unavailable hours	7.97	7.65	10.09	6.84	35.81	9.27	8.91	0.40
Unplanned unavailable hours	0	0	0	0	0	0	0	0.08
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2209.00	2160.00	2183.00	2208.00	2209.00	2081.40	1925.90	2208.00
Train 2								
Planned unavailable hours	0	6.88	10.13	15.58	6.15	9.25	2.40	8.18
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2209.00	2160.00	2183.00	2208.00	2209.00	2160.00	1734.70	2208.00
Indicator value	0.9%	0.9%	0.9%	0.9%	0.9%	0.7%	0.8%	0.8%

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Safety System Functional Failures	0	0	0	0	0	1	0	0
Indicator value	0	0	0	0	0	1	1	1

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	10/00	11/00	12/00	1/01	2/01	3/01	4/01	5/01	6/01	7/01	8/01	9/01
Maximum activity	N/A	0.001530	0.001930	0.002240	0.003000	0.003000	0.003000	0.002000	0.003000	0.003000	0.003000	0.003000
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	N/A	0.2	0.2	0.2	0.3	0.3	0.3	0.2	0.3	0.3	0.3	0.3

Reactor Coolant System Activity	10/01	11/01	12/01	1/02	2/02	3/02	4/02	5/02	6/02	7/02	8/02	9/02
Maximum activity	0.003000	0.003000	0.003000	0.003000	0.003000	0.004000	N/A	0.000700	0.001100	0.003000	0.001000	0.002000
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.3	0.3	0.3	0.3	0.3	0.4	N/A	0.1	0.1	0.3	0.1	0.2

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	10/00	11/00	12/00	1/01	2/01	3/01	4/01	5/01	6/01	7/01	8/01	9/01
Maximum leakage	N/A	0.155	0.161	0.162	0.162	0.162	0.163	0.160	0.161	0.195	0.163	0.160
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	N/A	1.5	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.9	1.6	1.6

Reactor Coolant System Leakage	10/01	11/01	12/01	1/02	2/02	3/02	4/02	5/02	6/02	7/02	8/02	9/02
Maximum leakage	0.160	0.160	0.160	0.170	0.160	0.160	0.650	0.620	0.110	0.040	0.020	0.020
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.6	1.6	1.6	1.7	1.6	1.6	6.5	6.2	1.1	0.4	0.2	0.2

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Successful opportunities	25.0	55.0	29.0	26.0	59.0	6.0	32.0	44.0
Total opportunities	25.0	59.0	30.0	26.0	63.0	6.0	36.0	48.0
Indicator value	96.2%	95.6%	95.5%	95.4%	95.1%	94.7%	93.7%	94.2%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Participating Key personnel	46.0	46.0	44.0	43.0	42.0	46.0	46.0	44.0
Total Key personnel	46.0	46.0	44.0	43.0	43.0	46.0	46.0	44.0
Indicator value	100.0%	100.0%	100.0%	100.0%	97.7%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Successful siren-tests	77	66	74	63	76	76	75	65
Total sirens-tests	77	66	77	66	77	77	77	66
Indicator value	99.7%	99.7%	99.0%	97.9%	97.6%	97.3%	97.6%	98.3%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent




Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Protected Area Security Performance Index




Thresholds: White > 0.080

Notes

Protected Area Security Performance Index	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
IDS compensatory hours	106.30	14.80	28.10	50.80	133.00	88.50	23.60	6.30
CCTV compensatory hours	26.7	2.6	1.1	3.3	2.8	0.5	2.3	6.9
IDS normalization factor	1.50	1.50	1.55	1.55	1.55	1.55	1.55	1.55
CCTV normalization factor	1.3	1.4	1.4	1.4	1.4	1.4	1.4	1.4
Index Value	0.014	0.011	0.009	0.009	0.009	0.011	0.011	0.010

Licensee Comments: none

Personnel Screening Program



Thresholds: White > 2.0 Yellow > 5.0

Notes

Personnel Screening Program	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Program failures	0	0	0	0	0	0	0	0
Indicator value	1	1	1	0	0	0	0	0

Licensee Comments: none

FFD/Personnel Reliability



Thresholds: White > 2.0 Yellow > 5.0

Notes

FFD/Personnel Reliability	4Q/00	1Q/01	2Q/01	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02
Program Failures	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

▲ [PI Summary](#) | [Inspection Findings Summary](#) | [Reactor Oversight Process](#)

Last Modified: October 22, 2002