


Fort Calhoun

3Q/2006 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/04	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06
Unplanned scrams	0	1.0	0	0	0	0	0	0
Critical hours	2209.0	1365.6	537.4	2208.0	2209.0	2160.0	2032.2	1700.5
Indicator value	0	0.9	1.1	1.1	1.1	0	0	0

Licensee Comments: none

Scrams with Loss of Normal Heat Removal




Thresholds: White > 2.0 Yellow > 10.0 Red > 20.0

Notes

Scrams with Loss of Normal Heat Removal	4Q/04	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06
Scrams	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/04	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06
Unplanned power changes	0	0	2.0	0	0	0	0	0
Critical hours	2209.0	1365.6	537.4	2208.0	2209.0	2160.0	2032.2	1700.5
Indicator value	0	0	2.2	2.2	2.2	2.0	0	0

Licensee Comments: none

Safety System Functional Failures (PWR)



Thresholds: White > 5.0


Notes

Safety System Functional Failures (PWR)	4Q/04	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06
Safety System Functional Failures	0	0	0	0	0	0	0	1
Indicator value	0	0	0	0	0	0	0	1

Licensee Comments:

3Q/06: LER 2006-002 "Inadequate Design Control Results in Potentially Insufficient Auxiliary Feedwater Flow" documents the SSFF for September 2006.

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	4Q/04	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06
UAI (Δ CDF)							7.10E-08	4.80E-08
URI (Δ CDF)							5.10E-07	5.30E-07
PLE							NO	NO
Indicator value							5.81E-07	5.78E-07

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	4Q/04	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06
UAI (Δ CDF)							3.50E-08	8.20E-08
URI (Δ CDF)							2.50E-07	-4.70E-08
PLE							NO	NO
Indicator value							2.85E-07	3.50E-08

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	4Q/04	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06
UAI (Δ CDF)							2.20E-08	2.50E-08
URI (Δ CDF)							-2.60E-07	-2.70E-07
PLE							NO	NO
Indicator value							-2.38E-07	-2.45E-07

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	4Q/04	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06
UAI (ΔCDF)							-1.20E-07	-1.20E-07
URI (ΔCDF)							2.80E-07	-2.30E-08
PLE							NO	NO
Indicator value							1.60E-07	-1.43E-07

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	4Q/04	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06
UAI (Δ CDF)							-2.00E-07	-1.90E-07
URI (Δ CDF)							-1.70E-08	-7.20E-09
PLE							NO	NO
Indicator value							-2.17E-07	-1.97E-07

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity		10/04	11/04	12/04	1/05	2/05	3/05	4/05	5/05	6/05	7/05	8/05	9/05
Maximum activity		0.018700	0.019000	0.019500	0.019800	0.029600	N/A	N/A	N/A	0.008150	0.009350	0.009300	0.009700
Technical specification limit		1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value		1.9	1.9	2.0	2.0	3.0	N/A	N/A	N/A	0.8	0.9	0.9	1.0

Reactor Coolant System Activity		10/05	11/05	12/05	1/06	2/06	3/06	4/06	5/06	6/06	7/06	8/06	9/06
Maximum activity		0.010300	0.010100	0.013200	0.010400	0.011100	0.010700	0.017300	0.011000	0.011300	0.011400	0.011800	0.011300
Technical specification limit		1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value		1.0	1.0	1.3	1.0	1.1	1.1	1.7	1.1	1.1	1.1	1.2	1.1

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	10/04	11/04	12/04	1/05	2/05	3/05	4/05	5/05	6/05	7/05	8/05	9/05
Maximum leakage	0.119	0.135	0.149	0.181	0.146	N/A	N/A	0.216	0.432	0.099	0.118	0.098
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.2	1.4	1.5	1.8	1.5	N/A	N/A	2.2	4.3	1.0	1.2	1.0

Reactor Coolant System Leakage	10/05	11/05	12/05	1/06	2/06	3/06	4/06	5/06	6/06	7/06	8/06	9/06
Maximum leakage	0.099	0.246	0.209	0.167	0.124	0.134	0.184	0.157	0.111	0.121	0.140	0.094
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.0	2.5	2.1	1.7	1.2	1.3	1.8	1.6	1.1	1.2	1.4	0.9

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	4Q/04	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06
Successful opportunities	46.0	11.0	9.0	22.0	52.0	17.0	31.0	27.0
Total opportunities	46.0	12.0	9.0	22.0	55.0	19.0	36.0	27.0
Indicator value	96.9%	97.0%	97.6%	97.9%	96.9%	95.9%	94.1%	95.1%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	4Q/04	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06
Participating Key personnel	91.0	90.0	86.0	87.0	89.0	90.0	100.0	101.0
Total Key personnel	94.0	95.0	92.0	90.0	92.0	93.0	104.0	106.0
Indicator value	96.8%	94.7%	93.5%	96.7%	96.7%	96.8%	96.2%	95.3%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	4Q/04	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06
Successful siren-tests	699	798	702	897	702	807	706	804
Total sirens-tests	707	808	707	909	707	808	707	808
Indicator value	98.9%	98.9%	99.0%	98.9%	99.0%	99.3%	99.4%	99.6%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	4Q/04	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06
High radiation area occurrences	0	1	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	1	1	1	1	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	4Q/04	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Physical Protection](#) information not publicly available.