


Dresden 2

4Q/2006 Performance Indicators

Licensee's General Comments: THIS FILE REFLECTS RECENT CHANGES MADE TO MSPI VALUES FOR SECOND AND THIRD QUARTERS.

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06
Unplanned scrams	1.0	0	0	0	0	0	1.0	0
Critical hours	2094.0	2183.0	1882.2	1735.1	2160.0	2183.0	2168.9	2003.2
Indicator value	2.9	0.9	0.9	0.9	0	0	0.8	0.8

Licensee Comments: none

Scrams with Loss of Normal Heat Removal




Thresholds: White > 2.0 Yellow > 10.0 Red > 20.0

Notes

Scrams with Loss of Normal Heat Removal	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06
Scrams	1.0	0	0	0	0	0	1.0	0
Indicator value	2.0	2.0	2.0	2.0	2.0	2.0	3.0	3.0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06
Unplanned power changes	0	0	1.0	1.0	1.0	1.0	0	0
Critical hours	2094.0	2183.0	1882.2	1735.1	2160.0	2183.0	2168.9	2003.2
Indicator value	2.0	1.9	1.9	1.8	2.6	3.5	2.5	1.6

Licensee Comments: none

Safety System Functional Failures (BWR)




Thresholds: White > 6.0

Notes

Safety System Functional Failures (BWR)	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06
Safety System Functional Failures	0	0	0	0	0	2	0	0
Indicator value	2	0	0	0	0	2	2	2

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes


Mitigating Systems Performance Index, Emergency AC Power System	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06
UAI (Δ CDF)						-4.60E-09	-4.10E-09	-4.10E-09
URI (Δ CDF)						-3.50E-08	-3.10E-08	-3.10E-08
PLE						NO	NO	NO
Indicator value						-3.96E-08	-3.51E-08	-3.51E-08

Licensee Comments:

3Q/06: Revised Baseline Data

2Q/06: Baseline Unavailability was corrected.

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06
UAI (Δ CDF)						-5.20E-08	-4.60E-08	-4.60E-08
URI (Δ CDF)						-7.20E-08	-6.40E-08	-6.40E-08
PLE						NO	NO	NO
Indicator value						-1.24E-07	-1.10E-07	-1.10E-07

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06
UAI (Δ CDF)						-1.50E-09	-1.30E-09	-1.30E-09
URI (Δ CDF)						-9.90E-10	-1.00E-10	-1.00E-10
PLE						NO	NO	NO
Indicator value						-2.49E-09	-1.40E-09	-1.40E-09

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Residual Heat Removal System	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06
UAI (Δ CDF)						-9.90E-10	-8.70E-10	-1.10E-09
URI (Δ CDF)						-1.80E-09	-1.50E-09	-1.50E-09
PLE						NO	NO	NO
Indicator value						-2.79E-09	-2.37E-09	-2.60E-09

Licensee Comments:

3Q/06: Revised Baseline Unavailability Revised Monthly Unavailability

Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes


Mitigating Systems Performance Index, Cooling Water Systems	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06
UAI (ΔCDF)						6.50E-12	4.20E-10	2.60E-10
URI (ΔCDF)						-2.50E-11	-2.10E-11	-2.00E-11
PLE						NO	NO	NO
Indicator value						-1.85E-11	3.99E-10	2.40E-10

Licensee Comments:

3Q/06: Revised Baseline Unavailability Revised Monthly Unavailability

2Q/06: Baseline Unavailability was corrected. Monthly unavailability data was also corrected.

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	1/05	2/05	3/05	4/05	5/05	6/05	7/05	8/05	9/05	10/05	11/05	12/05
Maximum activity	0.000032	0.000043	0.000006	0.000006	0.000005	0.000005	0.000006	0.000006	0.000007	0.000012	0.000004	0.000005
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Reactor Coolant System Activity	1/06	2/06	3/06	4/06	5/06	6/06	7/06	8/06	9/06	10/06	11/06	12/06
Maximum activity	0.000005	0.000005	0.000004	0.000004	0.000004	0.000004	0.000004	0.000003	0.000003	0.000003	0.000004	0.000004
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	1/05	2/05	3/05	4/05	5/05	6/05	7/05	8/05	9/05	10/05	11/05	12/05
Maximum leakage	1.650	1.643	1.655	1.717	1.687	1.687	1.670	1.658	1.663	1.668	2.600	2.423
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	6.6	6.6	6.6	6.9	6.7	6.7	6.7	6.6	6.7	6.7	10.4	9.7

Reactor Coolant System Leakage	1/06	2/06	3/06	4/06	5/06	6/06	7/06	8/06	9/06	10/06	11/06	12/06
Maximum leakage	2.482	2.550	2.515	2.877	2.945	2.978	2.900	1.867	1.832	1.832	1.965	1.813
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	9.9	10.2	10.1	11.5	11.8	11.9	11.6	7.5	7.3	7.3	7.9	7.3

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06
Successful opportunities	58.0	24.0	26.0	47.0	48.0	38.0	14.0	12.0
Total opportunities	59.0	26.0	27.0	48.0	48.0	38.0	19.0	12.0
Indicator value	95.6%	96.7%	96.6%	96.9%	97.2%	97.9%	96.3%	96.4%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06
Participating Key personnel	60.0	62.0	63.0	64.0	69.0	66.0	65.0	66.0
Total Key personnel	60.0	62.0	63.0	64.0	69.0	66.0	65.0	66.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06
Successful siren-tests	4983	4972	4966	4988	5061	4979	4971	4902
Total sirens-tests	4992	4991	4992	4992	5070	4991	4992	4914
Indicator value	99.4%	99.6%	99.7%	99.7%	99.7%	99.7%	99.8%	99.7%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	1Q/05	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Physical Protection](#) information not publicly available.