


# Peach Bottom 2

## 1Q/2007 Performance Indicators

Licensee's General Comments: none

### Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

### Notes

Unplanned Scrams per 7000 Critical Hrs	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07
Unplanned scrams	0	1.0	0	0	0	0	1.0	0
Critical hours	2183.0	2112.2	2209.0	2160.0	2183.0	1840.4	2024.2	2159.0
Indicator value	0.9	1.7	0.8	0.8	0.8	0	0.9	0.9

Licensee Comments: none

## Scrams with Loss of Normal Heat Removal




Thresholds: White > 2.0 Yellow > 10.0 Red > 20.0

### Notes

Scrams with Loss of Normal Heat Removal	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07
Scrams	0	0	0	0	0	0	0	0
Indicator value	3.0	3.0	2.0	2.0	2.0	1.0	1.0	1.0

Licensee Comments: none

## Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

### Notes

Unplanned Power Changes per 7000 Critical Hrs	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07
Unplanned power changes	0	0	0	0	0	0	1.0	1.0
Critical hours	2183.0	2112.2	2209.0	2160.0	2183.0	1840.4	2024.2	2159.0
Indicator value	3.4	2.5	0.8	0	0	0	0.9	1.7

Licensee Comments: none

# Safety System Functional Failures (BWR)




Thresholds: White > 6.0

## Notes

Safety System Functional Failures (BWR)	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07
Safety System Functional Failures	0	0	0	0	0	0	2	0
Indicator value	0	0	0	0	0	0	2	2

Licensee Comments: none

# Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White >  $1.00E-6$  Yellow >  $1.00E-5$  Red >  $1.00E-4$

## Notes

Mitigating Systems Performance Index, Emergency AC Power System	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07
UAI (ΔCDF)					$8.70E-08$	$7.90E-08$	$9.40E-08$	$2.10E-07$
URI (ΔCDF)					$6.20E-07$	$-7.80E-08$	$-1.80E-07$	$-1.70E-07$
PLE					NO	NO	NO	NO
Indicator value					$7.07E-07$	$1.00E-09$	$-8.60E-08$	$4.00E-08$

Licensee Comments: none

# Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, High Pressure Injection System	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07
UAI ( $\Delta$ CDF)					5.80E-08	5.80E-08	5.90E-08	3.90E-08
URI ( $\Delta$ CDF)					3.60E-08	5.70E-08	5.40E-08	5.40E-08
PLE					NO	NO	NO	NO
Indicator value					9.40E-08	1.15E-07	1.13E-07	9.30E-08

Licensee Comments: none

# Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Heat Removal System	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07
UAI ( $\Delta$ CDF)					-6.00E-08	-6.00E-08	-6.00E-08	-6.00E-08
URI ( $\Delta$ CDF)					-1.80E-07	-1.50E-07	-1.50E-07	-1.50E-07
PLE					NO	NO	NO	NO
Indicator value					-2.40E-07	-2.10E-07	-2.10E-07	-2.10E-07

Licensee Comments: none

# Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


## Notes

Mitigating Systems Performance Index, Residual Heat Removal System	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07
UAI ( $\Delta$ CDF)					-8.10E-10	-8.10E-10	-8.10E-10	-8.10E-10
URI ( $\Delta$ CDF)					-2.20E-09	-2.20E-09	-2.20E-09	-2.20E-09
PLE					NO	NO	NO	NO
Indicator value					-3.01E-09	-3.01E-09	-3.01E-09	-3.01E-09

Licensee Comments: none



# Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Cooling Water Systems	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07
UAI ( $\Delta$ CDF)					5.80E-10	-3.00E-10	-9.30E-11	8.10E-10
URI ( $\Delta$ CDF)					-5.30E-09	-3.50E-09	-3.60E-09	-3.60E-09
PLE					NO	NO	NO	NO
Indicator value					-4.72E-09	-3.80E-09	-3.69E-09	-2.79E-09

Licensee Comments: none

# Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0

## Notes


Reactor Coolant System Activity	4/05	5/05	6/05	7/05	8/05	9/05	10/05	11/05	12/05	1/06	2/06	3/06
Maximum activity	0.000018	0.000018	0.000031	0.000059	0.000071	0.000076	0.000046	0.000031	0.000025	0.000073	0.000044	0.000041
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Reactor Coolant System Activity	4/06	5/06	6/06	7/06	8/06	9/06	10/06	11/06	12/06	1/07	2/07	3/07
Maximum activity	0.000088	0.000060	0.000061	0.000049	0.000038	0.000051	0.000192	0.000204	0.000198	0.000143	0.000122	0.000125
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0.1	0.1	0.1	0.1	0.1	0.1

Licensee Comments: none

# Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0

## Notes


Reactor Coolant System Leakage	4/05	5/05	6/05	7/05	8/05	9/05	10/05	11/05	12/05	1/06	2/06	3/06
Maximum leakage	1.670	1.640	1.680	1.730	1.790	1.750	1.740	1.750	1.670	1.620	1.650	1.620
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	6.7	6.6	6.7	6.9	7.2	7.0	7.0	7.0	6.7	6.5	6.6	6.5

Reactor Coolant System Leakage	4/06	5/06	6/06	7/06	8/06	9/06	10/06	11/06	12/06	1/07	2/07	3/07
Maximum leakage	1.620	1.600	1.620	1.730	1.740	1.590	1.810	1.790	1.790	1.780	1.840	1.750
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	6.5	6.4	6.5	6.9	7.0	6.4	7.2	7.2	7.2	7.1	7.4	7.0

Licensee Comments: none

## Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

### Notes

Drill/Exercise Performance	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07
Successful opportunities	34.0	20.0	20.0	109.0	58.0	27.0	24.0	146.0
Total opportunities	39.0	20.0	21.0	111.0	58.0	28.0	24.0	150.0
<b>Indicator value</b>	<b>95.0%</b>	<b>95.0%</b>	<b>95.0%</b>	<b>95.6%</b>	<b>97.1%</b>	<b>96.7%</b>	<b>96.7%</b>	<b>97.1%</b>

Licensee Comments: none

# ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

## Notes

ERO Drill Participation	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07
Participating Key personnel	75.0	75.0	76.0	76.0	75.0	81.0	82.0	84.0
Total Key personnel	75.0	75.0	76.0	76.0	75.0	81.0	82.0	84.0
<b>Indicator value</b>	<b>100.0%</b>	<b>100.0%</b>	<b>100.0%</b>	<b>100.0%</b>	<b>100.0%</b>	<b>100.0%</b>	<b>100.0%</b>	<b>100.0%</b>

Licensee Comments: none

# Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

## Notes

Alert & Notification System	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07
Successful siren-tests	1259	1258	1261	1258	1247	1249	1257	1256
Total sirens-tests	1261	1261	1261	1261	1261	1261	1261	1261
<b>Indicator value</b>	<b>99.3%</b>	<b>99.4%</b>	<b>99.9%</b>	<b>99.8%</b>	<b>99.6%</b>	<b>99.4%</b>	<b>99.3%</b>	<b>99.3%</b>

Licensee Comments: none

# Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

## Notes

Occupational Exposure Control Effectiveness	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07
High radiation area occurrences	0	0	0	0	0	0	0	1
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>

Licensee Comments: none

# RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

## Notes

RETS/ODCM Radiological Effluent	2Q/05	3Q/05	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Physical Protection](#) information not publicly available.

▲ [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: June 1, 2007