


# Vogle 1

## 3Q/2007 Performance Indicators

Licensee's General Comments: 4Q06 - 2Q07 revision to reflect the new Unplanned Scrams with Complications PI.

### Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

### Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07
Unplanned scrams	1.0	0	1.0	0	0	0	0	0
Critical hours	2175.3	2160.0	2015.4	1875.9	1511.4	2159.0	2184.0	2208.0
Indicator value	2.6	1.6	1.6	1.7	0.9	0.9	0	0

Licensee Comments: none

## Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

### Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07
Unplanned power changes	0	0	0	0	0	0	0	0
Critical hours	2175.3	2160.0	2015.4	1875.9	1511.4	2159.0	2184.0	2208.0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

# Unplanned Scrams with Complications




Thresholds: White > 1.0

## Notes

Unplanned Scrams with Complications	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07
Scrams with complications					0	0	0	0
Indicator value								0.0

Licensee Comments: none

## Safety System Functional Failures (PWR)




Thresholds: White > 5.0

### Notes

Safety System Functional Failures (PWR)	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07
Safety System Functional Failures	0	0	0	0	1	0	0	0
Indicator value	0	0	0	0	1	1	1	1

Licensee Comments: none

# Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White >  $1.00E-6$  Yellow >  $1.00E-5$  Red >  $1.00E-4$

## Notes

Mitigating Systems Performance Index, Emergency AC Power System	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07
UAI ( $\Delta$ CDF)			$-1.80E-07$	$-1.80E-07$	$-1.40E-07$	$-5.80E-08$	$-5.80E-08$	$-5.90E-08$
URI ( $\Delta$ CDF)			$-7.80E-07$	$-7.80E-07$	$-7.70E-07$	$1.60E-07$	$1.30E-07$	$1.30E-07$
PLE			NO	NO	NO	NO	NO	NO
Indicator value			$-9.60E-07$	$-9.60E-07$	$-9.10E-07$	$1.02E-07$	$7.20E-08$	$7.10E-08$

Licensee Comments: none

# Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, High Pressure Injection System	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07
UAI ( $\Delta$ CDF)			6.80E-09	6.00E-09	6.60E-09	3.70E-09	3.20E-09	-2.20E-09
URI ( $\Delta$ CDF)			-1.00E-08	-1.00E-08	-1.00E-08	-1.00E-08	-1.00E-08	-9.70E-09
PLE			NO	NO	NO	NO	NO	NO
Indicator value			-3.20E-09	-4.00E-09	-3.40E-09	-6.30E-09	-6.80E-09	-1.19E-08

Licensee Comments: none

# Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Heat Removal System	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07
UAI ( $\Delta$ CDF)			$2.50E-07$	$2.80E-07$	$1.30E-07$	$6.80E-08$	$9.20E-08$	$9.20E-08$
URI ( $\Delta$ CDF)			$3.40E-07$	$3.30E-07$	$-2.10E-09$	$2.30E-08$	$2.30E-08$	$3.50E-08$
PLE			NO	NO	NO	NO	NO	NO
Indicator value			$5.90E-07$	$6.10E-07$	$1.28E-07$	$9.10E-08$	$1.15E-07$	$1.27E-07$

Licensee Comments: none

# Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


## Notes

Mitigating Systems Performance Index, Residual Heat Removal System	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07
UAI ( $\Delta$ CDF)			-1.50E-09	1.60E-09	1.60E-09	-3.90E-09	-3.70E-09	-7.00E-09
URI ( $\Delta$ CDF)			-3.20E-08	-3.30E-08	-3.40E-08	-3.40E-08	-3.40E-08	-3.40E-08
PLE			NO	NO	NO	NO	NO	NO
Indicator value			-3.35E-08	-3.14E-08	-3.24E-08	-3.79E-08	-3.77E-08	-4.10E-08

Licensee Comments: none



# Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White >  $1.00E-6$  Yellow >  $1.00E-5$  Red >  $1.00E-4$

## Notes

Mitigating Systems Performance Index, Cooling Water Systems	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07
UAI ( $\Delta$ CDF)			$1.10E-07$	$1.10E-07$	$1.10E-07$	$1.20E-07$	$1.20E-07$	$1.20E-07$
URI ( $\Delta$ CDF)			$-1.90E-08$	$-1.70E-08$	$-3.00E-08$	$5.70E-07$	$5.70E-07$	$5.70E-07$
PLE			NO	NO	NO	NO	NO	NO
Indicator value			$9.10E-08$	$9.30E-08$	$8.00E-08$	$6.90E-07$	$6.90E-07$	$6.90E-07$

Licensee Comments: none

# Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

## Notes

Reactor Coolant System Activity	10/05	11/05	12/05	1/06	2/06	3/06	4/06	5/06	6/06	7/06	8/06	9/06
Maximum activity	0.000380	0.000325	0.000376	0.000285	0.000388	0.000310	0.000221	0.000240	0.000356	0.000346	0.000360	0.000363
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0
Reactor Coolant System Activity	10/06	11/06	12/06	1/07	2/07	3/07	4/07	5/07	6/07	7/07	8/07	9/07
Maximum activity	N/A	0.000120	0.000127	0.000135	0.000137	0.000142	0.000178	0.000220	0.000265	0.000227	0.000240	0.000253
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	N/A	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

# Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0

## Notes


Reactor Coolant System Leakage	10/05	11/05	12/05	1/06	2/06	3/06	4/06	5/06	6/06	7/06	8/06	9/06
Maximum leakage	0.060	0.070	0.073	0.074	0.093	0.085	0.063	0.117	0.064	0.067	0.088	0.057
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.6	0.7	0.7	0.7	0.9	0.9	0.6	1.2	0.6	0.7	0.9	0.6

Reactor Coolant System Leakage	10/06	11/06	12/06	1/07	2/07	3/07	4/07	5/07	6/07	7/07	8/07	9/07
Maximum leakage	0.028	0.086	0.071	0.116	0.079	0.101	0.093	0.105	0.095	0.092	0.089	0.081
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.3	0.9	0.7	1.2	0.8	1.0	0.9	1.1	1.0	0.9	0.9	0.8

Licensee Comments: none

## Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

### Notes

Drill/Exercise Performance	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07
Successful opportunities	37.0	85.0	100.0	104.0	27.0	31.0	49.0	83.0
Total opportunities	39.0	98.0	100.0	112.0	28.0	38.0	50.0	87.0
Indicator value	96.5%	93.3%	94.8%	94.0%	94.3%	93.6%	93.8%	93.5%

Licensee Comments: none

# ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

## Notes

ERO Drill Participation	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07
Participating Key personnel	111.0	110.0	108.0	111.0	108.0	104.0	107.0	113.0
Total Key personnel	113.0	110.0	112.0	113.0	111.0	113.0	111.0	116.0
Indicator value	98.2%	100.0%	96.4%	98.2%	97.3%	92.0%	96.4%	97.4%

Licensee Comments: none

# Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

## Notes

Alert & Notification System	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07
Successful siren-tests	610	610	611	611	611	610	610	609
Total sirens-tests	611	611	611	611	611	611	611	611
Indicator value	99.2%	99.1%	99.3%	99.9%	100.0%	100.0%	99.9%	99.8%

Licensee Comments: none

# Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

## Notes

Occupational Exposure Control Effectiveness	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

# RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

## Notes

RETS/ODCM Radiological Effluent	4Q/05	1Q/06	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Physical Protection](#) information not publicly available.