


River Bend 1

2Q/2008 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
Unplanned scrams	0	1.0	0	1.0	1.0	1.0	1.0	0
Critical hours	2208.0	2153.6	2159.0	1731.7	2110.7	2058.0	789.6	2184.0
Indicator value	0.9	1.7	1.7	1.7	2.6	2.6	4.2	2.9

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
Unplanned power changes	0	1.0	0	2.0	0	1.0	1.0	1.0
Critical hours	2208.0	2153.6	2159.0	1731.7	2110.7	2058.0	789.6	2184.0
Indicator value	1.7	2.6	2.6	2.5	2.6	2.6	4.2	2.9

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
Scrams with complications		1.0	0	0	0	1.0	0	0
Indicator value					1.0	1.0	1.0	1.0

Licensee Comments: none

Safety System Functional Failures (BWR)




Thresholds: White > 6.0

Notes

Safety System Functional Failures (BWR)	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
Safety System Functional Failures	0	0	0	0	0	0	0	0
Indicator value	2	1	0	0	0	0	0	0

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
UAI (Δ CDF)	-4.80E-09	-4.80E-09	3.60E-09	3.70E-09	4.80E-09	1.40E-08	1.70E-08	2.70E-08
URI (Δ CDF)	3.30E-08	3.30E-08	-1.60E-09	-1.70E-09	3.00E-08	1.40E-07	1.30E-07	1.40E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.82E-08	2.82E-08	2.00E-09	2.00E-09	3.48E-08	1.54E-07	1.47E-07	1.67E-07

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
UAI (ΔCDF)	5.30E-09	4.40E-09	2.40E-09	-1.80E-09	-1.80E-09	-1.80E-09	-1.70E-09	-1.70E-09
URI (ΔCDF)	-3.70E-08	-3.70E-08	-3.60E-08	-3.50E-08	-3.40E-08	-3.30E-08	-3.20E-08	-3.30E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.17E-08	-3.26E-08	-3.36E-08	-3.68E-08	-3.58E-08	-3.48E-08	-3.37E-08	-3.47E-08

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > $1.00E-6$ Yellow > $1.00E-5$ Red > $1.00E-4$

Notes

Mitigating Systems Performance Index, Heat Removal System	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
UAI (Δ CDF)	$-2.20E-08$	$-1.70E-08$	$-4.60E-09$	$-5.00E-09$	$-1.20E-08$	$-1.60E-08$	$-1.40E-08$	$-1.60E-08$
URI (Δ CDF)	$-4.80E-08$	$5.60E-08$	$2.00E-08$	$2.70E-08$	$3.90E-08$	$6.10E-08$	$7.20E-08$	$8.10E-08$
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	$-7.00E-08$	$3.90E-08$	$1.54E-08$	$2.20E-08$	$2.70E-08$	$4.50E-08$	$5.80E-08$	$6.50E-08$

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
UAI (Δ CDF)	8.70E-08	7.30E-08	6.80E-08	1.70E-08	1.80E-08	3.00E-08	3.40E-08	3.40E-08
URI (Δ CDF)	3.50E-10	-2.80E-09	-1.80E-09	-1.80E-08	-1.80E-08	-2.30E-08	-2.70E-08	-2.80E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	8.74E-08	7.02E-08	6.62E-08	-1.00E-09	0.00E+00	7.00E-09	7.00E-09	6.00E-09

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
UAI (Δ CDF)	5.30E-08	4.00E-09	4.00E-09	4.10E-09	4.10E-09	3.90E-09	-2.60E-09	-2.60E-09
URI (Δ CDF)	-2.50E-08	-2.50E-08	-2.50E-08	-2.50E-08	-2.50E-08	-2.70E-08	-2.70E-08	-2.60E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.80E-08	-2.10E-08	-2.10E-08	-2.09E-08	-2.09E-08	-2.31E-08	-2.96E-08	-2.86E-08

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	7/06	8/06	9/06	10/06	11/06	12/06	1/07	2/07	3/07	4/07	5/07	6/07
Maximum activity	0.008390	0.007000	0.005690	0.005370	0.013500	0.015300	0.006150	0.005520	0.006730	0.008600	0.006970	0.011200
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	4.2	3.5	2.8	2.7	6.8	7.7	3.1	2.8	3.4	4.3	3.5	5.6

Reactor Coolant System Activity	7/07	8/07	9/07	10/07	11/07	12/07	1/08	2/08	3/08	4/08	5/08	6/08
Maximum activity	0.005340	0.006020	0.007080	0.009530	0.009650	0.005790	0.005800	N/A	0.004140	0.002949	0.004318	0.002413
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	2.7	3.0	3.5	4.8	4.8	2.9	2.9	N/A	2.1	1.5	2.2	1.2

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	7/06	8/06	9/06	10/06	11/06	12/06	1/07	2/07	3/07	4/07	5/07	6/07
Maximum leakage	2.160	2.180	2.180	2.630	2.200	2.240	2.300	2.210	2.180	2.460	2.990	2.220
Technical specification limit	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0
Indicator value	7.2	7.3	7.3	8.8	7.3	7.5	7.7	7.4	7.3	8.2	10.0	7.4

Reactor Coolant System Leakage	7/07	8/07	9/07	10/07	11/07	12/07	1/08	2/08	3/08	4/08	5/08	6/08
Maximum leakage	2.290	2.250	2.230	2.260	2.340	2.400	2.440	N/A	2.330	2.810	2.270	2.300
Technical specification limit	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0
Indicator value	7.6	7.5	7.4	7.5	7.8	8.0	8.1	N/A	7.8	9.4	7.6	7.7

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
Successful opportunities	40.0	3.0	15.0	47.0	21.0	0	18.0	32.0
Total opportunities	41.0	3.0	16.0	49.0	23.0	0	21.0	35.0
Indicator value	98.5%	98.4%	98.0%	97.2%	95.6%	95.1%	94.4%	93.6%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
Participating Key personnel	130.0	119.0	123.0	119.0	125.0	111.0	109.0	111.0
Total Key personnel	130.0	123.0	129.0	129.0	126.0	116.0	112.0	113.0
Indicator value	100.0%	96.7%	95.3%	92.2%	99.2%	95.7%	97.3%	98.2%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
Successful siren-tests	1203	1019	1202	1103	1201	1020	1199	1202
Total sirens-tests	1209	1023	1209	1116	1209	1023	1209	1209
Indicator value	99.4%	99.5%	99.4%	99.3%	99.3%	99.3%	99.3%	99.4%

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
High radiation area occurrences	0	0	0	0	0	0	1	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	1	1

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Physical Protection](#) information not publicly available.

▲ [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: August 4, 2008