


Waterford 3

2Q/2008 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
Unplanned scrams	0	0	0	0	0	0	0	0
Critical hours	2208.0	1464.3	2159.0	2184.0	2208.0	1878.8	2183.0	1349.8
Indicator value	0.8	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
Unplanned power changes	0	0	0	0	0	0	0	1.0
Critical hours	2208.0	1464.3	2159.0	2184.0	2208.0	1878.8	2183.0	1349.8
Indicator value	0	0	0	0	0	0	0	0.9

Licensee Comments:

2Q/08: During power ascension following Refuel Outage 15, the unit was shutdown to repair a steam leak from a test connection on the Main Turbine. The leak was repaired within five hours and the power ascension was resumed.

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
Scrams with complications		0	0	0	0	0	0	0
Indicator value					0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
Safety System Functional Failures	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
UAI (ΔCDF)	2.10E-07	2.10E-07	2.70E-07	2.70E-07	1.90E-07	1.60E-07	-1.40E-07	-1.50E-07
URI (ΔCDF)	-1.30E-06	-1.40E-06	-1.40E-06	-1.40E-06	-1.30E-06	-1.30E-06	-1.40E-06	-2.00E-06
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.09E-06	-1.19E-06	-1.13E-06	-1.13E-06	-1.11E-06	-1.14E-06	-1.54E-06	-2.15E-06

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
UAI (ΔCDF)	7.30E-08	7.30E-08	7.30E-08	5.80E-08	-4.40E-09	-1.40E-08	-6.30E-09	-8.00E-09
URI (ΔCDF)	8.80E-08	8.70E-08	8.70E-08	8.80E-08	-1.50E-07	-1.40E-07	-1.40E-07	-1.50E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.61E-07	1.60E-07	1.60E-07	1.46E-07	-1.54E-07	-1.54E-07	-1.46E-07	-1.58E-07

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
UAI (Δ CDF)	-6.10E-08	-6.10E-08	-3.70E-08	-6.30E-08	-6.30E-08	-4.40E-08	-2.20E-08	-2.40E-08
URI (Δ CDF)	-2.80E-07	-2.80E-07	-2.80E-07	-2.80E-07	-2.80E-07	-2.80E-07	-2.80E-07	-2.80E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.41E-07	-3.41E-07	-3.17E-07	-3.43E-07	-3.43E-07	-3.24E-07	-3.02E-07	-3.04E-07

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
UAI (Δ CDF)	6.10E-12	5.70E-12	4.20E-12	2.80E-12	-2.80E-12	-2.80E-12	-2.80E-12	-2.80E-12
URI (Δ CDF)	2.00E-11	2.00E-11	2.00E-11	2.00E-11	-5.10E-12	-5.20E-12	-5.10E-12	-5.20E-12
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.61E-11	2.57E-11	2.42E-11	2.28E-11	-7.90E-12	-8.00E-12	-7.90E-12	-8.00E-12

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
UAI (Δ CDF)	6.40E-08	6.40E-08	6.40E-08	6.40E-08	6.30E-08	6.40E-08	6.50E-08	6.40E-08
URI (Δ CDF)	6.30E-09	-2.30E-08	-2.40E-08	-3.60E-08	-4.60E-08	-4.50E-08	-2.00E-08	-2.10E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	7.03E-08	4.10E-08	4.00E-08	2.80E-08	1.70E-08	1.90E-08	4.50E-08	4.30E-08

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0

Notes


Reactor Coolant System Activity	7/06	8/06	9/06	10/06	11/06	12/06	1/07	2/07	3/07	4/07	5/07	6/07
Maximum activity	0.002050	0.002010	0.002190	0.002090	0.002150	N/A	0.001700	0.001210	0.001060	0.001230	0.001180	0.001870
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.2	0.2	0.2	0.2	0.2	N/A	0.2	0.1	0.1	0.1	0.1	0.2

Reactor Coolant System Activity	7/07	8/07	9/07	10/07	11/07	12/07	1/08	2/08	3/08	4/08	5/08	6/08
Maximum activity	0.001900	0.001990	0.002500	0.006940	0.001690	0.002050	0.002460	0.002220	0.001910	0.004460	N/A	0.000925
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.2	0.2	0.3	0.7	0.2	0.2	0.2	0.2	0.2	0.4	N/A	0.1

Licensee Comments:

6/08: The Reactor was shutdown for the entire month of May 2008 to conduct planned Refueling Outage 15.

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	7/06	8/06	9/06	10/06	11/06	12/06	1/07	2/07	3/07	4/07	5/07	6/07
Maximum leakage	0.136	0.150	0.140	0.130	0.130	0.396	0.030	0.020	0.020	0.030	0.040	0.040
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.4	1.5	1.4	1.3	1.3	4.0	0.3	0.2	0.2	0.3	0.4	0.4
Reactor Coolant System Leakage	7/07	8/07	9/07	10/07	11/07	12/07	1/08	2/08	3/08	4/08	5/08	6/08
Maximum leakage	0.038	0.040	0.030	0.040	0.030	0.030	0.030	0.030	0.030	0.030	N/A	0.060
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.4	0.4	0.3	0.4	0.3	0.3	0.3	0.3	0.3	0.3	N/A	0.6

Licensee Comments:

6/08: The Reactor was shutdown for the entire month of May 2008 to conduct planned Refueling Outage 15.

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
Successful opportunities	67.0	12.0	25.0	28.0	26.0	20.0	37.0	8.0
Total opportunities	68.0	12.0	26.0	28.0	28.0	20.0	38.0	8.0
Indicator value	96.5%	96.5%	96.1%	96.5%	96.2%	96.6%	96.6%	97.8%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
Participating Key personnel	125.0	125.0	123.0	122.0	123.0	120.0	126.0	112.0
Total Key personnel	126.0	129.0	136.0	132.0	131.0	123.0	133.0	121.0
Indicator value	99.2%	96.9%	90.4%	92.4%	93.9%	97.6%	94.7%	92.6%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
Successful siren-tests	431	431	432	431	432	432	432	431
Total sirens-tests	432	432	432	432	432	432	432	432
Indicator value	99.9%	99.9%	99.9%	99.8%	99.9%	99.9%	99.9%	99.9%

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Physical Protection](#) information not publicly available.

▲ [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: August 4, 2008