


Browns Ferry 3

4Q/2008 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Unplanned scrams	1.0	0	0	1.0	0	0	0	0
Critical hours	2076.5	2184.0	2089.3	2062.5	1458.9	1124.9	2172.2	2209.0
Indicator value	2.4	2.4	0.8	1.7	0.9	1.0	1.0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Unplanned power changes	0	0	0	0	0	0	2.0	0
Critical hours	2076.5	2184.0	2089.3	2062.5	1458.9	1124.9	2172.2	2209.0
Indicator value	0.8	0.8	0.8	0	0	0	2.1	2.0

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value			0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (BWR)




Thresholds: White > 6.0

Notes

Safety System Functional Failures (BWR)	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Safety System Functional Failures	0	0	1	0	1	0	0	0
Indicator value	0	0	1	1	2	2	1	1

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > $1.00E-6$ Yellow > $1.00E-5$ Red > $1.00E-4$

Notes


Mitigating Systems Performance Index, Emergency AC Power System	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
UAI (Δ CDF)	$-5.70E-08$	$5.40E-08$	$5.50E-08$	$5.50E-08$	$9.90E-08$	$1.60E-07$	$2.40E-07$	$2.60E-07$
URI (Δ CDF)	$-8.40E-07$	$-6.50E-08$	$-6.50E-08$	$-6.50E-08$	$4.20E-07$	$4.20E-07$	$4.20E-07$	$4.20E-07$
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	$-8.97E-07$	$-1.10E-08$	$-1.00E-08$	$-1.00E-08$	$5.19E-07$	$5.80E-07$	$6.60E-07$	$6.80E-07$

Licensee Comments:

4Q/08: Risk Cap Invoked.

2Q/06: A review of U2 and U3 MSPI baseline data entered in the CDE database identified several discrepancies with U2 and U3 MSPI Basis Documents. Unlocked to correct. Reference BFN PER 127680

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
UAI (Δ CDF)	-1.70E-08	-2.20E-08	-2.20E-08	-2.20E-08	-2.10E-08	-2.20E-08	-2.20E-08	-2.20E-08
URI (Δ CDF)	-4.70E-08	-4.70E-08	-4.70E-08	-4.70E-08	-4.70E-08	-4.70E-08	-4.70E-08	-4.70E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-6.40E-08	-6.90E-08	-6.90E-08	-6.90E-08	-6.80E-08	-6.90E-08	-6.90E-08	-6.90E-08

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
UAI (ΔCDF)	1.60E-08	4.00E-08	3.80E-08	6.20E-08	6.50E-08	5.80E-08	6.30E-08	3.40E-08
URI (ΔCDF)	-5.90E-08	-5.90E-08	-5.90E-08	-5.90E-08	-5.90E-08	1.20E-07	1.20E-07	1.30E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-4.30E-08	-1.90E-08	-2.10E-08	3.00E-09	6.00E-09	1.78E-07	1.83E-07	1.64E-07

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
UAI (Δ CDF)	1.80E-07	1.80E-07	1.50E-07	1.30E-07	2.00E-07	1.90E-07	1.90E-07	1.10E-07
URI (Δ CDF)	5.50E-08	5.60E-08	5.50E-08	5.30E-08	5.40E-08	2.90E-08	4.20E-08	5.60E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.35E-07	2.36E-07	2.05E-07	1.83E-07	2.54E-07	2.19E-07	2.32E-07	1.66E-07

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
UAI (Δ CDF)	1.20E-07	1.20E-07	2.30E-07	2.30E-07	2.40E-07	3.00E-07	1.20E-07	1.20E-07
URI (Δ CDF)	1.90E-07	2.00E-07	2.00E-07	2.00E-07	2.00E-07	2.00E-07	1.50E-07	8.70E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	3.10E-07	3.20E-07	4.30E-07	4.30E-07	4.40E-07	5.00E-07	2.70E-07	2.07E-07

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	1/07	2/07	3/07	4/07	5/07	6/07	7/07	8/07	9/07	10/07	11/07	12/07
Maximum activity	0.000029	0.000037	0.000040	0.000035	0.000042	0.000040	0.000037	0.000034	0.000041	0.000041	0.000044	0.000043
Technical specification limit	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Reactor Coolant System Activity	1/08	2/08	3/08	4/08	5/08	6/08	7/08	8/08	9/08	10/08	11/08	12/08
Maximum activity	0.000038	0.000041	0.000031	N/A	0.000031	0.000041	0.000041	0.000036	0.000043	0.000052	0.000047	0.000062
Technical specification limit	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
Indicator value	0	0	0	N/A	0	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	1/07	2/07	3/07	4/07	5/07	6/07	7/07	8/07	9/07	10/07	11/07	12/07
Maximum leakage	2.220	2.410	2.590	2.750	2.920	3.160	3.340	4.050	3.990	3.850	4.130	4.050
Technical specification limit	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0
Indicator value	7.4	8.0	8.6	9.2	9.7	10.5	11.1	13.5	13.3	12.8	13.8	13.5
Reactor Coolant System Leakage	1/08	2/08	3/08	4/08	5/08	6/08	7/08	8/08	9/08	10/08	11/08	12/08
Maximum leakage	4.120	4.220	4.360	0	1.860	1.870	1.680	1.690	1.620	1.580	1.640	1.760
Technical specification limit	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0
Indicator value	13.7	14.1	14.5	0	6.2	6.2	5.6	5.6	5.4	5.3	5.5	5.9

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Successful opportunities	0	7.0	8.0	55.0	6.0	3.0	4.0	48.0
Total opportunities	0	8.0	8.0	56.0	6.0	3.0	4.0	48.0
Indicator value	98.9%	98.3%	98.3%	98.1%	98.1%	98.7%	98.2%	98.5%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Participating Key personnel	63.0	66.0	66.0	68.0	62.0	56.0	63.0	67.0
Total Key personnel	65.0	67.0	67.0	68.0	64.0	61.0	64.0	67.0
Indicator value	96.9%	98.5%	98.5%	100.0%	96.9%	91.8%	98.4%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Successful siren-tests	797	795	798	698	999	596	994	597
Total sirens-tests	800	800	800	700	1000	600	1000	600
Indicator value	99.5%	99.5%	99.6%	99.6%	99.7%	99.7%	99.6%	99.6%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.