


Fort Calhoun

4Q/2008 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Unplanned scrams	0	0	0	0	1.0	0	0	0
Critical hours	2159.0	2184.0	2208.0	2209.0	2008.1	798.6	2208.0	2209.0
Indicator value	0	0	0	0	0.8	1.0	1.0	1.0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Unplanned power changes	0	0	0	0	1.0	1.0	1.0	0
Critical hours	2159.0	2184.0	2208.0	2209.0	2008.1	798.6	2208.0	2209.0
Indicator value	0	0	0	0	0.8	1.9	2.9	2.9

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Scrams with complications	0	0	0	0	1.0	0	0	0
Indicator value			0.0	0.0	1.0	1.0	1.0	1.0

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Safety System Functional Failures	1	2	0	0	0	0	0	0
Indicator value	4	6	5	3	2	0	0	0

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
UAI (ΔCDF)	1.60E-07	1.00E-07	4.40E-07	4.90E-07	9.60E-07	7.20E-07	7.40E-07	4.40E-07
URI (ΔCDF)	6.80E-07	7.20E-07	2.30E-07	2.10E-07	-8.70E-10	-6.50E-08	-8.00E-08	-5.10E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	8.40E-07	8.20E-07	6.70E-07	7.00E-07	9.59E-07	6.55E-07	6.60E-07	3.89E-07

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
UAI (Δ CDF)	1.30E-07	1.70E-07	9.90E-09	-4.30E-09	2.30E-08	2.60E-08	8.00E-08	1.70E-08
URI (Δ CDF)	-4.40E-08	-4.20E-08	-3.90E-08	-3.50E-08	-3.10E-08	-6.60E-08	-7.10E-08	-5.10E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	8.60E-08	1.28E-07	-2.91E-08	-3.93E-08	-8.00E-09	-4.00E-08	9.00E-09	-3.40E-08

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
UAI (Δ CDF)	5.50E-08	2.60E-08	1.50E-08	8.90E-09	2.50E-09	-1.20E-08	-3.10E-08	-4.20E-08
URI (Δ CDF)	-2.70E-07	-2.80E-07	-2.80E-07	-2.80E-07	-2.80E-07	-3.30E-07	-3.30E-07	-2.40E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.15E-07	-2.54E-07	-2.65E-07	-2.71E-07	-2.78E-07	-3.42E-07	-3.61E-07	-2.82E-07

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Residual Heat Removal System	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
UAI (Δ CDF)	-1.10E-07	-1.10E-07	-1.10E-07	-1.10E-07	-1.10E-07	-1.50E-07	-1.60E-08	-6.40E-08
URI (Δ CDF)	2.90E-07	2.90E-07	3.00E-07	3.00E-07	3.10E-07	4.10E-07	4.20E-07	4.80E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.80E-07	1.80E-07	1.90E-07	1.90E-07	2.00E-07	2.60E-07	4.04E-07	4.16E-07

Licensee Comments:

4Q/08: Changed PRA Parameter(s). The override function was used to update the MSPI model due to problems experienced in updating the MSPI model from the PRA model update.

Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Cooling Water Systems	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
UAI (Δ CDF)	-1.00E-07	-9.40E-08	-9.00E-08	-4.60E-08	8.90E-08	8.80E-08	5.60E-08	-2.40E-07
URI (Δ CDF)	7.70E-08	7.60E-08	7.50E-08	9.80E-08	1.20E-07	1.60E-07	1.20E-07	8.70E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.30E-08	-1.80E-08	-1.50E-08	5.20E-08	2.09E-07	2.48E-07	1.76E-07	-1.53E-07

Licensee Comments:

4Q/08: Changed PRA Parameter(s). The override function was used to update the MSPI model due to problems experienced in updating the MSPI model from the PRA model update.

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	1/07	2/07	3/07	4/07	5/07	6/07	7/07	8/07	9/07	10/07	11/07	12/07
Maximum activity	0.005150	0.005110	0.005290	0.005320	0.005560	0.005730	0.005480	0.006190	0.005910	0.005710	0.005660	0.005690
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.5	0.5	0.5	0.5	0.6	0.6	0.5	0.6	0.6	0.6	0.6	0.6

Reactor Coolant System Activity	1/08	2/08	3/08	4/08	5/08	6/08	7/08	8/08	9/08	10/08	11/08	12/08
Maximum activity	0.005870	0.006160	0.006180	0.006300	N/A	0.003210	0.003640	0.003600	0.003600	0.003820	0.004060	0.004260
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.6	0.6	0.6	0.6	N/A	0.3	0.4	0.4	0.4	0.4	0.4	0.4

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	1/07	2/07	3/07	4/07	5/07	6/07	7/07	8/07	9/07	10/07	11/07	12/07
Maximum leakage	0.155	0.128	0.169	0.127	0.277	0.205	0.082	0.113	0.205	0.128	0.206	0.172
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.6	1.3	1.7	1.3	2.8	2.1	0.8	1.1	2.1	1.3	2.1	1.7
Reactor Coolant System Leakage	1/08	2/08	3/08	4/08	5/08	6/08	7/08	8/08	9/08	10/08	11/08	12/08
Maximum leakage	0.151	0.197	0.260	0.290	N/A	0.331	1.040	0.169	0.122	0.105	0.092	0.183
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.5	2.0	2.6	2.9	N/A	3.3	10.4	1.7	1.2	1.1	0.9	1.8

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Successful opportunities	31.0	20.0	11.0	12.0	89.0	24.0	68.0	56.0
Total opportunities	32.0	23.0	12.0	13.0	90.0	24.0	70.0	56.0
Indicator value	94.5%	93.5%	92.6%	92.0%	94.8%	96.8%	96.6%	97.2%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Participating Key personnel	99.0	106.0	102.0	91.0	96.0	102.0	104.0	108.0
Total Key personnel	107.0	109.0	104.0	98.0	103.0	103.0	106.0	108.0
Indicator value	92.5%	97.2%	98.1%	92.9%	93.2%	99.0%	98.1%	100.0%

Licensee Comments: none

Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Successful siren-tests	807	706	906	806	704	805	804	804
Total sirens-tests	808	707	909	808	707	808	808	808
Indicator value	99.7%	99.7%	99.8%	99.8%	99.7%	99.7%	99.6%	99.6%

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.