


Vermont Yankee

4Q/2008 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Unplanned scrams	0	0	1.0	0	0	0	0	0
Critical hours	2159.0	1621.0	2172.2	2209.0	2183.0	2184.0	2208.0	1694.6
Indicator value	0	0	0.9	0.9	0.9	0.8	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Unplanned power changes	1.0	0	2.0	1.0	0	0	2.0	0
Critical hours	2159.0	1621.0	2172.2	2209.0	2183.0	2184.0	2208.0	1694.6
Indicator value	1.6	0.9	2.6	3.4	2.6	2.4	2.4	1.7

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value			0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (BWR)




Thresholds: White > 6.0

Notes

Safety System Functional Failures (BWR)	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Safety System Functional Failures	0	0	1	0	0	0	0	0
Indicator value	0	0	1	1	1	1	0	0

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
UAI (Δ CDF)	2.20E-08	1.40E-08	-3.30E-08	-2.90E-08	1.20E-08	1.40E-08	1.40E-08	-1.30E-08
URI (Δ CDF)	9.90E-07	1.00E-06	1.00E-06	1.00E-06	9.60E-07	9.40E-07	9.10E-07	7.30E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.01E-06	1.01E-06	9.67E-07	9.71E-07	9.72E-07	9.54E-07	9.24E-07	7.17E-07

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
UAI (Δ CDF)	-5.30E-08	7.00E-08	6.90E-08	6.90E-08	9.00E-08	8.90E-08	8.80E-08	8.90E-08
URI (Δ CDF)	-1.10E-07	-3.20E-08	-3.20E-08	-3.20E-08	-7.40E-08	-7.80E-08	-7.00E-08	-6.60E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.63E-07	3.80E-08	3.70E-08	3.70E-08	1.60E-08	1.10E-08	1.80E-08	2.30E-08

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
UAI (Δ CDF)	-6.20E-09	2.10E-09	-5.00E-08	-1.30E-08	-1.40E-09	-1.90E-09	-1.90E-09	3.50E-09
URI (Δ CDF)	-7.40E-08	-8.10E-08	-8.10E-08	-8.30E-08	-1.30E-08	-1.30E-08	-1.30E-08	-1.30E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-8.02E-08	-7.89E-08	-1.31E-07	-9.60E-08	-1.44E-08	-1.49E-08	-1.49E-08	-9.50E-09

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
UAI (Δ CDF)	-2.30E-08	-2.30E-08	-2.30E-08	-2.30E-08	-4.00E-08	-4.00E-08	-4.00E-08	-4.00E-08
URI (Δ CDF)	-1.00E-07	-1.00E-07	-1.00E-07	-1.00E-07	-2.10E-07	-2.10E-07	-2.00E-07	-2.00E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.23E-07	-1.23E-07	-1.23E-07	-1.23E-07	-2.50E-07	-2.50E-07	-2.40E-07	-2.40E-07

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
UAI (ΔCDF)	3.00E-07	3.20E-07	3.30E-07	3.30E-07	1.80E-07	8.40E-08	1.90E-07	1.90E-07
URI (ΔCDF)	-1.50E-07	-9.40E-08	-9.20E-08	-9.10E-08	-3.00E-07	-2.80E-07	5.80E-08	7.00E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.50E-07	2.26E-07	2.38E-07	2.39E-07	-1.20E-07	-1.96E-07	2.48E-07	2.60E-07

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	1/07	2/07	3/07	4/07	5/07	6/07	7/07	8/07	9/07	10/07	11/07	12/07
Maximum activity	0.000024	0.000025	0.000024	0.000023	0.000038	0.000022	0.000023	0.000034	0.000046	0.000046	0.000032	0.000037
Technical specification limit	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Reactor Coolant System Activity	1/08	2/08	3/08	4/08	5/08	6/08	7/08	8/08	9/08	10/08	11/08	12/08
Maximum activity	0.000034	0.000023	0.000027	0.000031	0.000037	0.000030	0.000054	0.000047	0.000030	0.000037	0.000011	0.000007
Technical specification limit	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	1/07	2/07	3/07	4/07	5/07	6/07	7/07	8/07	9/07	10/07	11/07	12/07
Maximum leakage	1.800	1.800	1.900	1.900	1.900	2.200	1.700	1.600	1.600	1.600	1.600	1.700
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	7.2	7.2	7.6	7.6	7.6	8.8	6.8	6.4	6.4	6.4	6.4	6.8

Reactor Coolant System Leakage	1/08	2/08	3/08	4/08	5/08	6/08	7/08	8/08	9/08	10/08	11/08	12/08
Maximum leakage	1.700	1.700	1.700	1.700	1.600	1.600	1.600	1.600	1.630	1.620	1.600	1.700
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	6.8	6.8	6.8	6.8	6.4	6.4	6.4	6.4	6.5	6.5	6.4	6.8

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Successful opportunities	13.0	23.0	58.0	27.0	40.0	36.0	75.0	17.0
Total opportunities	14.0	23.0	58.0	28.0	42.0	36.0	78.0	18.0
Indicator value	97.9%	98.3%	98.5%	98.3%	97.7%	97.6%	97.2%	97.3%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Participating Key personnel	64.0	64.0	64.0	67.0	58.0	62.0	59.0	57.0
Total Key personnel	64.0	65.0	64.0	67.0	59.0	62.0	60.0	57.0
Indicator value	100.0%	98.5%	100.0%	100.0%	98.3%	100.0%	98.3%	100.0%

Licensee Comments: none

Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
Successful siren-tests	63	63	63	63	63	63	63	63
Total sirens-tests	63	63	63	63	63	63	63	63
Indicator value	99.6%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0


Notes

Occupational Exposure Control Effectiveness	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
High radiation area occurrences	0	0	0	0	0	0	0	1
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	1

Licensee Comments:

4Q/08: A locked high radiation area was discovered in an area that was not locked or guarded when an RP technician performed a pre-job survey. The area was subsequently guarded until locked high radiation area controls were implemented. No workers had entered the area until the time the survey was performed.

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.