


Turkey Point 4

2Q/2009 Performance Indicators

Licensee's General Comments: The 3/30/09 siren test data was not in the original submittal made in 1st quarter 2009. This affected data for both units 3 and 4. Unit 3 also had a correction to 2Q2008 RCS activity data.

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09
Unplanned scrams	0	0	2.0	0	0	0	0	0
Critical hours	2077.1	2209.0	2098.6	1255.6	2019.8	2144.4	2159.0	2184.0
Indicator value	0	0	1.6	1.8	1.8	1.9	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09
Unplanned power changes	1.0	0	0	0	0	0	1.0	0
Critical hours	2077.1	2209.0	2098.6	1255.6	2019.8	2144.4	2159.0	2184.0
Indicator value	1.8	0.8	0.8	0.9	0	0	0.9	0.8

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09
Safety System Functional Failures	0	0	0	0	1	1	0	0
Indicator value	0	0	0	0	1	2	2	2

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09
UAI (ΔCDF)	6.60E-09	1.70E-09	1.70E-09	1.60E-09	2.00E-09	1.80E-09	4.50E-09	4.60E-09
URI (ΔCDF)	-3.50E-09	-7.10E-09	-7.20E-09	-7.60E-09	-7.70E-09	-1.40E-08	-1.40E-08	-1.40E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	3.10E-09	-5.40E-09	-5.50E-09	-6.00E-09	-5.70E-09	-1.22E-08	-9.50E-09	-9.40E-09

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09
UAI (Δ CDF)	-1.60E-09	7.60E-11	6.90E-11	1.10E-10	3.50E-10	5.60E-10	5.40E-10	4.80E-10
URI (Δ CDF)	2.30E-08	1.40E-09	1.40E-09	1.40E-09	1.40E-09	1.40E-09	-1.10E-09	-1.10E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.14E-08	1.48E-09	1.47E-09	1.51E-09	1.75E-09	1.96E-09	-5.60E-10	-6.20E-10

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09
UAI (Δ CDF)	7.30E-09	5.60E-09	8.60E-10	4.50E-10	3.30E-10	-2.50E-11	3.60E-09	4.60E-09
URI (Δ CDF)	1.60E-07	3.80E-08	3.80E-08	3.80E-08	3.80E-08	-9.80E-08	-1.00E-07	-1.00E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.67E-07	4.36E-08	3.89E-08	3.85E-08	3.83E-08	-9.80E-08	-9.64E-08	-9.54E-08

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09
UAI (Δ CDF)	5.60E-10	9.50E-10	-3.50E-11	-4.70E-10	-4.70E-10	-4.70E-10	-4.70E-10	-4.70E-10
URI (Δ CDF)	4.80E-09	2.90E-09	2.70E-09	-1.80E-09	-1.80E-09	-1.80E-09	-1.90E-09	-1.90E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	5.36E-09	3.85E-09	2.67E-09	-2.27E-09	-2.27E-09	-2.27E-09	-2.37E-09	-2.37E-09

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09
UAI (Δ CDF)	5.10E-08	6.00E-10	8.00E-10	9.90E-10	9.60E-10	1.30E-09	1.50E-09	1.60E-09
URI (Δ CDF)	1.20E-09	8.70E-11	3.70E-10	6.00E-11	6.10E-11	6.20E-11	6.10E-11	6.00E-11
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	5.22E-08	6.87E-10	1.17E-09	1.05E-09	1.02E-09	1.36E-09	1.56E-09	1.66E-09

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	7/07	8/07	9/07	10/07	11/07	12/07	1/08	2/08	3/08	4/08	5/08	6/08
Maximum activity	0.000427	0.000458	0.000641	0.000641	0.000580	0.000549	0.000710	0.000605	0.000657	0.000005	0.000286	0.000280
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0	0	0

Reactor Coolant System Activity	7/08	8/08	9/08	10/08	11/08	12/08	1/09	2/09	3/09	4/09	5/09	6/09
Maximum activity	0.000308	0.000308	0.000319	0.000320	0.000369	0.000377	0.000402	0.000391	0.000489	0.000424	0.000459	0.000461
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	7/07	8/07	9/07	10/07	11/07	12/07	1/08	2/08	3/08	4/08	5/08	6/08
Maximum leakage	0.050	0.040	0.040	0.040	0.050	0.080	0.080	0.060	0.060	N/A	0.090	0.050
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.5	0.4	0.4	0.4	0.5	0.8	0.8	0.6	0.6	N/A	0.9	0.5

Reactor Coolant System Leakage	7/08	8/08	9/08	10/08	11/08	12/08	1/09	2/09	3/09	4/09	5/09	6/09
Maximum leakage	0.160	0.220	0.140	0.140	0.120	0.050	0.030	0.040	0.060	0.020	0.040	0.020
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.6	2.2	1.4	1.4	1.2	0.5	0.3	0.4	0.6	0.2	0.4	0.2

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09
Successful opportunities	30.0	36.0	37.0	40.0	20.0	38.0	68.0	44.0
Total opportunities	30.0	38.0	45.0	42.0	20.0	41.0	72.0	44.0
Indicator value	96.3%	96.2%	93.5%	93.9%	93.6%	93.0%	93.8%	94.3%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09
Participating Key personnel	83.0	82.0	80.0	85.0	92.0	85.0	81.0	80.0
Total Key personnel	83.0	82.0	80.0	85.0	92.0	85.0	81.0	84.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	95.2%

Licensee Comments: none

Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09
Successful siren-tests	328	376	375	329	372	326	376	328
Total sirens-tests	329	376	376	329	376	329	376	329
Indicator value	99.6%	99.8%	99.8%	99.9%	99.7%	99.4%	99.5%	99.4%

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.