


South Texas 2

3Q/2009 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
Unplanned scrams	0	0	0	0	0	0	0	0
Critical hours	2209.0	2183.0	2184.0	2208.0	1485.9	2159.0	2184.0	1951.9
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
Unplanned power changes	0	0	0	0	0	0	0	0
Critical hours	2209.0	2183.0	2184.0	2208.0	1485.9	2159.0	2184.0	1951.9
Indicator value	0.9	0.9	0.8	0	0	0	0	0

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (PWR)



Thresholds: White > 5.0


Notes

Safety System Functional Failures (PWR)	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
Safety System Functional Failures	0	0	0	0	1	0	0	0
Indicator value	0	0	0	0	1	1	1	1

Licensee Comments:

4Q/08: LERs issued in Dec. - LER 2-08-001 Fuel Assembly Storage, LER 2-08-002 Loss of RHR SSFF* *Further review determined that LER 2-08-002, Loss of RHR) and Valid Actuation of Safety Systems submitted in Dec. 2008 should have been SSFF. No color change.

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
UAI (Δ CDF)	3.40E-07	3.20E-07	-8.00E-08	-2.00E-08	-2.10E-07	-1.40E-07	1.70E-07	2.40E-07
URI (Δ CDF)	-9.10E-07	-9.00E-07	-8.80E-07	-8.70E-07	-8.60E-07	-8.40E-07	-8.20E-07	-8.00E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-5.70E-07	-5.80E-07	-9.60E-07	-8.90E-07	-1.07E-06	-9.80E-07	-6.50E-07	-5.60E-07

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
UAI (Δ CDF)	-1.90E-08	-7.80E-09	-1.60E-08	-2.70E-08	-2.70E-08	-2.70E-08	-1.70E-08	2.00E-08
URI (Δ CDF)	-1.40E-08	-1.40E-08	-1.40E-08	-1.40E-08	-1.40E-08	-1.40E-08	-1.40E-08	-1.40E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.30E-08	-2.18E-08	-3.00E-08	-4.10E-08	-4.10E-08	-4.10E-08	-3.10E-08	6.00E-09

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
UAI (Δ CDF)	-2.30E-08	-3.60E-08	-2.90E-08	4.50E-08	1.40E-07	9.80E-08	1.50E-07	1.40E-07
URI (Δ CDF)	-1.70E-07	-1.70E-07	-1.70E-07	-1.80E-07	-1.80E-07	-1.80E-07	-1.80E-07	-1.80E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.93E-07	-2.06E-07	-1.99E-07	-1.35E-07	-4.00E-08	-8.20E-08	-3.00E-08	-4.00E-08

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
UAI (Δ CDF)	-5.70E-09	-5.70E-09	-5.70E-09	-3.90E-09	-3.40E-09	-4.60E-09	-5.10E-09	6.80E-09
URI (Δ CDF)	-3.10E-09	-3.00E-09	-3.00E-09	-3.00E-09	-2.90E-09	-2.90E-09	-2.90E-09	-2.80E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-8.80E-09	-8.70E-09	-8.70E-09	-6.90E-09	-6.30E-09	-7.50E-09	-8.00E-09	4.00E-09

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
UAI (Δ CDF)	1.20E-07	1.10E-07	-2.20E-09	-2.70E-08	-2.70E-08	-2.70E-08	3.20E-08	4.90E-08
URI (Δ CDF)	-6.50E-08	-6.40E-08	-7.30E-08	-7.10E-08	-7.00E-08	-6.80E-08	-6.60E-08	1.40E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	5.50E-08	4.60E-08	-7.52E-08	-9.80E-08	-9.70E-08	-9.50E-08	-3.40E-08	1.89E-07

Licensee Comments: none

Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Activity	10/07	11/07	12/07	1/08	2/08	3/08	4/08	5/08	6/08	7/08	8/08	9/08
Maximum activity	0.000089	0.000091	0.000096	0.000102	0.000101	0.000107	0.000103	0.000105	0.000113	0.000120	0.000133	0.000138
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0
Reactor Coolant System Activity	10/08	11/08	12/08	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09
Maximum activity	0.000123	0.000050	0.000065	0.000060	0.000064	0.000071	0.000066	0.000069	0.000077	0.000083	0.000076	0.000075
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	10/07	11/07	12/07	1/08	2/08	3/08	4/08	5/08	6/08	7/08	8/08	9/08
Maximum leakage	0.067	0.067	0.062	0.059	0.072	0.071	0.070	0.061	0.054	0.054	0.055	0.053
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.7	0.7	0.6	0.6	0.7	0.7	0.7	0.6	0.5	0.5	0.6	0.5
Reactor Coolant System Leakage	10/08	11/08	12/08	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09
Maximum leakage	0.045	0.046	0.052	0.064	0.042	0.045	0.049	0.039	0.045	0.041	0.036	0.048
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.5	0.5	0.5	0.6	0.4	0.5	0.5	0.4	0.5	0.4	0.4	0.5

Licensee Comments: none

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%


Notes

Drill/Exercise Performance	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
Successful opportunities	86.0	0	23.0	37.0	6.0	3.0	93.0	56.0
Total opportunities	86.0	0	23.0	40.0	6.0	3.0	93.0	59.0
Indicator value	97.2%	96.9%	97.8%	97.2%	97.2%	98.1%	99.0%	98.1%

Licensee Comments:

3Q/09: Revised 3Q08 and 2Q09 Drill/Exercise Performance

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
Participating Key personnel	118.0	112.0	118.0	109.0	110.0	111.0	130.0	130.0
Total Key personnel	120.0	119.0	118.0	109.0	110.0	115.0	130.0	130.0
Indicator value	98.3%	94.1%	100.0%	100.0%	100.0%	96.5%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
Successful siren-tests	222	256	256	223	256	256	254	256
Total sirens-tests	224	256	256	224	256	256	256	256
Indicator value	99.4%	99.6%	99.8%	99.7%	99.9%	99.9%	99.7%	99.8%

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.